

LICHELAND GOEREE, Netherlands

WMO: 063200

Lat: 51.926N

Lon: 3.670E

Elev: 19

StdP: 101.10

Time Zone: 1.00 (EUC)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-2.0	-0.6	-7.5	2.0	-0.9	-5.2	2.4	0.6	19.8	7.1	18.4	7.3	6.9	70	0.786

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	2.5	23.3	18.6	21.7	18.1	20.4	17.6	19.5	22.1	18.7	20.9	18.1	20.0	5.5	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.5	13.4	20.6	17.8	12.8	20.1	17.2	12.3	19.4	55.5	22.1	53.2	21.0	51.2	20.1	24.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)
(4) 17.3	15.6	14.2	DB	-2.6	27.9	1.9	2.5	-4.0	29.7	-5.1	31.2	-6.2	32.6	-7.6	34.5	(4)
(5)			WB	-4.0	21.1	2.2	1.0	-5.6	21.8	-6.9	22.4	-8.2	23.0	-9.8	23.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	11.3	5.4	5.1	6.5	9.2	12.3	15.1	17.4	18.2	16.7	13.3	9.5	6.5		
	DBStd	5.25	2.73	2.69	2.45	2.60	2.51	2.23	2.07	1.82	1.87	2.39	2.50	3.00		
	HDD10.0	592	143	137	110	46	6	0	0	0	0	4	36	110		
	HDD18.3	2609	402	370	366	274	187	101	43	23	57	156	264	366		
	CDD10.0	1071	0	0	2	21	78	154	230	256	200	107	22	2		
	CDD18.3	46	0	0	0	0	1	4	14	20	7	0	0	0		
	CDH23.3	66	0	0	0	0	2	11	24	23	5	0	0	0		
	CDH26.7	11	0	0	0	0	1	1	6	2	1	0	0	0		
(14) Wind	WSAvg	7.6	9.0	8.5	7.6	6.7	7.0	6.5	6.5	6.7	7.1	8.2	8.7	9.0		
(15) Precipitation	PrecAvg	850	69	63	46	41	55	70	79	84	83	82	93	85		
	PrecMax	1093	169	122	120	77	112	134	165	175	212	180	148	169		
	PrecMin	607	5	19	13	0	17	20	15	13	16	16	9	18		
	PrecStd	115	36	27	26	21	26	32	42	47	53	37	34	39		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.0	11.1	14.4	18.3	21.8	25.0	26.0	25.9	23.1	19.7	15.4	12.5		
		MCWB	9.5	8.1	10.2	12.4	14.8	18.3	19.5	19.7	18.9	16.4	13.8	10.7		
	2%	DB	10.0	9.9	11.5	15.9	18.8	21.2	22.8	23.3	21.1	17.9	14.3	11.6		
		MCWB	8.8	8.1	8.9	11.8	14.4	17.2	18.6	18.9	17.8	15.9	12.7	10.1		
	5%	DB	9.4	9.1	10.0	13.9	16.8	19.0	21.1	21.6	19.9	17.0	13.6	10.8		
		MCWB	8.1	7.7	8.4	10.8	13.7	16.4	18.1	18.5	17.3	15.1	11.9	9.4		
	10%	DB	8.7	8.3	9.2	12.4	15.4	17.5	19.9	20.2	19.0	16.2	12.8	10.1		
		MCWB	7.5	7.0	7.9	10.3	13.1	15.4	17.4	17.9	16.7	14.3	10.9	8.7		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.9	9.2	10.8	13.5	16.6	19.3	20.4	20.7	19.6	17.1	14.2	11.2		
		MCDB	10.5	10.0	13.3	16.7	19.7	22.8	24.0	23.9	22.9	18.7	14.9	11.9		
	2%	WB	9.1	8.6	9.4	12.2	15.0	17.7	19.2	19.6	18.5	16.1	13.2	10.5		
		MCDB	9.7	9.4	10.9	14.6	17.3	20.2	21.8	22.0	20.4	17.6	14.2	11.3		
	5%	WB	8.4	7.9	8.7	11.3	14.1	16.6	18.5	18.9	17.7	15.4	12.2	9.6		
		MCDB	9.1	8.8	9.7	13.3	16.1	18.7	20.6	21.0	19.3	16.8	13.4	10.5		
	10%	WB	7.7	7.2	8.1	10.4	13.3	15.7	17.7	18.2	17.1	14.7	11.2	8.9		
		MCDB	8.5	8.1	9.0	12.2	15.2	17.2	19.5	20.1	18.8	16.1	12.5	9.9		
(35) Mean Daily Temperature Range	5% DB	MDBR	2.5	2.6	2.8	3.2	2.9	2.8	2.5	2.5	2.5	2.7	2.6	2.7		
		MCDBR	2.7	3.1	4.3	6.3	6.0	6.0	4.9	4.8	3.8	3.2	3.0	2.7		
	5% WB	MCWBR	2.9	2.6	3.1	3.3	3.3	3.6	2.9	2.9	2.8	3.0	3.1	2.8		
		MCWBR	2.5	2.8	3.9	5.6	5.1	5.1	4.3	3.8	3.2	3.1	2.8	2.6		
(40) Clear-Sky Solar Irradiance	taub	taub	0.337	0.355	0.388	0.411	0.419	0.414	0.420	0.411	0.392	0.371	0.348	0.330		
		taud	2.358	2.357	2.280	2.255	2.295	2.322	2.316	2.355	2.399	2.416	2.376	2.344		
	Ebn at Noon	Ebn at Noon	656	755	797	823	835	842	829	816	789	728	635	593		
		Edh at Noon	63	82	106	122	123	121	120	110	94	77	62	55		
(44) All-Sky Solar Radiation	RadAvg	RadAvg	0.72	1.42	2.69	4.43	5.29	5.66	5.37	4.56	3.29	1.84	0.85	0.54		
		RadStd	0.06	0.26	0.31	0.39	0.35	0.37	0.56	0.35	0.23	0.16	0.08	0.06		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (80 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page