

EURO PLATFORM, Netherlands

WMO: 063210

Lat: 51.998N

Lon: 3.275E

Elev: 18

StdP: 101.11

Time Zone: 1.00 (EUC)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-1.2	0.1	-7.0	2.1	0.1	-4.7	2.5	1.1	19.8	7.4	18.5	7.5	8.1	80	0.799

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	2.2	21.6	18.4	20.4	17.8	19.6	17.3	19.0	20.7	18.3	20.0	17.7	19.3	5.5	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
18.2	13.1	20.0	17.6	12.6	19.5	17.0	12.2	19.0	53.9	20.8	52.0	20.1	50.2	19.4	22.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
17.4	15.9	14.5	DB	-1.3	25.3	1.7	2.6	-2.6	27.2	-3.6	28.7	-4.5	30.1	-5.8	32.0
			WB	-3.1	20.4	2.0	0.9	-4.5	21.1	-5.7	21.6	-6.8	22.1	-8.2	22.8

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	11.3	5.9	5.6	6.6	8.9	11.7	14.4	16.9	17.9	16.6	13.6	10.0	7.2
	DBStd	4.88	2.77	2.63	2.25	2.26	2.11	1.98	1.79	1.55	1.74	2.25	2.29	2.84
	HDD10.0	534	128	123	106	48	7	1	0	0	0	3	27	92
	HDD18.3	2593	386	357	363	284	204	119	53	27	56	148	251	346
	CDD10.0	1009	1	0	1	13	61	133	213	244	199	113	26	4
	CDD18.3	27	0	0	0	0	0	2	8	13	5	0	0	0
	CDH23.3	15	0	0	0	0	1	2	8	4	1	0	0	0
	CDH26.7	2	0	0	0	0	0	0	2	0	0	0	0	0
Wind	WSAvg	7.8	9.4	8.8	7.7	6.8	6.9	6.5	6.5	6.7	7.3	8.5	9.1	9.5
Precipitation	PrecAvg	835	67	61	45	39	51	68	76	83	82	83	93	84
	PrecMax	1023	166	116	126	78	106	144	171	182	206	185	150	165
	PrecMin	600	6	21	12	0	17	14	18	10	15	17	10	17
	PrecStd	108	36	27	26	20	26	32	43	48	53	38	36	38
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.6	11.0	12.2	16.1	18.6	21.9	23.4	23.6	21.9	19.0	15.7	13.0
		MCWB	10.4	9.1	9.1	11.6	14.1	17.0	18.7	19.4	18.7	16.5	14.1	11.5
	2%	DB	10.6	10.0	10.6	14.0	16.3	19.2	21.0	21.8	20.3	17.9	14.8	12.3
		MCWB	9.4	8.6	8.7	10.8	13.4	16.3	18.1	18.7	17.8	16.0	13.2	10.9
	5%	DB	10.0	9.4	9.7	12.5	15.1	17.5	19.9	20.6	19.6	17.1	14.0	11.5
		MCWB	8.7	8.0	8.2	10.3	12.9	15.5	17.6	18.1	17.4	15.2	12.3	10.0
	10%	DB	9.3	8.7	9.2	11.5	14.2	16.6	19.0	19.7	18.9	16.5	13.1	10.7
		MCWB	8.0	7.4	7.8	9.7	12.4	14.9	17.0	17.5	16.9	14.5	11.2	9.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.7	9.7	9.7	12.2	15.2	18.0	19.6	20.1	19.4	17.0	14.3	12.1
		MCDB	11.3	10.4	11.1	14.5	17.1	20.7	22.0	22.4	21.3	18.2	15.2	12.8
	2%	WB	9.8	9.1	9.1	11.2	14.0	16.7	18.6	19.1	18.6	16.2	13.5	11.2
		MCDB	10.4	9.8	10.2	13.2	15.5	18.5	20.5	20.9	19.9	17.6	14.6	12.1
	5%	WB	9.0	8.3	8.6	10.5	13.2	15.7	17.9	18.5	17.9	15.5	12.5	10.3
		MCDB	9.8	9.1	9.6	12.3	14.7	17.2	19.5	20.1	19.2	16.9	13.8	11.2
	10%	WB	8.2	7.6	8.1	9.9	12.6	15.1	17.2	17.9	17.2	14.9	11.5	9.4
		MCDB	9.1	8.5	9.0	11.3	14.0	16.4	18.6	19.5	18.7	16.3	12.9	10.4
Mean Daily Temperature Range	5% DB	MDBR	2.5	2.3	2.4	2.7	2.4	2.4	2.2	2.2	2.4	2.5	2.6	
		MCDBR	2.6	2.6	3.0	4.4	4.2	4.4	3.7	3.4	2.8	2.8	2.7	
		MCWBR	3.1	2.4	2.6	2.5	2.7	3.0	2.4	2.5	2.4	2.8	3.3	3.2
	5% WB	MCDBR	2.6	2.4	2.8	4.0	3.8	3.7	3.5	2.9	2.6	2.7	2.8	2.7
		MCWBR	3.2	2.5	2.6	2.5	2.7	2.9	2.6	2.5	2.5	3.0	3.3	3.3
Clear-Sky Solar Irradiance	taub	0.335	0.352	0.386	0.409	0.416	0.413	0.417	0.408	0.390	0.369	0.345	0.328	
	taud	2.366	2.373	2.298	2.274	2.315	2.340	2.338	2.378	2.416	2.428	2.386	2.350	
	Ebn at Noon	658	759	800	826	838	843	832	819	791	730	638	596	
	Edh at Noon	62	81	105	120	121	119	118	108	93	76	61	54	
All-Sky Solar Radiation	RadAvg	0.71	1.43	2.71	4.48	5.35	5.72	5.43	4.62	3.32	1.83	0.85	0.54	
	RadStd	0.06	0.25	0.30	0.39	0.35	0.35	0.56	0.34	0.22	0.17	0.08	0.06	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (79 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page