

HOEK VAN HOLLAND, Netherlands

WMO: 063300

Lat: 51.9911N

Lon: 4.1217E

Elev: 46

StdP: 14.67

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	23.3	26.5	14.4	11.4	26.7	19.2	14.4	28.3	41.9	43.6	38.7	44.0	12.3	80	0.745

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	11.8	81.4	66.9	76.9	65.4	73.4	64.5	69.2	78.0	67.3	74.3	65.7	71.5	11.7	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.3	96.9	72.2	64.7	91.8	70.4	63.3	87.3	68.9	33.2	78.0	31.8	74.7	30.6	71.6	77.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 35.8	32.0	29.0	DB	19.9	92.0	4.5	3.6	16.7	94.6	14.0	96.7	11.5	98.7	8.3	101.3	(4)
(5)			WB	18.8	73.1	4.6	1.7	15.5	74.3	12.8	75.3	10.2	76.2	6.9	77.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	52.1	39.8	40.6	44.3	50.1	55.8	60.4	64.6	65.1	60.7	54.1	47.0	41.3	(6)
(7)		DBStd	10.56	6.50	6.02	5.35	5.92	5.80	4.84	4.70	4.23	4.29	5.29	5.45	6.61	(7)
(8)		HDD50	1259	318	265	186	69	10	0	0	0	0	22	117	272	(8)
(9)		HDD65	4867	782	684	641	448	294	156	62	48	141	338	540	733	(9)
(10)		CDD50	2012	1	1	11	72	189	312	454	469	322	150	27	4	(10)
(11)		CDD65	144	0	0	0	1	8	18	51	52	13	1	0	0	(11)
(12)		CDH74	755	0	0	0	8	64	117	270	246	49	1	0	0	(12)
(13)		CDH80	205	0	0	0	0	10	32	84	69	10	0	0	0	(13)
(14)	Wind	WSAvg	15.3	17.4	16.6	15.7	14.1	14.6	14.2	13.5	13.5	14.3	15.8	16.4	17.2	(14)
(15)	Precipitation	PrecAvg	34.6	2.9	2.6	1.9	1.6	2.2	2.8	3.2	3.8	3.4	3.3	3.8	3.3	(15)
(16)		PrecMax	46.6	6.6	4.8	4.0	3.6	4.2	5.4	6.9	8.0	9.6	7.0	6.3	6.3	(16)
(17)		PrecMin	24.4	0.3	0.7	0.4	0.0	0.7	0.9	0.7	0.9	0.7	0.5	0.3	0.6	(17)
(18)		PrecStd	5.0	1.5	1.1	1.0	0.9	1.0	1.4	1.7	2.2	2.2	1.6	1.5	1.5	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	53.1	56.3	64.4	74.4	80.6	84.8	88.6	87.3	79.5	71.1	60.7	55.2	(19)
(20)			MCWB	50.5	48.6	52.8	57.6	61.6	68.3	69.1	68.9	67.0	63.1	56.8	52.4	(20)
(21)		2%	DB	50.7	52.0	57.9	68.0	74.4	76.7	80.6	80.4	73.4	65.8	57.6	53.0	(21)
(22)			MCWB	48.7	47.8	50.5	55.5	61.0	65.1	67.0	67.4	64.4	60.3	54.8	50.7	(22)
(23)		5%	DB	49.0	49.7	54.0	63.3	68.8	71.6	75.7	75.4	70.1	63.1	55.9	51.3	(23)
(24)			MCWB	47.0	47.0	48.8	53.6	58.9	62.9	66.4	66.2	63.1	59.0	53.3	49.2	(24)
(25)		10%	DB	47.4	48.0	51.3	58.8	64.7	67.9	72.1	72.0	67.3	61.1	54.2	49.4	(25)
(26)			MCWB	45.5	45.6	47.5	51.9	57.4	61.5	64.7	64.4	61.5	57.5	51.5	47.4	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	51.1	50.4	54.7	59.5	65.8	70.0	71.7	71.4	68.6	63.6	57.6	53.1	(27)
(28)			MADB	52.3	53.2	60.7	70.4	77.0	80.8	81.5	81.8	77.1	69.0	59.4	54.5	(28)
(29)		2%	WB	49.1	48.7	51.7	56.5	62.1	66.5	69.2	69.0	66.0	61.3	55.5	51.3	(29)
(30)			MADB	50.4	51.0	56.0	65.4	70.1	74.7	78.0	77.1	71.8	64.7	57.3	52.7	(30)
(31)		5%	WB	47.3	47.3	49.6	54.5	59.9	63.9	67.2	67.2	64.3	59.8	53.7	49.6	(31)
(32)			MADB	48.6	49.3	53.1	61.5	67.0	70.0	73.9	73.4	68.6	62.7	55.6	51.0	(32)
(33)		10%	WB	45.9	45.9	47.9	52.6	58.0	62.0	65.5	65.6	62.7	58.2	51.9	47.7	(33)
(34)			MADB	47.2	47.8	50.7	57.7	64.0	66.8	70.9	70.8	66.5	60.7	53.7	49.3	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	6.7	8.0	9.9	12.5	12.2	11.5	11.3	11.8	11.0	9.5	7.4	6.6	(35)
(36)			MCDBR	6.7	9.5	14.8	20.2	20.2	19.8	19.1	19.0	15.7	11.4	8.0	6.4	(36)
(37)			MCWBR	6.3	6.9	9.0	9.9	9.8	10.4	9.2	9.2	8.5	7.3	6.7	6.1	(37)
(38)		5% WB	MCDBR	6.5	8.4	12.5	17.4	17.6	16.7	16.1	15.9	13.6	10.6	7.4	6.4	(38)
(39)			MCWBR	6.5	6.8	8.4	9.2	9.3	9.7	8.7	8.6	8.1	7.6	6.8	6.5	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.339	0.358	0.391	0.415	0.423	0.418	0.425	0.416	0.395	0.373	0.350	0.334	(40)	
(41)		taud	2.338	2.333	2.256	2.228	2.269	2.299	2.288	2.327	2.376	2.393	2.356	2.326	(41)	
(42)		Ebn at Noon	206	237	251	259	264	266	261	257	249	229	199	185	(42)	
(43)		Edh at Noon	20	27	35	40	40	39	39	36	30	25	20	17	(43)	
(44)	All-Sky Solar Radiation	RadAvg	226	446	837	1365	1645	1760	1666	1408	1019	578	265	170	(44)	
(45)		RadStd	22	82	100	130	113	119	179	113	81	50	25	20	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
		N/A	N/A	+3.26	N/A	N/A	N/A	N/A	-203	+119	N/A	(46)
(47)	Regional (80 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page