

GILZE RIJEN, Netherlands

WMO: 063500

Lat: 51.5650N

Lon: 4.9353E

Elev: 49

StdP: 14.67

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	19.1	23.1	13.1	10.7	22.8	17.4	13.3	24.8	26.4	47.4	23.7	46.2	6.3	80	0.544

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.7	85.8	68.0	81.6	66.6	77.9	64.9	70.0	81.5	68.2	78.1	66.5	75.3	8.2	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.3	96.9	73.8	64.6	91.4	71.7	63.1	86.7	70.1	34.0	82.2	32.4	78.3	31.1	75.6	77.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 20.8	18.4	16.4	DB	12.3	93.0	5.9	3.4	8.0	95.5	4.5	97.5	1.2	99.4	-3.1	101.8	(4)
(5)			WB	11.6	73.8	5.8	1.5	7.5	74.9	4.1	75.7	0.8	76.6	-3.4	77.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	51.1	38.0	39.2	43.7	49.7	56.1	61.2	65.1	64.4	58.9	52.3	44.6	39.3	(6)
(7)		DBStd	11.60	7.84	7.33	6.28	6.75	6.48	5.82	5.85	5.18	4.97	6.09	6.44	7.66	(7)
(8)		HDD50	1559	374	305	210	88	16	0	0	0	1	46	182	337	(8)
(9)		HDD65	5250	836	723	661	461	285	143	70	75	192	395	612	797	(9)
(10)		CDD50	1966	2	3	14	78	206	337	469	446	269	117	20	5	(10)
(11)		CDD65	183	0	0	0	1	10	30	75	56	11	0	0	0	(11)
(12)		CDH74	1796	0	0	0	28	130	326	706	515	87	4	0	0	(12)
(13)		CDH80	524	0	0	0	2	22	89	234	162	15	0	0	0	(13)
(14)	Wind	WSAvg	7.8	9.2	8.9	8.8	7.9	7.8	7.3	6.8	6.6	6.8	7.6	7.8	8.7	(14)
(15)	Precipitation	PrecAvg	33.8	2.8	2.6	2.1	1.8	2.5	2.8	3.5	3.3	2.8	2.9	3.3	3.3	(15)
(16)		PrecMax	41.1	5.6	5.3	4.1	3.8	4.8	5.0	6.7	8.2	7.4	7.2	5.1	6.6	(16)
(17)		PrecMin	24.5	0.2	0.7	0.4	0.0	0.9	0.8	0.8	0.8	0.5	0.9	0.4	0.8	(17)
(18)		PrecStd	4.2	1.3	1.1	1.1	1.0	1.2	1.3	1.5	1.8	1.6	1.2	1.2	1.5	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	55.8	58.6	66.2	78.0	83.0	88.5	92.5	90.0	81.7	73.1	62.5	56.8	(19)
(20)			MCWB	52.2	50.3	54.7	59.5	64.8	68.7	69.7	69.9	66.5	63.6	57.2	53.5	(20)
(21)		2%	DB	53.0	54.0	61.0	71.5	77.4	82.0	86.0	84.5	76.1	67.1	58.5	54.7	(21)
(22)			MCWB	50.4	49.4	51.9	57.1	61.7	66.4	68.0	67.7	64.6	60.8	54.9	52.2	(22)
(23)		5%	DB	50.7	51.8	56.7	66.3	73.4	77.4	81.6	79.8	71.6	63.8	56.2	52.5	(23)
(24)			MCWB	48.2	48.2	50.1	54.8	60.1	64.4	66.9	66.7	62.6	58.9	53.2	50.0	(24)
(25)		10%	DB	48.3	49.5	53.6	61.7	69.0	73.2	77.2	75.1	68.0	61.2	53.9	49.9	(25)
(26)			MCWB	46.1	46.6	48.8	52.8	58.5	62.7	65.5	64.4	60.6	57.3	51.4	47.8	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	53.3	52.2	55.7	61.2	67.5	71.4	72.3	72.2	68.3	64.3	58.0	54.6	(27)
(28)			MCD B	54.8	55.6	62.5	73.2	79.3	83.4	85.6	85.0	78.5	69.7	60.6	55.8	(28)
(29)		2%	WB	50.6	50.4	53.2	58.1	64.3	68.1	70.1	69.6	65.9	61.6	55.6	52.6	(29)
(30)			MCD B	52.6	53.2	58.5	68.2	73.2	78.1	82.0	80.9	73.7	66.0	58.1	54.5	(30)
(31)		5%	WB	48.4	48.6	51.2	55.8	61.5	65.9	68.3	67.5	63.7	59.6	53.6	50.3	(31)
(32)			MCD B	50.4	51.3	55.6	64.5	70.1	75.0	78.5	76.5	69.6	63.0	55.8	52.2	(32)
(33)		10%	WB	46.3	46.7	49.3	53.7	59.4	63.7	66.5	65.7	61.9	57.9	51.5	47.9	(33)
(34)			MCD B	48.1	49.2	53.0	60.4	67.2	71.3	75.0	73.4	66.8	60.7	53.5	49.7	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	9.4	11.2	14.5	18.0	18.1	18.0	17.7	17.9	16.2	13.7	10.5	8.9	(35)
(36)			MCDBR	9.8	13.5	20.7	25.2	25.6	25.5	25.4	25.2	21.2	16.3	11.1	9.3	(36)
(37)			MCWBR	8.8	9.8	13.0	13.0	12.4	12.4	10.8	11.1	11.0	10.5	8.6	8.2	(37)
(38)		5% WB	MCD BR	9.6	11.3	17.3	21.8	21.8	22.0	22.0	22.1	18.4	15.1	10.5	9.3	(38)
(39)			MCWBR	9.0	9.0	11.6	11.9	11.7	11.7	10.5	11.0	10.4	10.3	8.7	8.4	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.340	0.363	0.398	0.429	0.437	0.432	0.440	0.430	0.403	0.377	0.353	0.337	(40)	
(41)		taud	2.324	2.291	2.202	2.157	2.184	2.217	2.201	2.249	2.310	2.355	2.336	2.304	(41)	
(42)		Ebn at Noon	207	236	249	256	260	262	257	253	246	228	200	186	(42)	
(43)		Edh at Noon	21	28	36	43	44	43	43	39	33	26	21	18	(43)	
(44)	All-Sky Solar Radiation	RadAvg	235	452	823	1323	1592	1719	1612	1374	1013	593	276	180	(44)	
(45)		RadStd	28	87	115	141	129	135	191	120	92	47	27	22	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (85 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page