

GILZE RIJEN, Netherlands

WMO: 063500

Lat: 51.5650N

Lon: 4.9353E

Elev: 15

StdP: 101.15

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-7.2	-4.9	-10.5	1.5	-5.1	-8.1	1.9	-4.0	11.8	8.5	10.6	7.9	2.8	80	0.544

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.9	29.9	20.0	27.6	19.2	25.5	18.3	21.1	27.5	20.1	25.6	19.2	24.0	3.7	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.0	13.8	23.2	18.1	13.1	22.1	17.3	12.4	21.2	61.1	27.9	57.5	25.7	54.4	24.2	25.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.3	8.2	7.3	DB	-11.0	33.9	3.3	1.9	-13.3	35.3	-15.3	36.4	-17.1	37.4	-19.5	38.8	(4)
(5)			WB	-11.3	23.2	3.2	0.8	-13.6	23.8	-15.5	24.3	-17.3	24.8	-19.7	25.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	10.6	3.3	4.0	6.5	9.8	13.4	16.2	18.4	18.0	15.0	11.3	7.0	4.0	(6)	
	DBStd	6.44	4.35	4.07	3.49	3.75	3.60	3.23	3.25	2.88	2.76	3.38	3.58	4.26	(7)	
	HDD10.0	866	208	169	117	49	9	0	0	0	1	26	101	187	(8)	
	HDD18.3	2917	464	402	367	256	158	79	39	42	107	219	340	443	(9)	
	CDD10.0	1092	1	2	8	43	114	187	261	248	149	65	11	3	(10)	
	CDD18.3	102	0	0	0	1	6	17	42	31	6	0	0	0	(11)	
	CDH23.3	998	0	0	0	16	72	181	392	286	48	2	0	0	(12)	
	CDH26.7	291	0	0	0	1	12	49	130	90	8	0	0	0	(13)	
(14) Wind	WSAvg	3.5	4.1	4.0	3.9	3.5	3.5	3.3	3.1	2.9	3.0	3.4	3.5	3.9	(14)	
(15) Precipitation	PrecAvg	859	72	67	53	46	64	72	88	83	72	74	83	85	(15)	
	PrecMax	1045	142	135	104	96	121	127	169	209	188	184	129	167	(16)	
	PrecMin	623	6	18	10	0	22	20	21	21	12	24	10	20	(17)	
	PrecStd	107	34	29	28	25	30	33	37	46	41	31	30	39	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.2	14.8	19.0	25.6	28.3	31.4	33.6	32.2	27.6	22.8	16.9	13.8	(19)	
		MCWB	11.2	10.2	12.6	15.3	18.2	20.4	20.9	21.0	19.2	17.6	14.0	12.0	(20)	
	2%	DB	11.7	12.2	16.1	21.9	25.2	27.8	30.0	29.2	24.5	19.5	14.7	12.6	(21)	
		MCWB	10.2	9.7	11.1	13.9	16.5	19.1	20.0	19.9	18.1	16.0	12.7	11.2	(22)	
	5%	DB	10.4	11.0	13.7	19.0	23.0	25.2	27.5	26.6	22.0	17.6	13.4	11.4	(23)	
		MCWB	9.0	9.0	10.0	12.7	15.6	18.0	19.4	19.3	17.0	14.9	11.8	10.0	(24)	
	10%	DB	9.0	9.7	12.0	16.5	20.5	22.9	25.1	24.0	20.0	16.2	12.2	9.9	(25)	
		MCWB	7.8	8.1	9.3	11.5	14.7	17.1	18.6	18.0	15.9	14.0	10.8	8.8	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.8	11.2	13.2	16.2	19.7	21.9	22.4	22.3	20.2	17.9	14.4	12.5	(27)	
		MCDB	12.7	13.1	17.0	22.9	26.3	28.6	29.8	29.4	25.8	20.9	15.9	13.2	(28)	
	2%	WB	10.3	10.2	11.8	14.5	17.9	20.0	21.2	20.9	18.8	16.4	13.1	11.4	(29)	
		MCDB	11.4	11.8	14.7	20.1	22.9	25.6	27.8	27.1	23.2	18.9	14.5	12.5	(30)	
	5%	WB	9.1	9.2	10.7	13.2	16.4	18.8	20.2	19.7	17.6	15.4	12.0	10.2	(31)	
		MCDB	10.2	10.7	13.1	18.0	21.2	23.9	25.8	24.7	20.9	17.2	13.2	11.2	(32)	
	10%	WB	7.9	8.2	9.6	12.1	15.2	17.6	19.1	18.7	16.6	14.4	10.8	8.8	(33)	
		MCDB	9.0	9.6	11.7	15.8	19.6	21.8	23.9	23.0	19.3	15.9	11.9	9.8	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	5.2	6.2	8.0	10.0	10.1	10.0	9.9	10.0	9.0	7.6	5.8	5.0	(35)	
		MCDBR	5.4	7.5	11.5	14.0	14.2	14.2	14.1	14.0	11.8	9.1	6.2	5.2	(36)	
	5% WB	MCWBR	4.9	5.5	7.2	7.2	6.9	6.9	6.0	6.2	6.1	5.8	4.8	4.6	(37)	
		MCWBR	5.3	6.3	9.6	12.1	12.1	12.2	12.2	12.3	10.2	8.4	5.8	5.2	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.340	0.363	0.398	0.429	0.437	0.432	0.440	0.430	0.403	0.377	0.353	0.337	(40)	
		taud	2.324	2.291	2.202	2.157	2.184	2.217	2.201	2.249	2.310	2.355	2.336	2.304	(41)	
	Ebn at Noon		653	743	784	806	819	826	810	798	775	719	629	585	(42)	
		Edh at Noon	66	88	115	135	138	135	135	122	103	82	65	58	(43)	
(44) All-Sky Solar Radiation	RadAvg		0.74	1.42	2.60	4.17	5.02	5.42	5.08	4.33	3.19	1.87	0.87	0.57	(44)	
	RadStd		0.09	0.28	0.36	0.45	0.41	0.43	0.60	0.38	0.29	0.15	0.09	0.07	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days					
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)	
(47) Regional (85 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)	

Nomenclature: See separate page