

MAASTRICHT AACHEN AP, Netherlands

WMO: 063800

Lat: 50.9053N

Lon: 5.7619E

Elev: 375

StdP: 14.50

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	20.2	23.7	13.7	11.2	23.2	18.0	13.8	26.0	31.4	47.8	28.1	47.8	8.0	50	0.557

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.3	86.3	68.3	82.0	66.9	78.5	65.3	70.0	81.9	68.3	79.2	66.7	75.9	7.7	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.0	97.3	74.3	64.5	92.2	72.6	63.0	87.3	71.1	34.1	81.6	32.7	79.4	31.4	76.1	78.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
24.8	21.7	19.0		DB	15.4	93.3	5.8	3.3	11.2	95.7	7.8	97.6	4.6	99.5	0.4	101.9
				WB	14.7	73.5	5.8	2.1	10.5	75.0	7.1	76.3	3.9	77.5	-0.3	79.0

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	51.4	37.6	39.0	43.9	50.1	56.9	62.2	66.0	65.2	59.3	52.5	44.5	39.1	(6)
	DBStd	12.03	7.71	7.41	6.59	6.80	6.54	6.03	6.17	5.52	5.40	6.42	6.51	7.47	(7)
	HDD50	1577	385	311	206	82	14	0	0	0	1	48	186	344	(8)
	HDD65	5187	848	728	654	448	264	125	62	63	188	389	614	804	(9)
	CDD50	2099	2	3	18	85	226	366	497	472	279	125	21	5	(10)
	CDD65	235	0	0	0	1	11	41	94	71	16	1	0	0	(11)
	CDH74	1982	0	0	0	18	111	361	785	594	108	5	0	0	(12)
	CDH80	576	0	0	0	1	19	95	248	194	19	0	0	0	(13)
(14) Wind	WSAvg	9.0	10.8	10.5	9.9	8.7	8.3	8.0	7.7	7.4	7.9	9.0	9.4	10.6	(14)
(15) Precipitation	PrecAvg	30.4	2.4	2.1	2.3	2.0	2.4	2.8	2.8	2.8	2.4	2.5	2.8	2.9	(15)
	PrecMax	44.4	4.3	5.5	4.9	4.8	6.7	6.0	7.2	7.4	5.8	5.8	4.4	6.2	(16)
	PrecMin	22.2	0.2	0.2	0.3	0.2	0.6	0.3	0.5	0.5	0.4	0.3	0.8	0.6	(17)
	PrecStd	5.3	1.1	1.3	1.1	1.0	1.2	1.4	1.5	1.5	1.4	1.4	1.0	1.5	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	55.2	58.6	66.7	76.6	82.6	88.7	92.4	90.9	82.6	73.6	63.0	56.5	(19)
		MCWB	51.6	49.1	54.1	59.3	65.2	69.1	69.9	69.9	66.2	63.3	56.7	52.0	(20)
	2%	DB	52.7	53.9	61.2	71.0	76.7	82.3	86.5	85.4	77.1	68.0	58.7	54.0	(21)
		MCWB	49.7	48.4	51.4	57.1	62.1	67.3	68.7	68.1	64.7	60.4	54.2	51.0	(22)
	5%	DB	50.1	51.3	57.2	66.3	73.1	78.0	81.8	80.7	72.5	64.5	56.0	52.0	(23)
		MCWB	47.3	47.5	50.1	55.0	60.2	65.0	66.9	67.1	62.7	58.8	52.7	49.3	(24)
	10%	DB	47.8	49.2	53.8	61.8	69.1	74.0	78.1	76.1	68.4	61.7	53.7	49.4	(25)
		MCWB	45.4	46.1	48.4	52.9	58.9	63.3	65.6	64.7	60.6	57.2	50.8	47.1	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	52.7	51.3	55.5	61.2	67.8	71.7	72.6	72.4	68.4	63.9	57.4	53.6	(27)
		MCDB	54.4	55.3	63.5	72.5	78.5	83.9	86.6	85.5	79.4	71.1	61.0	55.4	(28)
	2%	WB	50.0	49.5	53.0	58.3	64.4	68.4	70.1	69.6	65.7	61.4	54.9	51.3	(29)
		MCDB	52.2	52.5	58.9	68.1	73.8	79.3	82.1	81.7	74.0	66.7	58.1	53.5	(30)
	5%	WB	47.7	48.0	51.0	55.9	61.8	66.4	68.4	67.6	63.6	59.4	53.1	49.6	(31)
		MCDB	49.9	50.8	55.8	64.1	70.1	75.6	79.2	77.9	70.8	63.7	55.9	51.8	(32)
	10%	WB	45.5	46.1	49.2	53.8	59.5	64.3	66.6	65.9	61.7	57.6	51.0	47.3	(33)
		MCDB	47.6	49.2	53.2	60.9	67.3	72.3	75.5	74.4	67.4	61.2	53.5	49.3	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	8.3	9.8	12.9	15.9	16.3	16.5	16.3	16.2	14.7	12.3	9.2	7.8	(35)
		MCDBR	9.6	12.8	18.8	22.5	22.4	23.3	23.2	23.7	20.2	15.9	11.1	9.0	(36)
	5% WB	MCWBR	8.4	9.0	11.4	12.3	11.4	11.4	9.6	10.3	10.2	9.9	8.3	7.5	(37)
		MCWBR	9.4	10.9	15.6	20.1	19.6	20.4	20.3	20.5	17.7	14.7	10.3	8.4	(38)
(40) Clear-Sky Solar Irradiance	taub		0.320	0.343	0.375	0.407	0.415	0.415	0.419	0.410	0.382	0.359	0.334	0.317	(40)
		taud	2.418	2.376	2.296	2.230	2.249	2.264	2.252	2.300	2.368	2.427	2.418	2.387	(41)
	Ebn at Noon		224	248	259	264	267	267	264	260	255	239	215	204	(42)
		Edh at Noon	19	26	34	40	41	41	41	37	31	24	19	17	(43)
(44) All-Sky Solar Radiation	RadAvg		242	456	821	1310	1561	1698	1607	1371	1023	602	284	188	(44)
	RadStd		34	89	119	149	146	150	193	135	109	52	33	27	(45)

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (83 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page