

KOKSIJDE AP, Belgium

WMO: 064000

Lat: 51.0881N

Lon: 2.6525E

Elev: 20

StdP: 14.69

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	23.4	26.8	18.2	13.8	25.5	21.9	16.4	28.4	34.8	49.9	31.3	49.9	7.3	70	0.597

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	14.7	80.7	67.2	76.6	65.6	73.3	64.2	68.9	78.0	67.2	74.5	65.4	71.5	9.0	20

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
65.8	95.1	72.6	64.3	90.2	70.6	62.8	85.6	68.9	33.0	78.4	31.6	74.6	30.3	71.5	78.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.6	24.2	21.3	DB	19.2	90.4	5.1	3.0	15.6	92.5	12.6	94.3	9.7	96.0	6.0	98.2
			WB	18.4	73.3	5.0	2.1	14.8	74.8	11.9	76.1	9.1	77.3	5.4	78.8

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	51.5	40.1	40.9	44.5	49.1	54.7	59.6	63.5	63.7	59.3	53.6	46.6	41.2
	DBStd	10.03	6.81	6.20	5.33	5.34	5.07	4.63	4.41	4.24	4.03	5.39	5.59	6.74
	HDD50	1271	310	256	181	78	12	0	0	0	0	27	129	278
	HDD65	5035	773	674	635	476	321	175	83	77	176	355	553	737
	CDD50	1805	2	3	11	52	158	288	417	424	280	138	26	6
	CDD65	94	0	0	0	0	3	13	35	36	6	1	0	0
	CDH74	672	0	0	0	4	34	115	237	236	43	3	0	0
	CDH80	152	0	0	0	0	4	28	54	60	6	0	0	0
Wind	WSAvg	9.9	11.7	11.4	11.1	9.8	9.8	8.9	8.4	8.3	8.7	9.5	10.3	11.1
Precipitation	PrecAvg	27.4	2.2	1.5	2.1	1.7	2.0	2.3	2.4	2.4	2.8	2.8	3.1	2.4
	PrecMax	35.5	5.8	3.5	4.5	3.9	4.8	5.0	6.2	5.8	6.3	8.1	6.4	5.3
	PrecMin	18.0	0.4	0.2	0.4	0.2	0.4	0.2	0.5	0.4	0.2	0.2	1.1	0.3
	PrecStd	4.8	1.1	0.9	1.1	0.8	1.0	1.3	1.4	1.4	1.7	1.9	1.5	1.2
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	55.1	57.3	64.2	73.3	78.1	83.8	86.5	87.1	79.4	72.1	61.6	56.9
		MCWB	52.4	50.2	53.5	57.8	62.4	68.2	69.8	70.3	66.1	63.3	58.2	54.2
	2%	DB	53.2	53.7	58.3	66.9	72.5	76.7	80.1	80.3	73.3	66.3	58.9	54.9
		MCWB	51.0	50.1	51.7	56.0	60.8	65.8	67.3	67.3	63.5	60.7	56.3	52.7
	5%	DB	51.1	51.7	55.1	61.9	67.4	71.7	75.6	75.4	69.6	63.5	56.7	52.9
		MCWB	48.8	48.7	50.5	53.9	59.0	63.3	65.5	66.1	61.8	59.2	54.1	50.6
	10%	DB	49.1	49.8	52.6	57.9	63.7	68.2	72.2	71.8	66.7	61.3	54.6	50.6
		MCWB	46.9	47.1	48.8	51.9	57.1	60.9	64.3	64.0	60.5	57.7	52.0	48.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	53.1	52.6	55.3	59.4	65.7	70.0	71.3	71.5	67.9	64.3	58.9	54.9
		MCDB	54.5	55.2	59.9	68.5	74.4	80.5	81.9	82.7	75.5	70.1	60.3	56.3
	2%	WB	51.2	50.7	52.9	56.8	61.9	66.7	68.9	68.9	65.4	61.8	56.5	52.9
		MCDB	52.8	53.0	56.9	64.9	69.1	75.4	77.7	77.6	71.4	65.5	58.4	54.8
	5%	WB	49.1	49.1	51.0	54.8	59.7	64.0	66.9	67.0	63.4	60.0	54.5	51.0
		MCDB	50.8	51.4	54.3	60.8	66.2	70.5	73.9	73.7	67.6	62.9	56.5	52.7
	10%	WB	47.1	47.3	49.4	52.6	57.7	61.8	65.1	65.2	61.8	58.3	52.4	48.6
		MCDB	48.9	49.6	52.3	57.3	63.2	67.1	70.9	70.5	65.9	60.9	54.3	50.4
Mean Daily Temperature Range	5% DB	MDBR	8.4	9.8	11.7	14.1	13.5	13.9	14.3	14.7	13.9	12.0	9.2	8.3
		MCDBR	9.1	11.6	16.4	21.4	21.5	21.5	21.5	21.8	19.6	14.3	10.2	8.6
		MCWBR	8.4	8.9	11.0	12.2	11.9	12.3	10.8	11.0	10.9	9.7	8.6	8.0
	5% WB	MCDWR	9.1	10.1	14.5	18.6	18.5	19.8	18.6	19.1	16.0	13.4	9.8	8.5
		MCWBR	8.7	8.4	10.3	11.2	11.0	11.9	10.3	10.5	10.0	9.7	8.6	8.1
Clear-Sky Solar Irradiance	taub	0.334	0.353	0.392	0.413	0.423	0.421	0.421	0.412	0.390	0.370	0.345	0.328	
	taud	2.366	2.348	2.243	2.215	2.240	2.267	2.275	2.318	2.367	2.396	2.378	2.346	
	Ebn at Noon	214	243	253	261	264	266	263	259	252	233	207	195	
	Edh at Noon	20	27	36	41	42	41	40	36	31	25	20	18	
All-Sky Solar Radiation	RadAvg	247	469	856	1389	1623	1763	1668	1423	1057	607	289	190	
	RadStd	22	87	108	132	125	144	168	122	72	52	30	24	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (70 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page