

KOKSIJDE AP, Belgium

WMO: 064000

Lat: 51.0881N

Lon: 2.6525E

Elev: 6

StdP: 101.25

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -4.8	(c) -2.9	(d) -7.7	(e) 2.0	(f) -3.6	(g) -5.6	(h) 2.3	(i) -2.0	(j) 15.5	(k) 9.9	(l) 14.0	(m) 10.0	(n) 3.3	(o) 70	(p) 0.597

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 8.2	(c) 27.1	(d) 19.5	(e) 24.8	(f) 18.7	(g) 22.9	(h) 17.9	(i) 20.5	(j) 25.5	(k) 19.5	(l) 23.6	(m) 18.6	(n) 21.9	(o) 4.0	(p) 20

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.8	13.6	22.6	17.9	12.9	21.5	17.1	12.2	20.5	58.9	25.8	55.6	23.7	52.5	22.0	25.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12.3	10.8	9.5	-7.1	32.4	2.8	1.7	-9.1	33.6	-10.8	34.6	-12.4	35.6	-14.4	36.8
			-7.5	22.9	2.8	1.2	-9.5	23.8	-11.2	24.5	-12.7	25.1	-14.8	26.0
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	10.8	4.5	5.0	7.0	9.5	12.6	15.3	17.5	17.6	15.2	12.0	8.1	5.1
	DBStd	5.57	3.78	3.45	2.96	2.97	2.82	2.57	2.45	2.36	2.24	2.99	3.11	3.75
	HDD10.0	706	172	142	101	43	7	0	0	0	0	15	72	154
	HDD18.3	2797	429	374	353	264	178	97	46	43	98	197	307	409
	CDD10.0	1003	1	2	6	29	88	160	232	236	156	77	14	3
	CDD18.3	52	0	0	0	0	2	7	19	20	3	1	0	0
	CDH23.3	373	0	0	0	2	19	64	132	131	24	2	0	0
	CDH26.7	84	0	0	0	0	2	16	30	33	3	0	0	0
Wind	WSAvg	4.4	5.2	5.1	5.0	4.4	4.4	4.0	3.7	3.7	3.9	4.2	4.6	5.0
Precipitation	PrecAvg	697	56	37	53	43	51	58	61	60	72	70	80	60
	PrecMax	901	147	88	114	100	122	127	157	147	160	205	163	135
	PrecMin	458	9	6	11	6	10	5	13	11	5	6	28	8
	PrecStd	123	29	22	27	21	26	34	35	35	42	48	37	31
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.9	14.0	17.9	23.0	25.6	28.8	30.3	30.6	26.3	22.3	16.5	13.8
		MCWB	11.3	10.1	12.0	14.3	16.9	20.1	21.0	21.3	18.9	17.4	14.5	12.3
	2%	DB	11.8	12.0	14.6	19.4	22.5	24.9	26.7	26.8	22.9	19.1	14.9	12.7
		MCWB	10.5	10.0	10.9	13.3	16.0	18.8	19.6	19.6	17.5	15.9	13.5	11.5
	5%	DB	10.6	10.9	12.8	16.6	19.7	22.1	24.2	24.1	20.9	17.5	13.7	11.6
		MCWB	9.3	9.3	10.3	12.2	15.0	17.4	18.6	18.9	16.5	15.1	12.3	10.3
	10%	DB	9.5	9.9	11.4	14.4	17.6	20.1	22.3	22.1	19.3	16.3	12.6	10.3
		MCWB	8.3	8.4	9.3	11.1	13.9	16.1	17.9	17.8	15.8	14.3	11.1	9.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.7	11.5	13.0	15.2	18.7	21.1	21.8	22.0	19.9	18.0	14.9	12.7
		MCDB	12.5	12.9	15.5	20.3	23.5	26.9	27.7	28.1	24.1	21.2	15.7	13.5
	2%	WB	10.6	10.4	11.6	13.8	16.6	19.3	20.5	20.5	18.6	16.6	13.6	11.6
		MCDB	11.6	11.7	13.8	18.3	20.6	24.1	25.4	25.3	21.9	18.6	14.7	12.6
	5%	WB	9.5	9.5	10.6	12.6	15.4	17.8	19.4	19.5	17.4	15.5	12.5	10.5
		MCDB	10.5	10.8	12.4	16.0	19.0	21.4	23.3	23.2	19.8	17.2	13.6	11.5
	10%	WB	8.4	8.5	9.6	11.4	14.3	16.6	18.4	18.4	16.6	14.6	11.3	9.2
		MCDB	9.4	9.8	11.3	14.0	17.3	19.5	21.6	21.4	18.8	16.1	12.4	10.2
Mean Daily Temperature Range	5% DB	MDBR	4.6	5.4	6.5	7.8	7.5	7.7	7.9	8.2	7.7	6.7	5.1	4.6
		MCDBR	5.0	6.4	9.1	11.9	11.9	11.9	11.9	12.1	10.9	7.9	5.7	4.8
		MCWBR	4.7	5.0	6.1	6.8	6.6	6.9	6.0	6.1	6.1	5.4	4.8	4.4
	5% WB	MCDBR	5.0	5.6	8.0	10.4	10.3	11.0	10.3	10.6	8.9	7.5	5.5	4.7
		MCWBR	4.8	4.7	5.7	6.2	6.1	6.6	5.7	5.8	5.5	5.4	4.8	4.5
Clear-Sky Solar Irradiance	taub		0.334	0.353	0.392	0.413	0.423	0.421	0.421	0.412	0.390	0.370	0.345	0.328
	taud		2.366	2.348	2.243	2.215	2.240	2.267	2.275	2.318	2.367	2.396	2.378	2.346
	Ebn at Noon		676	765	797	824	833	837	830	818	794	735	654	615
	Edh at Noon		64	84	112	128	131	129	126	115	98	80	63	57
All-Sky Solar Radiation	RadAvg		0.78	1.48	2.70	4.38	5.12	5.56	5.26	4.49	3.33	1.92	0.91	0.60
	RadStd		0.07	0.27	0.34	0.42	0.40	0.45	0.53	0.39	0.23	0.16	0.10	0.07

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (70 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page