

BEITEM, Belgium

WMO: 064140

Lat: 50.9039N

Lon: 3.1217E

Elev: 82

StdP: 14.65

Time Zone: 1.00 (EUC)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 24.2	(c) 27.1	(d) 18.2	(e) 13.8	(f) 26.6	(g) 21.7	(h) 16.4	(i) 29.7	(j) 27.7	(k) 48.8	(l) 25.4	(m) 48.8	(n) 6.3	(o) 60	(p) 0.546

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.9	84.0	67.0	79.8	65.0	76.7	63.2	69.1	80.6	67.1	76.8	65.3	73.4	8.0	80

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
65.2	93.5	73.1	63.5	87.9	71.3	61.9	83.0	69.4	33.2	80.9	31.6	76.9	30.2	73.3	80.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 22.1	(b) 19.1	(c) 16.8	(e) 19.2	(f) 93.1	(g) 5.2	(h) 5.1	(i) 15.4	(j) 96.8	(k) 12.4	(l) 99.8	(m) 9.5	(n) 102.6	(o) 5.7	(p) 106.3		
(a) 22.1	(b) 19.1	(c) 16.8	(e) 18.9	(f) 73.3	(g) 5.0	(h) 3.2	(i) 15.3	(j) 75.6	(k) 12.4	(l) 77.5	(m) 9.6	(n) 79.3	(o) 6.0	(p) 81.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	51.8	38.8	39.9	44.6	50.5	56.3	61.6	65.2	64.2	59.3	53.4	46.0	40.8	(6)
(7)		DBStd	10.89	6.51	5.92	5.71	6.08	6.21	5.21	5.08	4.42	4.64	5.80	6.00	6.92	(7)
(8)		HDD50	1359	349	284	181	65	11	0	0	0	0	32	146	291	(8)
(9)		HDD65	4977	812	702	632	437	279	129	59	67	180	360	569	751	(9)
(10)		CDD50	2012	2	1	14	79	207	349	471	441	279	137	27	5	(10)
(11)		CDD65	155	0	0	0	0	9	28	65	43	9	1	0	0	(11)
(12)		CDH74	1407	0	0	0	18	97	240	570	384	89	9	0	0	(12)
(13)		CDH80	363	0	0	0	0	8	56	169	113	17	0	0	0	(13)
(14)	Wind	WSAvg	8.2	9.3	9.4	9.3	8.0	8.2	8.0	7.4	7.0	6.8	7.5	8.6	9.3	(14)
(15)	Precipitation	PrecAvg	32.0	2.7	2.2	1.9	2.1	2.1	2.8	2.7	2.6	3.0	3.0	3.5	3.5	(15)
(16)		PrecMax	38.3	5.4	5.2	4.3	4.4	3.6	5.7	5.2	5.6	7.0	5.4	6.0	7.7	(16)
(17)		PrecMin	25.4	0.2	0.6	0.3	0.2	0.7	1.1	0.7	0.2	0.3	0.8	1.2	1.1	(17)
(18)		PrecStd	4.5	1.4	1.2	1.0	1.0	1.0	1.3	1.4	1.6	1.8	1.2	1.4	1.8	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	54.8	57.7	65.5	76.5	80.7	86.6	91.9	88.9	82.2	74.0	62.5	56.5	(19)
(20)			MCWB	51.9	50.1	55.0	58.4	66.1	70.6	70.5	67.2	63.3	63.4	58.2	53.2	(20)
(21)		2%	DB	52.3	52.7	60.8	71.8	76.8	79.9	84.0	82.8	75.9	68.2	59.3	54.5	(21)
(22)			MCWB	49.6	49.3	55.0	57.9	60.9	65.8	67.1	66.1	62.4	61.8	55.8	52.0	(22)
(23)		5%	DB	50.2	50.9	56.7	65.8	72.3	76.0	80.0	77.9	71.2	64.3	57.1	52.7	(23)
(24)			MCWB	47.5	48.3	51.1	55.8	59.5	64.2	65.4	63.9	61.1	59.3	53.9	50.3	(24)
(25)		10%	DB	48.0	48.9	53.4	61.2	67.7	72.0	76.1	73.9	67.9	61.7	54.7	50.4	(25)
(26)			MCWB	45.7	46.4	49.0	53.4	58.3	62.0	63.5	62.2	59.4	57.4	51.9	48.2	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	52.6	52.6	60.8	62.4	69.2	71.7	71.5	71.0	68.1	64.7	59.6	54.3	(27)
(28)			MCDWB	54.6	55.3	60.8	72.1	77.3	84.6	86.1	82.9	77.5	71.7	61.8	55.6	(28)
(29)		2%	WB	50.0	50.3	54.4	58.5	64.8	67.6	69.1	67.8	64.9	62.2	56.3	52.3	(29)
(30)			MCDWB	52.2	52.1	58.8	67.9	71.0	77.6	81.6	78.6	71.1	67.8	58.8	54.1	(30)
(31)		5%	WB	47.8	48.5	51.9	56.0	61.2	65.1	67.0	65.8	62.9	59.9	54.3	50.7	(31)
(32)			MCDWB	49.9	50.7	55.9	65.0	68.6	73.7	77.1	74.6	68.7	63.8	56.9	52.7	(32)
(33)		10%	WB	45.8	46.4	49.7	54.0	59.0	63.0	65.0	64.1	61.1	58.0	52.0	48.4	(33)
(34)			MCDWB	47.8	48.9	53.3	60.7	67.0	70.9	73.3	71.3	66.3	61.2	54.4	50.3	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	8.3	9.9	13.0	16.4	16.1	15.7	16.9	17.4	16.0	12.3	9.0	8.1	(35)
(36)			MCDBR	9.2	12.4	19.8	23.9	22.8	22.5	24.2	25.7	21.5	15.4	10.3	8.6	(36)
(37)			MCWBR	8.8	9.9	14.1	13.1	11.2	11.2	10.7	11.7	11.8	10.4	8.9	8.0	(37)
(38)		5% WB	MCDBR	9.3	12.1	17.6	21.4	19.1	20.0	21.2	20.7	18.2	15.0	10.2	8.6	(38)
(39)			MCWBR	8.9	10.4	13.6	13.6	11.8	11.0	10.9	11.4	11.9	10.8	9.2	8.3	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.333	0.354	0.392	0.418	0.428	0.425	0.426	0.417	0.393	0.370	0.345	0.328	(40)	
(41)		taud	2.359	2.332	2.223	2.177	2.196	2.227	2.231	2.276	2.331	2.381	2.367	2.336	(41)	
(42)		Ebn at Noon	216	243	253	260	263	264	262	258	251	233	208	196	(42)	
(43)		Edh at Noon	21	27	36	42	43	43	42	38	32	26	20	18	(43)	
(44)	All-Sky Solar Radiation	RadAvg	252	473	856	1379	1609	1754	1661	1415	1061	614	295	196	(44)	
(45)		RadStd	23	89	110	137	131	149	168	125	75	53	31	25	(45)	

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (69 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page