

SEMMEZAKE, Belgium

WMO: 064280

Lat: 50.9406N

Lon: 3.6697E

Elev: 123

StdP: 14.63

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	22.3	25.7	15.6	12.2	25.7	19.7	14.9	28.0	27.8	49.1	25.5	49.0	5.8	70	0.512

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.1	84.4	67.8	80.4	66.2	77.2	64.5	69.5	80.6	67.7	77.8	66.1	74.7	5.6	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
65.7	95.3	73.6	64.2	90.2	71.5	62.7	85.6	69.9	33.6	80.8	32.1	78.0	30.8	74.8	78.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 21.8	18.7	16.2	DB	18.7	91.5	5.0	3.2	15.1	93.8	12.1	95.7	9.3	97.4	5.6	99.8	(4)
(5)			WB	17.8	73.4	5.0	2.0	14.2	74.8	11.3	75.9	8.5	77.0	4.9	78.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	51.9	39.1	40.5	44.9	50.4	56.4	61.4	65.4	64.9	59.7	53.3	45.7	40.3	(6)
(7)		DBStd	11.13	7.23	6.69	6.05	6.39	6.20	5.49	5.40	4.87	4.88	5.87	6.15	7.02	(7)
(8)		HDD50	1362	340	270	176	71	12	0	0	0	0	34	152	307	(8)
(9)		HDD65	4964	802	687	622	438	276	135	61	61	173	364	578	767	(9)
(10)		CDD50	2059	2	3	19	83	211	344	478	462	291	136	25	5	(10)
(11)		CDD65	185	0	0	0	1	10	29	73	58	13	1	0	0	(11)
(12)		CDH74	1457	0	0	0	17	86	249	584	436	81	4	0	0	(12)
(13)		CDH80	360	0	0	0	1	10	55	165	118	11	0	0	0	(13)
(14)	Wind	WSAvg	7.2	9.0	8.7	8.3	7.1	6.8	6.3	5.9	5.7	5.9	7.0	7.5	8.6	(14)
(15)	Precipitation	PrecAvg	32.8	2.8	2.4	2.1	1.9	2.4	3.0	3.1	3.4	2.6	2.8	3.2	3.2	(15)
(16)		PrecMax	40.5	6.4	5.4	5.2	3.9	4.5	5.9	6.5	8.0	7.5	5.0	5.7	6.7	(16)
(17)		PrecMin	25.0	0.2	0.7	0.2	0.0	0.7	1.1	0.9	0.9	0.5	0.7	0.5	0.9	(17)
(18)		PrecStd	3.7	1.4	1.1	1.2	1.0	1.0	1.3	1.5	2.0	1.6	1.0	1.3	1.6	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	55.3	57.7	66.3	76.3	81.0	86.4	90.3	88.8	81.1	72.1	62.6	56.3	(19)
(20)			MCWB	52.2	49.1	54.9	59.5	64.9	68.7	69.3	69.7	66.3	63.2	57.8	53.2	(20)
(21)		2%	DB	53.1	54.0	60.7	70.5	76.6	80.4	84.4	83.6	75.8	67.0	58.9	54.5	(21)
(22)			MCWB	50.4	49.2	51.8	57.0	61.3	65.6	68.1	67.6	64.4	60.4	55.0	52.0	(22)
(23)		5%	DB	50.9	51.7	56.8	65.4	72.4	76.3	80.5	79.0	71.4	63.9	56.5	52.4	(23)
(24)			MCWB	48.3	48.0	50.2	54.7	59.7	64.2	66.7	66.1	62.4	58.8	53.5	50.1	(24)
(25)		10%	DB	48.6	49.8	53.9	61.0	67.9	72.4	76.5	74.8	68.1	61.5	54.2	50.1	(25)
(26)			MCWB	46.2	46.8	48.9	52.5	57.7	62.2	64.9	64.1	60.4	57.4	51.5	47.7	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	53.0	51.9	55.5	61.5	67.0	70.7	72.0	71.9	68.3	63.8	58.5	54.2	(27)
(28)			MCD B	54.7	55.3	62.7	73.1	78.1	82.0	83.9	84.5	77.3	70.9	61.5	55.6	(28)
(29)		2%	WB	50.8	50.2	53.1	58.1	63.5	67.6	69.8	69.1	65.9	61.4	55.7	52.3	(29)
(30)			MCD B	52.8	52.7	58.5	67.5	72.5	77.9	81.6	79.8	73.7	66.0	58.4	54.2	(30)
(31)		5%	WB	48.5	48.7	51.3	55.7	60.9	65.5	67.8	67.2	63.8	59.7	53.8	50.3	(31)
(32)			MCD B	50.5	51.3	55.6	64.0	69.2	74.3	77.9	76.6	69.3	63.2	56.2	52.3	(32)
(33)		10%	WB	46.4	46.8	49.5	53.4	58.8	63.3	66.1	65.4	62.0	58.1	51.8	48.0	(33)
(34)			MCD B	48.4	49.5	53.4	60.0	66.7	70.8	74.7	72.7	66.9	61.1	54.1	49.9	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	7.9	9.4	12.2	15.1	15.3	15.8	16.1	15.9	14.2	11.7	8.6	7.6	(35)
(36)			MCDBR	8.9	11.2	17.2	21.5	22.2	22.7	22.9	22.9	18.9	13.9	9.7	8.4	(36)
(37)			MCWBR	8.1	8.3	10.5	11.4	10.4	11.2	9.8	9.9	9.4	8.6	7.8	7.6	(37)
(38)		5% WB	MCD BR	8.8	9.9	14.3	18.9	19.1	19.9	20.3	20.4	16.5	12.7	9.2	8.3	(38)
(39)			MCWBR	8.4	8.1	9.7	10.8	10.1	11.0	9.7	9.9	9.0	8.6	7.8	7.8	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.332	0.353	0.389	0.416	0.427	0.423	0.426	0.416	0.391	0.369	0.344	0.328	(40)	
(41)		taud	2.371	2.339	2.237	2.186	2.203	2.234	2.233	2.278	2.336	2.391	2.375	2.341	(41)	
(42)		Ebn at Noon	216	243	254	260	263	265	262	258	251	234	208	196	(42)	
(43)		Edh at Noon	20	27	36	42	43	42	42	38	32	25	20	18	(43)	
(44)	All-Sky Solar Radiation	RadAvg	250	469	850	1370	1604	1747	1654	1409	1054	612	292	194	(44)	
(45)		RadStd	25	89	111	138	132	148	172	127	79	52	31	25	(45)	

Historical Trends

		Heating		Cooling			Degree-Days					
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47)	Regional (73 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page