

SEMMEZAKE, Belgium

WMO: 064280

Lat: 50.9406N

Lon: 3.6697E

Elev: 38

StdP: 100.88

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-5.4	-3.5	-9.1	1.7	-3.5	-6.8	2.1	-2.2	12.4	9.5	11.4	9.5	2.6	70	0.512

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.0	29.1	19.9	26.9	19.0	25.1	18.1	20.8	27.0	19.8	25.4	19.0	23.7	2.5	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
18.7	13.6	23.1	17.9	12.9	21.9	17.1	12.2	21.1	60.2	27.1	56.8	25.5	53.9	23.8	25.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.7	8.3	7.2	DB	-7.4	33.0	2.8	1.8	-9.4	34.3	-11.0	35.4	-12.6	36.4	-14.7	37.6	(4)
(5)			WB	-7.9	23.0	2.8	1.1	-9.9	23.8	-11.5	24.4	-13.0	25.0	-15.0	25.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	11.1	4.0	4.7	7.2	10.2	13.6	16.4	18.6	18.3	15.4	11.8	7.6	4.6	(6)
(7)		DBStd	6.18	4.02	3.71	3.36	3.55	3.44	3.05	3.00	2.71	2.71	3.26	3.42	3.90	(7)
(8)		HDD10.0	757	189	150	98	39	7	0	0	0	0	19	84	171	(8)
(9)		HDD18.3	2758	446	382	346	243	153	75	34	34	96	202	321	426	(9)
(10)		CDD10.0	1144	1	2	11	46	117	191	266	257	162	76	14	3	(10)
(11)		CDD18.3	103	0	0	0	1	6	16	41	32	7	1	0	0	(11)
(12)		CDH23.3	809	0	0	0	9	48	138	324	242	45	2	0	0	(12)
(13)		CDH26.7	200	0	0	0	1	6	31	92	66	6	0	0	0	(13)
(14)	Wind	WSAvg	3.2	4.0	3.9	3.7	3.2	3.0	2.8	2.7	2.5	2.6	3.1	3.4	3.9	(14)
(15)	Precipitation	PrecAvg	834	71	62	53	47	60	76	80	87	66	70	81	82	(15)
(16)		PrecMax	1028	163	137	133	100	114	151	166	203	191	127	144	170	(16)
(17)		PrecMin	636	4	17	4	1	18	28	22	23	13	18	13	23	(17)
(18)		PrecStd	93	36	29	30	26	25	33	39	51	40	26	33	41	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.0	14.3	19.0	24.6	27.2	30.2	32.4	31.5	27.3	22.3	17.0	13.5	(19)
(20)			MCWB	11.2	9.5	12.7	15.3	18.3	20.4	20.7	20.9	19.0	17.3	14.4	11.8	(20)
(21)		2%	DB	11.7	12.2	15.9	21.4	24.8	26.9	29.1	28.7	24.4	19.5	15.0	12.5	(21)
(22)			MCWB	10.2	9.6	11.0	13.9	16.3	18.7	20.1	19.8	18.0	15.8	12.8	11.1	(22)
(23)		5%	DB	10.5	10.9	13.8	18.5	22.4	24.6	26.9	26.1	21.9	17.7	13.6	11.4	(23)
(24)			MCWB	9.1	8.9	10.1	12.6	15.4	17.9	19.3	19.0	16.9	14.9	11.9	10.0	(24)
(25)		10%	DB	9.2	9.9	12.2	16.1	19.9	22.4	24.7	23.8	20.0	16.4	12.4	10.0	(25)
(26)			MCWB	7.9	8.2	9.4	11.4	14.3	16.8	18.3	17.9	15.8	14.1	10.8	8.7	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.7	11.1	13.0	16.4	19.5	21.5	22.2	22.2	20.2	17.7	14.7	12.3	(27)
(28)			MCDWB	12.6	12.9	17.1	22.8	25.6	27.8	28.8	29.2	25.1	21.6	16.4	13.1	(28)
(29)		2%	WB	10.5	10.1	11.7	14.5	17.5	19.8	21.0	20.6	18.8	16.3	13.2	11.3	(29)
(30)			MCDWB	11.6	11.5	14.7	19.7	22.5	25.5	27.5	26.6	23.2	18.9	14.7	12.3	(30)
(31)		5%	WB	9.2	9.3	10.7	13.1	16.1	18.6	19.9	19.5	17.6	15.4	12.1	10.2	(31)
(32)			MCDWB	10.3	10.7	13.1	17.8	20.7	23.5	25.5	24.8	20.7	17.3	13.5	11.3	(32)
(33)		10%	WB	8.0	8.2	9.7	11.9	14.9	17.4	18.9	18.5	16.7	14.5	11.0	8.9	(33)
(34)			MCDWB	9.1	9.7	11.9	15.6	19.3	21.5	23.7	22.6	19.4	16.1	12.3	9.9	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	4.4	5.2	6.8	8.4	8.5	8.8	9.0	8.8	7.9	6.5	4.8	4.2	(35)
(36)			MCDBR	5.0	6.2	9.6	11.9	12.3	12.6	12.7	12.7	10.5	7.7	5.4	4.7	(36)
(37)			MCWBR	4.5	4.6	5.9	6.3	5.8	6.2	5.5	5.5	5.2	4.8	4.3	4.2	(37)
(38)		5% WB	MCDWB	4.9	5.5	7.9	10.5	10.6	11.1	11.3	11.3	9.2	7.0	5.1	4.6	(38)
(39)			MCWBR	4.6	4.5	5.4	6.0	5.6	6.1	5.4	5.5	5.0	4.8	4.4	4.3	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.332	0.353	0.389	0.416	0.427	0.423	0.426	0.416	0.391	0.369	0.344	0.328	(40)	
(41)		taud	2.371	2.339	2.237	2.186	2.203	2.234	2.233	2.278	2.336	2.391	2.375	2.341	(41)	
(42)		Ebn at Noon	682	766	800	821	830	835	825	813	792	738	657	618	(42)	
(43)		Edh at Noon	64	85	112	132	136	133	131	119	101	80	64	57	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.79	1.48	2.68	4.32	5.06	5.51	5.21	4.44	3.32	1.93	0.92	0.61	(44)	
(45)		RadStd	0.08	0.28	0.35	0.44	0.42	0.47	0.54	0.40	0.25	0.16	0.10	0.08	(45)	

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47)	Regional (73 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page