

UCCLE, Belgium

WMO: 064470

Lat: 50.7969N

Lon: 4.3581E

Elev: 101

StdP: 100.12

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-5.7	-3.9	-10.5	1.6	-3.1	-7.8	2.0	-1.8	11.3	9.2	10.3	8.8	3.0	50	0.510

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.0	29.3	19.6	27.3	18.8	25.3	17.8	20.7	26.9	19.7	25.4	18.8	23.8	2.9	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
18.6	13.6	23.2	17.6	12.8	22.0	16.8	12.1	21.1	60.2	26.8	56.5	25.5	53.6	23.9	26.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.0	7.8	6.8	DB	-8.1	33.0	2.9	1.7	-10.1	34.1	-11.8	35.1	-13.4	36.0	-15.5	37.2	(4)
(5)			WB	-8.4	23.0	2.7	1.4	-10.3	24.0	-11.9	24.9	-13.4	25.7	-15.3	26.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	11.0	3.8	4.5	7.2	10.5	13.9	16.7	18.8	18.5	15.3	11.7	7.3	4.1	(6)
(7)		DBStd	6.44	4.13	3.84	3.57	3.82	3.70	3.30	3.24	3.05	2.75	3.48	3.40	3.93	(7)
(8)		HDD10.0	796	195	156	100	39	7	0	0	0	1	22	92	184	(8)
(9)		HDD18.3	2784	452	388	346	237	146	71	34	34	99	206	331	441	(9)
(10)		CDD10.0	1176	1	1	13	53	127	201	272	263	158	75	11	2	(10)
(11)		CDD18.3	124	0	0	0	1	8	22	47	38	7	1	0	0	(11)
(12)		CDH23.3	897	0	0	0	12	59	163	334	287	37	3	0	0	(12)
(13)		CDH26.7	227	0	0	0	1	8	37	89	87	6	0	0	0	(13)
(14)	Wind	WSAvg	3.4	3.9	4.0	3.7	3.4	3.1	3.0	2.9	2.8	2.9	3.5	3.6	3.9	(14)
(15)	Precipitation	PrecAvg	828	72	59	66	52	66	75	78	76	62	70	79	83	(15)
(16)		PrecMax	1074	154	168	141	134	146	175	177	231	199	163	175	173	(16)
(17)		PrecMin	541	3	9	4	0	14	12	19	10	7	5	9	14	(17)
(18)		PrecStd	118	34	31	32	29	32	37	40	49	41	36	31	40	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.9	14.8	19.4	25.0	27.9	30.6	32.0	32.2	27.4	23.1	17.0	13.2	(19)
(20)			MCWB	10.7	8.4	11.5	14.1	18.1	20.5	20.3	20.9	18.4	17.1	12.9	11.2	(20)
(21)		2%	DB	11.6	12.0	16.5	21.9	24.9	27.3	29.2	29.0	23.8	20.1	14.6	12.1	(21)
(22)			MCWB	10.0	8.8	10.5	13.2	16.1	18.7	19.5	20.0	17.2	15.8	12.1	10.7	(22)
(23)		5%	DB	10.2	10.6	14.1	19.0	22.7	25.1	27.2	26.7	21.6	18.0	13.1	10.9	(23)
(24)			MCWB	8.6	8.4	9.7	12.4	15.4	17.7	18.7	19.2	16.4	14.6	11.2	9.5	(24)
(25)		10%	DB	9.0	9.5	12.3	16.5	20.4	22.9	25.1	24.2	19.8	16.4	11.8	9.6	(25)
(26)			MCWB	7.6	7.7	9.0	11.1	14.4	16.7	18.0	18.0	15.4	13.9	10.2	8.4	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.4	10.5	12.7	15.6	19.4	21.8	22.0	22.7	19.4	17.6	13.7	12.0	(27)
(28)			MCDWB	12.3	12.0	16.7	22.9	25.5	28.5	29.2	29.6	24.5	21.8	15.6	12.6	(28)
(29)		2%	WB	10.1	9.6	11.4	13.9	17.6	19.6	20.5	20.8	18.3	16.2	12.5	10.9	(29)
(30)			MCDWB	11.3	11.0	14.7	19.4	23.2	25.5	26.8	27.0	22.2	19.2	14.1	11.9	(30)
(31)		5%	WB	8.9	8.7	10.4	12.7	16.2	18.5	19.6	19.7	17.2	15.2	11.5	9.6	(31)
(32)			MCDWB	10.0	10.3	13.2	17.8	20.8	23.7	25.3	25.1	20.4	17.5	13.1	10.7	(32)
(33)		10%	WB	7.7	7.8	9.5	11.7	15.0	17.4	18.7	18.6	16.3	14.2	10.3	8.5	(33)
(34)			MCDWB	9.0	9.4	11.9	16.0	19.3	21.8	23.8	22.9	19.1	16.1	11.5	9.5	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	4.1	5.0	6.6	8.0	8.2	8.2	8.0	8.2	7.3	6.1	4.5	3.9	(35)
(36)			MCDBR	4.6	6.7	9.8	11.5	11.5	11.6	11.3	12.1	10.1	7.9	5.6	4.8	(36)
(37)			MCWBR	4.1	4.6	5.4	5.5	5.2	5.3	4.6	5.4	4.9	4.4	4.1	4.2	(37)
(38)		5% WB	MCDBR	4.5	5.5	7.6	9.9	9.8	10.2	9.6	10.4	8.6	7.1	5.1	4.4	(38)
(39)			MCWBR	4.3	4.5	4.8	5.1	5.1	5.5	4.7	5.7	4.9	4.5	4.1	4.2	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.324	0.345	0.378	0.415	0.425	0.422	0.426	0.416	0.388	0.360	0.336	0.321	(40)	
(41)		taud	2.405	2.374	2.280	2.189	2.205	2.234	2.227	2.274	2.340	2.421	2.409	2.375	(41)	
(42)		Ebn at Noon	700	780	815	823	831	836	826	814	796	753	674	636	(42)	
(43)		Edh at Noon	63	83	108	132	136	133	132	120	101	78	62	56	(43)	
(44)	All-Sky Solar Radiation	RadAvg	0.78	1.45	2.62	4.17	4.95	5.38	5.10	4.34	3.27	1.92	0.92	0.61	(44)	
(45)		RadStd	0.10	0.28	0.37	0.47	0.47	0.47	0.60	0.44	0.32	0.16	0.10	0.09	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (79 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page