

BRUSSELS AP, Belgium

WMO: 064510

Lat: 50.8964N

Lon: 4.5272E

Elev: 184

StdP: 14.60

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	21.0	24.6	14.9	11.8	23.6	19.0	14.4	26.3	31.5	49.3	28.0	48.9	5.6	60	0.542

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.5	84.9	68.6	81.0	66.8	77.5	65.1	69.9	81.7	68.1	78.5	66.3	75.2	6.8	60

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
65.8	95.8	74.7	64.2	90.4	72.7	62.7	85.7	70.9	34.0	82.1	32.4	78.8	31.1	75.3	80.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
24.1	21.0	18.4	16.7	91.4	5.3	2.6	13.0	93.3	9.9	94.9	6.9	96.3	3.1	98.2		
			15.9	74.0	5.2	2.4	12.2	75.7	9.1	77.1	6.2	78.5	2.4	80.2		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	51.6	38.7	39.9	44.4	50.1	56.3	61.5	65.4	64.9	59.4	52.9	45.3	39.9
	DBStd	11.39	7.52	7.13	6.25	6.53	6.27	5.70	5.48	5.15	5.03	6.25	6.22	7.36
	HDD50	1446	352	287	190	79	13	0	0	0	0	41	164	320
	HDD65	5076	815	703	638	448	278	138	63	65	181	376	591	780
	CDD50	2038	2	3	18	81	209	344	477	462	282	131	23	6
	CDD65	192	0	0	0	1	9	31	75	62	13	1	0	0
	CDH74	1624	0	0	0	14	89	284	623	525	86	3	0	0
	CDH80	430	0	0	0	0	13	65	175	162	15	0	0	0
Wind	WSAvg	8.4	10.3	9.9	9.4	8.0	7.6	7.3	7.1	6.9	7.2	8.1	8.8	10.0
Precipitation	PrecAvg	30.7	2.7	2.5	2.1	1.9	2.3	2.7	2.8	3.2	2.4	2.4	2.7	2.9
	PrecMax	40.0	5.2	5.5	4.6	4.1	4.1	5.5	5.4	8.1	7.1	5.5	5.5	7.0
	PrecMin	24.3	0.1	0.5	0.1	0.0	0.7	1.0	1.0	0.5	0.4	0.6	1.3	0.7
	PrecStd	4.5	1.4	1.2	1.2	0.9	0.9	1.1	1.2	2.1	1.7	1.1	1.0	1.4
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	55.3	58.7	65.7	76.1	81.3	87.2	89.8	89.8	82.0	72.9	62.9	56.6
		MCWB	51.8	49.6	53.3	59.8	66.0	70.3	70.0	70.5	66.4	62.8	56.8	53.0
	2%	DB	53.1	54.4	61.0	70.4	76.2	81.0	84.9	84.5	76.0	67.6	58.6	54.5
		MCWB	50.1	48.9	51.6	57.1	62.5	66.8	68.4	68.5	64.2	60.4	54.4	51.5
	5%	DB	50.7	51.8	56.9	65.7	72.3	76.9	80.8	80.1	71.6	64.1	56.3	52.4
		MCWB	47.9	47.9	50.3	54.9	60.4	64.9	66.7	66.6	62.4	58.6	52.8	49.7
	10%	DB	48.4	49.6	53.8	61.2	68.0	72.9	76.9	75.3	68.2	61.5	54.1	49.9
		MCWB	45.8	46.4	48.5	52.6	58.4	62.8	65.2	64.7	60.4	57.1	51.0	47.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	52.6	51.9	55.3	61.1	67.8	72.2	72.1	72.6	68.0	63.7	57.7	53.9
		MCDB	54.6	55.7	62.0	72.6	79.4	83.9	84.7	85.6	78.5	70.7	61.0	55.8
	2%	WB	50.3	50.1	53.0	57.9	64.4	68.3	69.8	69.8	65.6	61.2	55.0	51.9
		MCDB	52.6	53.1	58.7	67.4	73.3	78.7	82.0	81.5	73.7	66.5	58.2	54.2
	5%	WB	48.0	48.3	51.0	55.7	61.6	65.9	68.0	67.7	63.5	59.3	53.2	49.9
		MCDB	50.4	51.3	55.7	64.0	69.5	74.8	78.2	77.7	69.8	63.3	56.1	52.2
	10%	WB	46.1	46.4	49.3	53.6	59.3	63.8	66.1	65.6	61.7	57.6	51.1	47.6
		MCDB	48.4	49.4	53.4	60.5	66.7	71.4	74.7	73.6	67.1	61.1	53.7	49.8
Mean Daily Temperature Range	5% DB	MDBR	7.9	9.4	12.5	15.6	16.0	16.5	16.5	16.3	14.6	12.0	8.8	7.6
		MCDBR	9.2	11.9	18.3	22.4	22.7	23.6	23.6	24.1	19.9	14.9	10.6	8.5
		MCWBR	8.0	8.6	11.1	11.8	11.4	12.1	10.2	10.8	10.2	9.2	8.1	7.5
	5% WB	MCDBR	9.1	9.8	15.0	19.6	19.7	21.0	20.6	21.4	17.4	13.5	9.8	8.4
		MCWBR	8.2	7.8	10.0	11.1	11.0	11.5	9.9	10.5	9.6	8.9	8.1	7.7
Clear-Sky Solar Irradiance	taub	0.327	0.350	0.383	0.419	0.428	0.425	0.429	0.420	0.392	0.364	0.340	0.325	
	taud	2.392	2.358	2.264	2.184	2.202	2.231	2.223	2.270	2.336	2.408	2.396	2.360	
	Ebn at Noon	220	245	256	260	263	264	261	257	251	236	211	199	
	Edh at Noon	20	27	35	42	43	42	42	38	32	25	20	18	
All-Sky Solar Radiation	RadAvg	244	458	825	1314	1567	1703	1611	1373	1029	607	287	191	
	RadStd	33	90	117	148	147	148	193	137	104	50	32	28	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (82 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page