

DOURBES, Belgium

WMO: 064550

Lat: 50.0956N

Lon: 4.5944E

Elev: 764

StdP: 14.29

Time Zone: 1.00 (EUC)

Period: 09-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	18.7	23.1	13.9	11.5	19.9	18.8	14.6	25.9	22.4	46.2	20.0	45.5	4.3	40	0.508

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.0	85.6	68.5	81.1	66.8	77.6	65.2	70.4	80.1	68.4	77.2	66.7	75.3	6.2	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
67.5	104.0	73.2	65.7	97.7	71.2	63.8	91.3	69.4	34.8	80.3	33.1	77.7	31.7	75.2	76.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 17.8	15.3	13.3	DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	50.2	37.3	37.2	43.4	48.7	54.2	60.9	64.7	63.0	57.9	52.3	43.7	38.2
	DBStd	11.71	6.76	7.84	6.99	6.75	6.69	5.92	5.92	5.27	5.47	6.81	6.24	7.26
	HDD50	1736	394	358	221	106	30	0	0	0	3	53	204	367
	HDD65	5558	858	777	669	491	342	155	78	100	224	395	638	831
	CDD50	1810	1	0	17	65	160	326	456	403	239	125	16	2
	CDD65	157	0	0	0	0	7	30	69	39	10	2	0	0
	CDH74	1724	0	0	0	5	83	350	720	450	111	5	0	0
	CDH80	499	0	0	0	0	12	91	231	145	20	0	0	0
(14) Wind	WSAvg	5.7	7.0	6.6	6.0	5.7	5.1	5.1	4.8	4.9	4.7	5.8	6.4	7.1
(15) Precipitation	PrecAvg	38.2	3.9	3.2	2.8	2.5	2.7	3.1	3.1	3.3	2.7	3.3	3.3	4.2
	PrecMax	47.7	9.5	8.1	6.9	6.8	6.1	5.0	7.0	8.1	6.5	7.5	5.9	10.3
	PrecMin	30.1	0.6	0.6	0.2	0.4	0.5	1.0	1.5	1.2	0.7	1.4	0.5	0.9
	PrecStd	4.7	1.9	1.7	1.6	1.3	1.5	1.2	1.2	2.0	1.4	1.3	1.4	2.0
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	53.3	60.8	68.1	74.7	81.2	89.1	93.5	90.1	83.2	74.3	61.0	55.3
		MCWB	52.2	47.3	52.8	57.9	64.6	69.8	68.2	68.8	67.1	63.1	56.8	53.0
	2%	DB	51.1	52.4	64.2	71.5	75.7	81.7	85.9	84.1	77.0	69.8	58.1	52.3
		MCWB	49.8	47.2	51.6	57.2	62.2	68.7	68.9	68.1	64.8	62.2	55.9	50.5
	5%	DB	48.6	49.4	59.7	66.6	71.6	77.9	81.2	78.7	72.8	65.5	55.5	49.9
		MCWB	47.2	46.7	50.4	55.0	60.4	65.6	66.1	65.9	63.4	59.8	54.0	48.8
	10%	DB	46.4	47.2	54.8	61.6	67.3	73.4	77.3	74.4	68.5	62.0	52.8	47.7
		MCWB	45.2	45.4	48.3	52.5	58.4	63.9	65.1	63.9	61.5	58.0	51.3	46.6
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	52.9	50.3	55.6	61.3	70.0	72.7	72.3	72.7	71.2	66.0	58.6	53.1
		MCDB	53.0	54.0	62.6	71.0	78.3	83.9	86.4	83.6	76.0	71.0	59.8	53.7
	2%	WB	49.9	48.6	53.4	57.7	64.4	69.4	69.7	69.3	67.0	62.7	56.2	51.0
		MCDB	50.8	50.6	60.4	67.3	71.4	78.1	80.2	77.7	73.0	68.4	57.5	52.0
	5%	WB	47.4	47.0	51.2	55.7	61.6	67.1	67.9	67.3	64.8	60.5	54.0	49.1
		MCDB	48.4	49.1	57.7	65.2	69.2	75.6	78.3	75.9	71.5	64.2	55.5	49.9
	10%	WB	45.4	45.3	49.2	53.5	59.2	64.9	66.3	65.5	62.3	58.5	51.6	46.8
		MCDB	46.4	47.5	54.2	60.6	66.2	71.9	75.6	73.0	67.3	61.3	52.7	47.5
(35) Mean Daily Temperature Range	MDBR		7.7	10.4	15.8	19.0	18.2	17.9	19.0	18.7	18.1	13.3	9.2	8.2
	5% DB	MCDBR	8.8	14.8	26.3	26.9	25.3	25.5	26.4	26.9	24.8	18.3	12.2	10.1
		MCWBR	8.2	10.3	15.1	14.2	13.7	12.8	11.3	12.9	14.1	11.3	9.9	8.9
	5% WB	MCDBR	9.0	13.1	20.4	23.9	21.5	22.0	22.0	21.7	21.2	16.1	10.9	9.4
		MCWBR	8.5	10.0	13.2	13.1	12.8	11.9	10.9	12.4	13.2	11.1	9.4	9.1
(40) Clear-Sky Solar Irradiance	taub		0.313	0.335	0.368	0.400	0.411	0.409	0.409	0.402	0.372	0.354	0.328	0.310
	taud		2.427	2.386	2.302	2.230	2.237	2.264	2.262	2.307	2.373	2.424	2.427	2.396
	Ebn at Noon		231	254	264	267	269	270	267	263	260	243	222	213
	Edh at Noon		20	26	34	40	42	41	41	37	31	25	20	18
(44) All-Sky Solar Radiation	RadAvg		252	473	845	1328	1571	1728	1644	1402	1066	622	294	200
	RadStd		39	90	118	160	167	159	181	154	112	53	35	33

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (73 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page