

DOURBES, Belgium

WMO: 064550

Lat: 50.0956N

Lon: 4.5944E

Elev: 233

StdP: 98.56

Time Zone: 1.00 (EUC)

Period: 09-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-7.4	-4.9	-10.0	1.6	-6.7	-7.3	2.1	-3.4	10.0	7.9	9.0	7.5	1.9	40	0.508

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.6	29.8	20.3	27.3	19.3	25.3	18.4	21.3	26.7	20.2	25.1	19.3	24.0	2.8	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.7	14.9	22.9	18.7	14.0	21.8	17.7	13.0	20.8	63.0	26.8	59.2	25.4	55.9	24.0	24.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.9	6.8	5.9	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	10.1	3.0	2.9	6.3	9.3	12.3	16.0	18.2	17.2	14.4	11.3	6.5	3.4
	DBStd	6.50	3.76	4.35	3.88	3.75	3.72	3.29	3.29	2.93	3.04	3.79	3.47	4.04
	HDD10.0	964	219	199	123	59	17	0	0	0	2	29	113	204
	HDD18.3	3088	477	432	372	273	190	86	43	56	124	219	354	462
	CDD10.0	1006	1	0	9	36	89	181	253	224	133	69	9	1
	CDD18.3	87	0	0	0	0	4	17	38	22	6	1	0	0
	CDH23.3	958	0	0	0	3	46	194	400	250	62	3	0	0
	CDH26.7	277	0	0	0	0	7	51	128	81	11	0	0	0
Wind	WSAvg	2.6	3.1	2.9	2.7	2.5	2.3	2.3	2.1	2.2	2.1	2.6	2.8	3.2
Precipitation	PrecAvg	971	100	81	72	64	69	80	80	85	68	83	83	107
	PrecMax	1211	242	205	175	172	156	127	177	205	165	191	150	262
	PrecMin	764	15	15	5	11	13	26	38	30	18	35	13	22
	PrecStd	120	48	42	40	34	37	31	31	51	36	33	36	52
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.8	16.0	20.0	23.7	27.4	31.7	34.2	32.3	28.4	23.5	16.1	13.0
		MCWB	11.2	8.5	11.6	14.4	18.1	21.0	20.1	20.4	19.5	17.3	13.8	11.7
	2%	DB	10.6	11.3	17.9	21.9	24.3	27.6	29.9	28.9	25.0	21.0	14.5	11.3
		MCWB	9.9	8.4	10.9	14.0	16.8	20.4	20.5	20.0	18.2	16.8	13.3	10.3
	5%	DB	9.2	9.7	15.4	19.2	22.0	25.5	27.3	25.9	22.7	18.6	13.1	10.0
		MCWB	8.4	8.2	10.2	12.8	15.8	18.7	19.0	18.8	17.5	15.4	12.2	9.3
	10%	DB	8.0	8.5	12.7	16.4	19.6	23.0	25.2	23.6	20.3	16.7	11.6	8.7
		MCWB	7.3	7.4	9.1	11.4	14.6	17.7	18.4	17.7	16.4	14.4	10.7	8.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.6	10.2	13.1	16.3	21.1	22.6	22.4	22.6	21.8	18.9	14.8	11.7
		MCDB	11.7	12.2	17.0	21.7	25.7	28.8	30.2	28.7	24.5	21.7	15.5	12.1
	2%	WB	10.0	9.2	11.9	14.3	18.0	20.8	20.9	20.7	19.4	17.1	13.4	10.5
		MCDB	10.4	10.3	15.8	19.6	21.9	25.6	26.8	25.4	22.8	20.2	14.2	11.1
	5%	WB	8.6	8.4	10.7	13.2	16.4	19.5	20.0	19.6	18.2	15.8	12.2	9.5
		MCDB	9.1	9.5	14.3	18.4	20.7	24.2	25.7	24.4	22.0	17.9	13.1	10.0
	10%	WB	7.5	7.4	9.6	11.9	15.1	18.3	19.0	18.6	16.9	14.7	10.9	8.2
		MCDB	8.0	8.6	12.3	15.9	19.0	22.2	24.2	22.8	19.6	16.3	11.5	8.6
Mean Daily Temperature Range	5% DB	MDBR	4.3	5.8	8.8	10.6	10.1	10.0	10.6	10.4	10.0	7.4	5.1	4.6
		MCDBR	4.9	8.2	14.6	15.0	14.1	14.2	14.6	15.0	13.8	10.2	6.8	5.6
		MCWBR	4.5	5.7	8.4	7.9	7.6	7.1	6.3	7.2	7.8	6.3	5.5	5.0
	5% WB	MCDBR	5.0	7.3	11.3	13.3	12.0	12.2	12.2	12.1	11.8	9.0	6.1	5.2
		MCWBR	4.7	5.5	7.3	7.3	7.1	6.6	6.0	6.9	7.3	6.2	5.2	5.1
Clear-Sky Solar Irradiance	taub	0.313	0.335	0.368	0.400	0.411	0.409	0.409	0.402	0.372	0.354	0.328	0.310	
	taud	2.427	2.386	2.302	2.230	2.237	2.264	2.262	2.307	2.373	2.424	2.427	2.396	
	Ebn at Noon	729	800	831	841	847	850	843	830	819	767	700	670	
	Edh at Noon	62	83	106	127	132	129	128	117	98	79	62	56	
All-Sky Solar Radiation	RadAvg	0.79	1.49	2.67	4.19	4.95	5.45	5.18	4.42	3.36	1.96	0.93	0.63	
	RadStd	0.12	0.28	0.37	0.50	0.53	0.50	0.57	0.49	0.35	0.17	0.11	0.10	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (73 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page