

DIEPENBEEK, Belgium

WMO: 064770

Lat: 50.9156N

Lon: 5.4503E

Elev: 128

StdP: 14.63

Time Zone: 1.00 (EUC)

Period: 09-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	20.2	24.1	10.9	9.6	23.9	16.8	12.9	28.1	24.3	47.6	21.8	49.4	4.9	100	0.510

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	20.0	87.6	68.5	82.7	65.6	79.2	63.9	69.9	82.9	67.9	79.4	66.2	75.9	6.3	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
65.6	95.1	73.7	64.0	89.6	71.9	62.5	85.0	70.6	33.9	82.2	32.2	78.9	31.0	76.4	77.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 19.4	16.7	14.7	DB	16.9	95.8	6.5	3.9	12.3	98.6	8.4	100.9	4.8	103.1	0.0	106.0	(4)
(5)			WB	16.1	73.6	7.0	2.4	11.0	75.3	6.9	76.7	3.0	78.0	-2.1	79.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	51.5	38.2	38.5	44.8	50.1	56.2	62.1	65.9	64.1	58.6	52.5	45.1	40.5	(6)	
	DBStd	11.53	7.32	7.53	5.92	6.60	6.65	5.50	5.93	4.94	5.12	6.57	6.56	7.40	(7)	
	HDD50	1496	369	324	178	81	16	0	0	0	2	49	175	302	(8)	
	HDD65	5140	831	743	627	447	285	121	60	76	203	390	596	761	(9)	
	CDD50	2025	2	1	17	84	207	364	494	437	258	125	29	7	(10)	
	CDD65	193	0	0	0	0	11	35	89	48	9	1	0	0	(11)	
	CDH74	2303	0	0	0	28	148	401	992	571	148	15	0	0	(12)	
	CDH80	709	0	0	0	2	21	104	357	193	32	0	0	0	(13)	
(14) Wind	WSAvg	6.7	7.8	8.0	7.4	6.7	6.4	6.2	5.8	5.6	5.5	6.1	7.0	8.4	(14)	
(15) Precipitation	PrecAvg	30.9	2.6	2.3	2.2	1.9	2.4	2.9	3.0	3.2	2.3	2.5	2.6	2.9	(15)	
	PrecMax	40.6	4.9	5.6	5.3	4.6	5.5	6.6	9.0	8.5	6.9	6.9	4.3	6.1	(16)	
	PrecMin	23.6	0.1	0.2	0.1	0.2	0.9	0.6	1.2	0.6	0.6	1.2	0.2	0.7	(17)	
	PrecStd	4.6	1.2	1.2	1.1	1.0	1.1	1.3	1.6	2.0	1.5	1.1	1.0	1.3	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	55.8	61.0	68.4	77.3	82.9	88.9	95.2	91.9	84.4	76.2	64.6	57.8	(19)	
		MCWB	51.5	48.3	53.2	59.0	64.1	70.5	70.1	69.0	65.0	62.6	56.9	53.2	(20)	
	2%	DB	53.4	53.5	64.6	73.5	78.3	82.9	88.8	85.9	78.3	70.3	60.9	55.3	(21)	
		MCWB	49.9	47.9	51.1	56.4	61.8	66.2	68.2	68.9	63.6	61.5	55.5	51.5	(22)	
	5%	DB	50.4	51.3	59.7	68.7	74.3	78.8	83.2	79.9	73.7	65.6	58.1	53.3	(23)	
		MCWB	47.1	47.0	50.1	55.2	59.7	63.6	65.5	65.6	62.5	58.4	53.6	49.7	(24)	
	10%	DB	48.3	49.4	55.5	63.6	70.2	74.4	79.3	75.7	69.5	62.7	55.5	50.6	(25)	
		MCWB	45.4	45.5	48.0	53.3	58.1	62.1	64.0	63.4	60.5	57.1	51.7	47.7	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	52.4	51.2	53.9	61.7	67.6	72.7	72.9	72.5	67.6	64.4	60.6	54.7	(27)	
		MCDB	55.0	55.7	62.9	74.8	78.2	84.7	90.4	85.7	75.7	73.0	63.3	56.8	(28)	
	2%	WB	50.1	49.1	52.5	58.1	64.2	68.6	69.9	69.3	64.9	61.7	56.2	52.4	(29)	
		MCDB	53.1	52.6	61.1	70.2	72.4	79.7	84.1	81.0	73.4	69.3	59.7	54.7	(30)	
	5%	WB	47.9	47.2	50.5	56.2	60.7	66.1	68.0	67.1	63.2	59.7	54.3	50.3	(31)	
		MCDB	50.5	50.8	58.0	67.2	70.0	76.2	80.1	77.8	70.4	65.5	58.3	53.2	(32)	
	10%	WB	45.7	45.1	48.7	54.5	58.6	63.9	66.2	65.4	61.1	58.0	52.2	48.3	(33)	
		MCDB	48.3	49.0	54.5	63.6	68.4	71.4	75.5	73.8	67.4	62.3	56.1	50.9	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	9.0	11.4	16.5	19.7	19.0	18.6	20.0	19.9	19.2	15.0	11.4	9.3	(35)	
		MCDBR	9.5	15.6	26.9	28.5	26.1	26.4	29.1	29.1	27.4	20.1	14.1	10.4	(36)	
	5% WB	MCWBR	8.1	11.2	16.2	14.8	12.3	12.1	11.6	14.0	15.3	12.3	10.2	7.6	(37)	
		MCWBR	9.5	14.8	21.5	25.1	21.9	22.4	24.6	25.0	21.9	18.4	12.7	9.8	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.326	0.349	0.382	0.415	0.423	0.422	0.427	0.418	0.389	0.364	0.340	0.323	(40)	
		taud	2.400	2.357	2.272	2.206	2.226	2.247	2.236	2.283	2.351	2.410	2.402	2.369	(41)	
	Ebn at Noon		220	245	257	261	264	265	262	258	252	236	212	200	(42)	
		Edh at Noon	20	27	35	41	42	42	42	38	32	25	20	18	(43)	
(44) All-Sky Solar Radiation	RadAvg		244	457	825	1315	1568	1704	1611	1373	1029	607	287	190	(44)	
	RadStd		33	90	117	148	147	148	193	137	103	50	32	28	(45)	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (84 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page