

BUZENOL, Belgium

WMO: 064840

Lat: 49.6203N

Lon: 5.5875E

Elev: 324

StdP: 97.49

Time Zone: 1.00 (EUC)

Period: 09-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-8.8	-6.3	-13.3	1.2	-6.7	-9.9	1.7	-4.5	8.4	7.0	7.7	6.7	2.3	70	0.537

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.3	29.7	19.8	27.1	18.9	25.0	17.5	20.9	26.8	19.9	25.2	18.9	23.6	2.9	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.4	14.7	22.2	18.3	13.7	21.2	17.3	12.8	20.1	61.8	26.7	58.2	25.1	54.9	23.7	25.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.3	6.4	5.7	-12.9	34.1	3.3	1.7	-15.2	35.3	-17.1	36.3	-19.0	37.3	-21.4	38.6		
(5)			-13.1	23.4	3.3	1.1	-15.5	24.2	-17.4	24.8	-19.3	25.4	-21.7	26.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	9.3	1.4	1.5	5.4	8.7	11.9	15.6	17.5	16.8	13.4	9.9	5.8	2.7
	DBStd	6.70	3.94	4.22	3.60	3.66	3.55	3.29	3.31	3.20	2.86	3.68	3.53	4.19
	HDD10.0	1150	266	238	147	68	20	0	0	0	3	47	133	228
	HDD18.3	3378	524	471	402	289	202	96	55	68	149	260	376	486
	CDD10.0	882	0	0	3	28	78	168	234	212	106	45	7	1
	CDD18.3	70	0	0	0	0	2	14	31	22	2	0	0	0
	CDH23.3	882	0	0	0	4	31	186	367	254	39	2	0	0
	CDH26.7	266	0	0	0	0	4	51	122	81	7	0	0	0
Wind	WSAvg	2.7	2.9	3.0	3.1	3.0	2.7	2.7	2.4	2.3	2.4	2.5	2.9	2.9
Precipitation	PrecAvg	1002	111	88	79	62	69	69	76	82	71	90	91	115
	PrecMax	1263	277	207	183	154	141	190	205	192	133	204	164	317
	PrecMin	714	15	7	7	4	19	29	26	18	17	40	37	68
	PrecStd	147	64	53	45	36	31	39	37	43	38	36	38	59
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.2	13.8	19.0	23.6	26.6	31.1	33.3	32.5	27.5	22.6	15.7	12.3
		MCWB	10.0	7.4	10.5	14.3	18.3	20.0	20.3	19.7	18.8	15.6	14.1	10.8
	2%	DB	9.9	10.1	17.0	21.4	23.6	28.1	29.9	29.0	23.8	19.8	13.8	10.8
		MCWB	9.2	7.6	9.8	12.7	15.9	19.7	20.0	19.4	17.2	15.7	12.6	9.8
	5%	DB	8.4	8.6	14.3	19.0	21.6	25.1	27.1	26.0	21.5	16.9	12.5	9.6
		MCWB	7.8	7.4	8.4	11.8	15.0	17.8	18.7	18.4	16.6	14.4	11.4	8.8
	10%	DB	6.9	7.2	11.7	16.3	19.3	22.9	24.8	23.5	19.1	15.0	11.0	8.4
		MCWB	6.4	6.1	8.1	10.7	14.2	16.9	17.7	17.6	15.2	13.5	10.0	7.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.5	9.7	11.4	15.6	19.3	22.2	22.3	21.8	19.7	17.7	14.9	11.3
		MCDB	10.8	11.9	16.0	22.5	24.7	29.0	26.1	27.0	23.8	19.6	15.3	11.7
	2%	WB	9.3	8.5	10.4	13.6	17.4	20.3	21.0	20.3	18.4	16.1	12.7	10.1
		MCDB	9.8	9.7	14.4	19.2	21.0	25.8	27.7	25.2	22.5	18.7	13.2	10.7
	5%	WB	7.7	7.2	9.5	12.3	15.9	18.9	20.0	19.3	17.1	14.9	11.5	9.0
		MCDB	8.2	8.5	13.2	17.6	19.5	23.7	25.8	24.2	20.5	16.7	12.3	9.5
	10%	WB	6.5	6.1	8.4	11.3	14.7	17.5	18.9	18.3	15.9	13.8	10.1	7.8
		MCDB	6.9	7.3	11.6	15.7	18.6	21.8	23.5	22.5	18.6	15.2	10.8	8.4
Mean Daily Temperature Range	5% DB	MDBR	4.6	6.1	8.9	11.0	10.7	10.6	11.3	11.0	9.9	7.8	4.9	5.1
		MCDBR	5.7	8.9	14.9	15.4	14.2	15.0	15.9	15.5	14.1	11.0	6.6	6.0
		MCWBR	5.1	6.6	8.6	8.3	7.7	7.6	6.9	7.1	7.9	7.1	5.5	5.4
	5% WB	MCDBR	5.4	7.8	11.9	13.6	11.9	13.0	13.6	12.7	11.6	9.3	6.3	5.8
		MCWBR	5.0	6.2	7.8	7.7	7.2	7.2	6.7	6.9	7.1	6.8	5.5	5.4
Clear-Sky Solar Irradiance	taub	0.304	0.329	0.359	0.389	0.399	0.401	0.398	0.393	0.365	0.350	0.323	0.302	
	taud	2.437	2.395	2.325	2.261	2.268	2.288	2.289	2.330	2.388	2.429	2.446	2.422	
	Ebn at Noon	750	812	845	854	859	859	855	841	830	776	716	694	
	Edh at Noon	62	82	104	124	128	127	125	114	97	79	62	56	
All-Sky Solar Radiation	RadAvg	0.81	1.53	2.73	4.25	5.02	5.58	5.30	4.54	3.46	1.99	0.92	0.64	
	RadStd	0.13	0.28	0.38	0.53	0.56	0.51	0.53	0.51	0.36	0.17	0.10	0.11	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (58 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page