

SPA LA SAUVENIERE AP, Belgium

WMO: 064900

Lat: 50.4786N

Lon: 5.9100E

Elev: 1581

StdP: 13.88

Time Zone: 1.00 (EUC)

Period: 07-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	17.2	20.5	5.9	7.9	23.4	12.5	11.0	24.2	25.6	31.0	23.7	33.3	6.0	150	0.588

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.3	82.0	65.8	77.6	63.9	74.0	61.8	67.3	78.3	65.1	74.9	63.4	71.9	7.4	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
63.3	92.4	71.4	61.5	86.6	69.1	59.9	81.7	67.5	32.6	78.6	30.8	75.2	29.5	71.9	72.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 21.0	18.7	16.7	DB	13.3	89.3	5.7	3.3	9.1	91.7	5.8	93.6	2.6	95.5	-1.6	97.9	(4)
(5)			WB	12.1	70.8	5.8	1.4	7.9	71.8	4.5	72.6	1.2	73.5	-3.0	74.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	48.1	33.8	34.8	40.3	47.6	53.5	58.7	62.6	61.7	55.5	49.4	41.7	36.4	(6)
(7)		DBStd	12.16	6.81	8.01	7.35	7.71	7.33	6.47	6.71	5.84	5.54	6.88	6.42	6.70	(7)
(8)		HDD50	2212	503	427	311	137	47	3	0	0	8	96	259	421	(8)
(9)		HDD65	6304	968	846	766	523	362	211	129	137	291	485	700	886	(9)
(10)		CDD50	1508	0	2	10	64	156	264	390	364	173	76	9	0	(10)
(11)		CDD65	124	0	0	0	1	5	21	54	36	7	0	0	0	(11)
(12)		CDH74	819	0	0	0	3	28	150	367	240	31	0	0	0	(12)
(13)		CDH80	206	0	0	0	0	3	31	106	63	3	0	0	0	(13)
(14)	Wind	WSAvg	8.3	9.9	9.5	8.8	7.6	7.2	6.9	6.9	7.3	7.3	8.8	9.7	10.2	(14)
(15)	Precipitation	PrecAvg	41.0	3.9	3.5	3.0	2.6	3.0	3.2	3.6	3.9	3.1	3.1	3.7	4.4	(15)
(16)		PrecMax	53.9	9.8	9.0	6.5	6.6	7.2	6.5	9.8	9.1	8.7	8.3	6.3	11.3	(16)
(17)		PrecMin	30.4	0.2	0.6	0.4	0.1	1.1	1.0	1.4	1.3	0.4	1.2	0.3	0.7	(17)
(18)		PrecStd	6.3	2.0	1.8	1.8	1.4	1.3	1.4	1.7	2.0	2.0	1.5	1.4	2.2	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	50.2	57.6	64.1	72.9	77.9	85.0	89.0	86.7	78.8	70.5	59.7	52.2	(19)
(20)			MCWB	48.3	44.0	49.6	55.3	61.7	67.2	66.2	67.4	63.8	58.8	54.4	49.0	(20)
(21)		2%	DB	47.9	50.2	59.5	68.3	72.4	78.4	82.5	80.5	72.1	65.5	55.6	49.8	(21)
(22)			MCWB	46.1	42.1	47.7	53.2	58.3	64.7	66.4	65.3	60.9	57.5	51.2	47.3	(22)
(23)		5%	DB	45.0	46.7	54.4	64.0	69.1	74.0	77.6	75.6	68.1	61.5	53.1	47.6	(23)
(24)			MCWB	43.3	43.2	45.8	52.0	57.2	62.0	64.1	63.2	59.5	55.6	50.0	45.7	(24)
(25)		10%	DB	42.6	44.6	50.3	59.7	65.4	70.0	73.8	71.6	64.3	58.5	50.6	45.3	(25)
(26)			MCWB	41.0	41.6	44.0	50.1	55.8	60.3	62.1	61.8	57.5	54.0	48.2	43.6	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	48.8	47.4	51.1	57.1	64.4	69.1	69.6	69.7	65.0	60.9	56.0	50.2	(27)
(28)			MCD B	49.7	51.3	59.9	69.9	73.6	81.2	83.1	81.9	76.0	67.0	59.5	51.2	(28)
(29)		2%	WB	46.1	45.6	48.7	54.4	61.6	65.6	67.3	66.6	62.3	58.5	52.1	47.6	(29)
(30)			MCD B	47.4	48.1	56.0	65.1	69.1	75.3	79.0	76.6	69.5	63.6	54.6	49.3	(30)
(31)		5%	WB	43.5	43.8	46.8	52.4	58.4	63.2	65.2	64.3	60.3	56.6	50.3	45.7	(31)
(32)			MCD B	44.9	46.6	52.3	61.9	65.7	71.5	75.6	73.6	67.2	60.9	52.8	47.4	(32)
(33)		10%	WB	41.1	41.9	45.0	50.6	56.3	61.2	63.4	62.5	58.2	54.6	48.2	43.7	(33)
(34)			MCD B	42.4	44.7	49.5	58.9	63.8	69.0	72.2	70.1	63.4	58.1	50.6	45.1	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	6.5	8.2	11.1	13.8	14.3	14.2	14.3	13.8	11.8	9.8	7.3	6.8	(35)
(36)			MCDBR	8.2	11.8	17.1	18.5	18.6	20.0	19.3	19.9	16.7	13.6	10.3	8.9	(36)
(37)			MCWBR	8.3	8.4	9.4	9.8	9.8	10.4	9.1	9.8	8.9	8.3	7.6	7.3	(37)
(38)		5% WB	MCDBR	8.3	10.2	13.9	16.9	16.0	17.3	17.5	17.5	15.1	12.3	9.7	8.0	(38)
(39)			MCWBR	8.3	8.1	9.1	9.3	9.7	10.1	9.0	9.6	8.6	8.2	7.7	7.4	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.300	0.322	0.354	0.386	0.394	0.395	0.396	0.389	0.361	0.342	0.317	0.297	(40)	
(41)		taud	2.443	2.393	2.333	2.271	2.283	2.295	2.288	2.332	2.395	2.451	2.450	2.421	(41)	
(42)		Ebn at Noon	236	258	268	271	273	273	271	267	263	247	226	217	(42)	
(43)		Edh at Noon	19	26	32	39	40	40	39	36	30	24	19	17	(43)	
(44)	All-Sky Solar Radiation	RadAvg	245	461	824	1308	1545	1694	1607	1374	1032	607	286	192	(44)	
(45)		RadStd	37	89	121	153	153	158	190	143	118	56	36	30	(45)	

Historical Trends

		Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (77 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page