

MONT-RIGI, Belgium

WMO: 064940

Lat: 50.5108N

Lon: 6.0733E

Elev: 2208

StdP: 13.56

Time Zone: 1.00 (EUC)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	14.3	17.6	6.1	8.1	19.4	12.6	11.3	19.2	25.3	40.0	23.2	39.3	5.9	80	0.623

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	15.7	79.7	64.8	75.4	62.8	71.9	60.7	66.2	75.8	64.1	72.7	62.4	69.5	7.3	170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
62.9	93.0	68.9	61.2	87.5	67.0	59.6	82.7	65.3	32.1	76.2	30.4	73.2	29.2	69.9	76.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 21.8	19.2	17.1	9.9	86.6	5.2	3.3	6.2	88.9	3.1	90.8	0.2	92.7	-3.6	95.1		
(5)			8.6	71.1	5.3	2.2	4.8	72.6	1.7	73.9	-1.3	75.1	-5.1	76.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	45.3	30.7	31.5	37.7	44.5	50.6	56.0	59.7	59.2	53.1	47.1	39.5	33.5		
	DBStd	12.27	6.47	7.88	7.51	7.74	7.33	6.57	6.62	5.97	5.60	7.02	6.58	6.91		
	HDD50	2805	597	520	385	202	84	14	2	3	26	140	320	512		
	HDD65	7243	1062	939	846	616	448	281	192	203	359	555	766	976		
	CDD50	1103	0	1	5	36	103	194	303	287	119	51	4	0		
	CDD65	65	0	0	0	0	2	11	28	22	2	0	0	0		
	CDH74	498	0	0	0	0	12	93	215	163	15	0	0	0		
	CDH80	99	0	0	0	0	1	13	54	31	0	0	0	0		
(14) Wind	WSAvg	8.4	9.7	9.5	9.2	7.7	7.9	7.0	7.1	7.0	7.3	8.8	9.8	10.0		
(15) Precipitation	PrecAvg	40.4	3.8	3.4	3.0	2.5	2.9	3.4	3.6	3.7	3.1	3.1	3.5	4.3		
	PrecMax	49.0	8.0	9.1	6.3	5.4	6.7	6.9	8.8	8.0	8.0	8.2	5.9	10.5		
	PrecMin	31.5	0.2	0.7	0.5	0.0	1.3	1.1	1.1	1.5	0.6	1.3	0.1	0.8		
	PrecStd	5.0	1.9	1.8	1.7	1.2	1.1	1.3	1.7	1.9	1.9	1.5	1.4	2.0		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	47.1	56.9	62.3	69.0	75.7	81.8	86.2	83.7	76.3	69.2	58.9	49.4		
		MCWB	46.6	42.8	47.6	51.9	60.9	66.2	66.0	65.9	63.1	57.3	51.4	47.6		
	2%	DB	44.3	47.0	57.7	65.5	70.3	76.3	79.8	79.0	70.6	64.5	53.6	47.2		
		MCWB	43.5	41.7	46.5	51.5	56.6	63.2	64.8	64.3	60.0	56.9	49.5	45.6		
	5%	DB	41.7	43.6	52.3	61.1	66.7	71.9	74.9	73.7	66.5	59.4	50.8	45.0		
		MCWB	40.9	41.3	43.9	50.1	55.3	60.6	62.9	62.7	58.7	54.5	48.8	43.6		
	10%	DB	39.3	41.1	47.6	56.6	63.2	67.9	71.4	69.7	62.2	56.1	48.4	42.6		
		MCWB	38.6	39.3	42.4	48.0	54.4	59.1	60.9	60.3	56.6	52.9	46.9	41.5		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	47.0	45.9	49.5	54.7	63.7	68.6	68.4	68.4	64.2	59.9	54.5	48.6		
		MCDB	47.0	51.5	57.5	64.6	71.6	79.4	79.7	79.7	73.5	65.2	56.2	48.8		
	2%	WB	43.6	43.7	47.3	52.7	60.1	64.4	66.1	65.8	61.7	57.5	50.8	46.2		
		MCDB	44.1	45.9	54.5	61.9	66.3	73.0	76.1	74.8	68.4	62.0	52.6	46.8		
	5%	WB	41.1	41.6	45.4	50.7	57.3	62.1	64.2	63.6	59.4	55.5	49.0	43.9		
		MCDB	41.5	43.7	50.7	58.7	64.0	69.3	73.5	71.0	65.4	59.0	50.5	44.7		
	10%	WB	38.8	39.2	43.4	48.8	55.0	60.0	62.2	61.8	57.4	53.6	46.9	41.6		
		MCDB	39.3	40.8	47.1	55.8	61.5	66.6	69.3	68.1	61.5	55.9	48.5	42.4		
(35) Mean Daily Temperature Range	5% DB	MDBR	6.3	7.9	11.4	14.7	15.4	15.5	15.7	15.7	13.5	10.7	7.7	7.1		
		MCDBR	8.4	12.1	18.9	19.9	19.8	21.1	21.1	21.4	18.6	15.8	12.0	10.1		
	5% WB	MCWBR	8.0	9.0	10.5	10.3	10.4	11.3	10.4	11.1	10.6	9.9	9.0	8.2		
		MCWBR	7.9	10.6	15.6	18.1	17.0	18.6	18.4	18.3	16.7	13.5	10.4	8.6		
(40) Clear-Sky Solar Irradiance	taub	taub	0.290	0.311	0.341	0.372	0.379	0.381	0.382	0.376	0.349	0.330	0.307	0.287		
		taud	2.465	2.418	2.369	2.311	2.321	2.327	2.317	2.360	2.421	2.479	2.478	2.446		
	Ebn at Noon	Ebn at Noon	241	263	273	276	278	278	275	272	267	252	231	223		
		Edh at Noon	18	25	31	37	38	38	38	35	30	23	18	16		
(44) All-Sky Solar Radiation	RadAvg	RadAvg	244	461	822	1307	1541	1691	1603	1372	1027	603	283	189		
	RadStd	RadStd	37	89	122	153	150	159	190	141	121	57	36	29		

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (74 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page