

LE MOLESON, Switzerland

WMO: 066090

Lat: 46.5462N

Lon: 7.0177E

Elev: 6473

StdP: 11.57

Time Zone: 1.00 (EUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	4.8	8.5	-19.7	2.4	27.5	-13.8	3.3	25.7	54.8	27.3	46.3	28.7	11.8	40	0.815

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.7	67.6	56.1	64.8	54.7	62.3	53.4	58.6	64.6	56.6	62.2	54.9	60.4	7.9	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
56.2	85.8	61.6	54.3	79.9	59.6	52.4	74.6	57.8	28.6	64.9	27.1	62.0	25.9	60.6	66.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 40.2	33.1	28.1	1.6	72.6	5.1	3.5	-2.0	75.1	-5.0	77.1	-7.9	79.1	-11.6	81.6		
(5)			0.4	62.6	4.6	1.9	-2.9	64.0	-5.6	65.1	-8.2	66.2	-11.6	67.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	38.3	26.1	25.5	29.2	35.1	40.8	48.9	52.0	51.6	45.8	41.9	33.0	28.8	
	DBStd	12.45	7.86	9.12	8.37	7.85	8.09	8.20	7.23	7.52	7.35	8.21	8.81	8.49	
	HDD50	4674	740	686	646	447	303	118	65	74	164	265	510	656	
	HDD65	9749	1205	1106	1111	896	752	484	406	417	576	715	960	1121	
	CDD50	406	0	0	0	1	17	85	126	124	38	15	0	0	
	CDD65	6	0	0	0	0	0	2	2	2	0	0	0	0	
	CDH74	4	0	0	0	0	0	2	2	0	0	0	0	0	
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0	
Wind	WSAvg	11.8	14.8	13.5	12.8	10.3	10.1	10.3	9.6	9.9	9.8	11.6	14.0	15.6	
Precipitation	PrecAvg	49.8	3.0	3.0	3.1	3.8	5.1	5.3	5.6	5.4	4.2	4.0	3.9	3.7	
	PrecMax	60.7	7.8	8.2	10.1	6.8	9.4	10.8	13.2	9.3	7.6	7.9	7.7	8.0	
	PrecMin	38.7	0.6	0.8	1.3	1.0	2.0	2.2	1.9	0.9	2.0	0.3	0.3	0.2	
	PrecStd	6.4	1.8	1.9	1.9	1.7	2.1	2.0	2.4	2.0	1.5	1.7	2.0	1.9	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	46.3	48.3	48.3	55.2	61.9	71.2	71.3	71.0	62.8	59.9	53.5	48.5	
		MCWB	33.4	35.4	34.1	43.8	50.4	56.5	58.0	57.7	53.0	47.1	38.9	33.8	
	2%	DB	42.9	45.0	45.0	51.3	58.1	66.2	67.2	67.2	60.0	56.7	49.6	45.1	
		MCWB	31.2	32.2	34.3	42.2	48.7	55.4	56.1	56.1	51.7	44.8	37.7	32.1	
	5%	DB	39.8	40.8	42.2	48.6	54.9	62.8	64.0	64.5	57.5	54.3	46.8	42.3	
		MCWB	30.5	30.7	33.3	40.5	47.1	53.9	54.9	54.1	50.1	43.6	36.9	31.4	
	10%	DB	36.4	37.0	39.8	45.6	51.9	59.8	61.3	61.9	55.2	52.1	44.5	39.7	
		MCWB	29.8	29.2	32.3	38.6	45.0	52.2	53.5	53.2	48.4	42.3	35.5	30.8	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	38.2	41.1	39.4	45.8	53.8	60.7	60.3	61.3	56.2	50.1	42.7	39.0
			MCDB	40.0	43.5	43.3	52.1	58.6	67.2	66.9	67.4	60.1	56.3	47.9	42.3
2%		WB	35.3	34.6	36.9	43.4	50.5	57.5	58.4	58.4	53.7	47.6	40.6	36.2	
		MCDB	37.8	39.0	41.1	49.4	55.7	63.1	64.2	64.7	57.9	52.8	45.5	39.6	
5%		WB	33.3	32.5	35.2	41.3	48.0	55.3	56.4	56.0	51.7	46.0	38.9	34.3	
		MCDB	36.2	36.9	39.6	47.0	53.4	60.9	62.0	61.9	56.0	51.2	44.0	38.0	
10%		WB	31.3	30.7	33.5	39.5	45.8	53.1	54.7	54.2	49.7	44.5	37.2	32.5	
		MCDB	35.2	35.9	38.0	44.8	50.9	58.3	60.1	60.0	53.7	49.6	42.7	36.5	
Mean Daily Temperature Range		5% DB	MDBR	8.8	9.4	8.7	9.1	9.5	10.0	10.7	9.9	9.1	9.2	8.6	9.2
			MCDBR	11.8	14.5	10.6	11.5	12.3	11.9	12.9	11.5	10.7	10.8	10.3	11.4
	MCWBR		8.0	9.9	8.2	9.5	10.4	11.6	10.6	10.6	10.5	8.7	6.9	7.9	
	5% WB	MCDBR	10.3	12.3	9.2	10.9	11.6	11.4	11.8	11.2	10.2	9.5	9.8	11.3	
		MCWBR	9.7	10.8	8.2	9.4	10.6	11.4	10.7	11.3	10.5	8.6	8.0	10.0	
Clear-Sky Solar Irradiance	taub	0.225	0.243	0.272	0.299	0.309	0.312	0.311	0.304	0.290	0.274	0.249	0.226		
	taud	2.483	2.462	2.480	2.466	2.478	2.500	2.488	2.520	2.554	2.589	2.581	2.508		
	Ebn at Noon	290	303	307	305	303	302	301	299	297	288	278	278		
	Edh at Noon	20	25	29	32	33	33	33	30	27	22	18	17		
All-Sky Solar Radiation	RadAvg	434	711	1068	1386	1581	1876	1847	1609	1263	818	459	353		
	RadStd	49	102	153	197	137	177	159	146	110	84	62	56		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (103 neighbors)	N/A	N/A	N/A	+1.30	+0.72	+0.54	N/A	N/A	+97	+32

Nomenclature: See separate page