

LE MOLESON, Switzerland

WMO: 066090

Lat: 46.5462N

Lon: 7.0177E

Elev: 1973

StdP: 79.76

Time Zone: 1.00 (EUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-15.1	-13.1	-28.7	0.3	-2.5	-25.4	0.5	-3.5	24.5	-2.6	20.7	-1.8	5.3	40	0.815

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	6.0	19.8	13.4	18.2	12.6	16.8	11.9	14.8	18.1	13.7	16.8	12.7	15.8	3.6	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
13.4	12.3	16.4	12.4	11.4	15.3	11.4	10.7	14.3	48.7	18.3	45.1	16.7	42.3	15.9	19.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 18.0	14.8	12.5	DB	-16.9	22.5	2.8	1.9	-18.9	23.9	-20.6	25.1	-22.1	26.1	-24.2	27.5	(4)
(5)			WB	-17.6	17.0	2.6	1.1	-19.4	17.8	-20.9	18.4	-22.4	19.0	-24.2	19.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	3.5	-3.3	-3.6	-1.6	1.7	4.9	9.4	11.1	10.9	7.7	5.5	0.6	-1.8
	DBStd	6.92	4.37	5.07	4.65	4.36	4.50	4.55	4.02	4.18	4.09	4.56	4.89	4.72
	HDD10.0	2597	411	381	359	248	168	66	36	41	91	147	283	364
	HDD18.3	5416	669	614	617	498	418	269	226	232	320	397	533	623
	CDD10.0	226	0	0	0	1	9	47	70	69	21	8	0	0
	CDD18.3	3	0	0	0	0	0	1	1	1	0	0	0	0
	CDH23.3	2	0	0	0	0	0	1	1	0	0	0	0	0
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	5.3	6.6	6.0	5.7	4.6	4.5	4.6	4.3	4.4	4.4	5.2	6.3	7.0
Precipitation	PrecAvg	1266	75	75	79	96	129	135	143	136	106	102	98	93
	PrecMax	1541	198	208	256	173	238	275	336	236	193	200	195	203
	PrecMin	982	16	20	34	26	51	55	48	22	50	8	7	4
	PrecStd	162	45	48	47	42	53	52	60	52	38	42	52	47
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	7.9	9.1	9.0	12.9	16.6	21.8	21.8	21.7	17.1	15.5	11.9	9.2
		MCWB	0.8	1.9	1.2	6.5	10.2	13.6	14.5	14.3	11.7	8.4	3.8	1.0
	2%	DB	6.1	7.2	7.2	10.7	14.5	19.0	19.5	19.5	15.6	13.7	9.8	7.3
		MCWB	-0.4	0.1	1.3	5.7	9.3	13.0	13.4	13.4	11.0	7.1	3.2	0.0
	5%	DB	4.3	4.9	5.7	9.2	12.7	17.1	17.8	18.0	14.2	12.4	8.2	5.7
		MCWB	-0.8	-0.7	0.7	4.7	8.4	12.2	12.7	12.3	10.1	6.5	2.7	-0.3
	10%	DB	2.4	2.8	4.4	7.6	11.0	15.4	16.3	16.6	12.9	11.2	6.9	4.3
		MCWB	-1.2	-1.5	0.2	3.6	7.2	11.2	11.9	11.8	9.1	5.7	2.0	-0.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	3.4	5.0	4.1	7.7	12.1	16.0	15.7	16.3	13.5	10.1	6.0	3.9
		MCDB	4.4	6.4	6.3	11.2	14.8	19.6	19.4	19.7	15.6	13.5	8.8	5.7
	2%	WB	1.9	1.5	2.7	6.3	10.3	14.2	14.7	14.6	12.0	8.7	4.8	2.3
		MCDB	3.2	3.9	5.1	9.7	13.1	17.3	17.9	18.2	14.4	11.5	7.5	4.2
	5%	WB	0.7	0.3	1.8	5.2	8.9	12.9	13.6	13.3	10.9	7.8	3.8	1.3
		MCDB	2.3	2.7	4.2	8.4	11.9	16.1	16.6	16.6	13.3	10.6	6.6	3.3
	10%	WB	-0.4	-0.7	0.8	4.1	7.6	11.7	12.6	12.3	9.8	6.9	2.9	0.3
		MCDB	1.8	2.2	3.3	7.1	10.5	14.6	15.6	15.6	12.1	9.8	6.0	2.5
Mean Daily Temperature Range	5% DB	MDBR	4.9	5.2	4.8	5.0	5.3	5.6	6.0	5.5	5.0	5.1	4.8	5.1
		MCDBR	6.5	8.0	5.9	6.4	6.9	6.6	7.2	6.4	6.0	6.0	5.7	6.3
		MCWBR	4.5	5.5	4.6	5.3	5.8	6.4	5.9	5.9	5.9	4.9	3.8	4.4
	5% WB	MCDBR	5.7	6.8	5.1	6.1	6.5	6.4	6.6	6.2	5.7	5.3	5.4	6.3
		MCWBR	5.4	6.0	4.5	5.2	5.9	6.4	6.0	6.3	5.8	4.8	4.5	5.5
Clear-Sky Solar Irradiance	taub	0.225	0.243	0.272	0.299	0.309	0.312	0.311	0.304	0.290	0.274	0.249	0.226	
	taud	2.483	2.462	2.480	2.466	2.478	2.500	2.488	2.520	2.554	2.589	2.581	2.508	
	Ebn at Noon	914	956	967	962	956	952	948	944	935	907	877	876	
	Edh at Noon	62	79	91	102	105	104	103	96	85	70	57	54	
All-Sky Solar Radiation	RadAvg	1.37	2.24	3.37	4.37	4.98	5.92	5.82	5.07	3.98	2.58	1.45	1.11	
	RadStd	0.15	0.32	0.48	0.62	0.43	0.56	0.50	0.46	0.35	0.27	0.19	0.18	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (103 neighbors)		N/A	N/A	N/A	+0.72	+0.40	+0.30	N/A	N/A	+54	+18

Nomenclature: See separate page