

LA CHAUX-DE-FONDS, Switzerland

WMO: 066120

Lat: 47.0831N

Lon: 6.7922E

Elev: 1018

StdP: 89.68

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-13.5	-10.8	-16.6	1.0	-11.6	-13.7	1.3	-9.1	10.0	4.8	8.8	3.1	1.7	60	0.567

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.5	26.6	17.3	24.7	16.7	23.0	16.0	18.2	24.3	17.4	23.2	16.6	21.9	2.7	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
16.0	12.9	20.6	15.1	12.2	19.9	14.4	11.6	19.1	55.8	24.6	53.0	23.3	50.4	22.1	21.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
7.9	6.8	5.9	-18.4	29.2	3.4	1.8	-20.9	30.4	-22.9	31.5	-24.8	32.4	-27.3	33.7		
			-18.5	19.8	3.0	0.9	-20.6	20.5	-22.4	21.0	-24.1	21.5	-26.2	22.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	7.1	-1.2	-0.8	2.6	6.2	10.1	14.0	15.6	15.3	11.6	8.5	3.1	0.0	(6)
(7)		DBStd	7.21	4.40	4.65	4.19	3.87	3.54	3.80	3.35	3.34	3.35	3.85	4.40	4.41	(7)
(8)		HDD10.0	1671	347	302	230	124	43	8	2	2	22	72	207	312	(8)
(9)		HDD18.3	4122	606	536	488	366	256	138	97	105	202	304	456	570	(9)
(10)		CDD10.0	622	0	0	1	9	47	127	176	166	71	27	1	0	(10)
(11)		CDD18.3	31	0	0	0	0	0	7	12	11	1	0	0	0	(11)
(12)		CDH23.3	322	0	0	0	0	4	80	119	116	3	0	0	0	(12)
(13)		CDH26.7	52	0	0	0	0	0	13	19	20	0	0	0	0	(13)
(14)	Wind	WSAvg	2.1	2.3	2.4	2.5	2.2	2.0	1.9	1.7	1.9	1.9	2.2	2.4	(14)	
(15)	Precipitation	PrecAvg	1371	105	100	92	103	124	117	126	125	112	119	121	128	(15)
(16)		PrecMax	1777	274	238	302	183	211	238	284	259	223	214	306	276	(16)
(17)		PrecMin	1006	21	29	23	28	52	49	55	31	49	16	11	2	(17)
(18)		PrecStd	201	64	54	66	53	48	48	49	57	50	51	67	66	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.4	12.1	15.8	20.1	23.6	28.5	29.0	29.2	23.5	21.1	16.0	11.2	(19)
MCWB			5.0	5.1	7.9	11.3	15.0	17.6	17.5	17.1	15.6	12.8	9.4	6.2	(20)	
2%		DB	7.8	9.4	13.6	17.7	21.2	25.7	26.4	26.2	21.9	18.7	13.4	9.0	(21)	
		MCWB	5.1	4.3	7.0	10.0	13.7	17.0	17.2	17.4	15.2	12.2	8.4	5.6	(22)	
5%		DB	6.2	7.3	11.5	15.5	19.3	23.4	24.3	24.3	20.0	16.8	11.4	7.5	(23)	
		MCWB	4.0	3.8	6.2	9.3	12.7	16.1	16.8	16.6	14.2	11.6	7.7	5.3	(24)	
10%		DB	4.8	5.4	9.1	13.2	17.1	21.4	22.5	22.2	18.0	14.9	9.6	6.1	(25)	
		MCWB	3.0	3.1	5.5	8.1	11.7	15.4	16.0	16.1	13.5	10.9	7.2	4.3	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.3	6.5	9.0	12.1	16.2	19.3	19.1	19.1	17.2	14.2	10.7	7.9	(27)
MCDWB			8.4	9.1	13.3	18.3	22.0	25.9	25.3	25.5	21.7	18.5	13.5	9.3	(28)	
2%		WB	5.5	5.2	7.9	10.7	14.6	17.8	18.1	18.1	15.9	13.2	9.3	6.6	(29)	
		MCDWB	7.0	8.0	11.6	16.2	19.8	23.8	24.4	24.2	20.2	16.8	11.9	8.1	(30)	
5%		WB	4.3	4.2	6.8	9.7	13.3	16.7	17.2	17.2	14.8	12.3	8.3	5.5	(31)	
		MCDWB	5.9	6.7	10.7	14.5	17.8	22.2	23.2	22.9	18.9	15.7	10.8	7.1	(32)	
10%		WB	3.2	3.2	5.7	8.6	12.1	15.7	16.4	16.3	13.8	11.3	7.2	4.4	(33)	
		MCDWB	4.5	5.4	8.8	12.6	16.3	20.7	21.7	21.3	17.3	14.3	9.5	6.0	(34)	
(35)	Mean Daily Temperature Range	5% DB	MDBR	7.2	7.7	8.3	8.8	9.0	9.5	9.5	8.9	8.9	7.3	7.0	(35)	
MCDBR			8.4	10.9	12.5	13.3	13.3	13.2	13.1	13.5	12.7	12.4	10.9	9.4	(36)	
MCWBR			5.9	7.0	7.3	7.4	7.2	6.7	6.2	6.5	7.2	7.1	7.0	6.4	(37)	
5% WB		MCDWR	6.7	8.8	10.6	11.9	11.8	12.0	11.7	12.0	11.0	10.7	9.6	7.2	(38)	
		MCWBR	5.2	6.1	6.6	6.9	6.8	6.4	6.0	6.2	6.5	6.5	6.6	5.5	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.272	0.294	0.324	0.356	0.364	0.367	0.366	0.359	0.341	0.323	0.294	0.271	(40)	
(41)		taud	2.480	2.434	2.411	2.344	2.359	2.380	2.373	2.404	2.441	2.485	2.514	2.488	(41)	
(42)		Ebn at Noon	835	882	901	898	900	897	892	885	872	835	799	793	(42)	
(43)		Edh at Noon	64	82	98	116	118	117	116	108	95	78	62	57	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.20	2.04	3.23	4.35	5.02	5.95	5.75	5.00	3.85	2.44	1.33	0.97	(44)	
(45)		RadStd	0.15	0.31	0.48	0.64	0.47	0.55	0.51	0.46	0.35	0.24	0.17	0.17	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (99 neighbors)	N/A	N/A	N/A	N/A	+0.75	+0.51	+0.29	N/A	N/A	N/A

Nomenclature: See separate page