

FAHY-BONCOURT, Switzerland

WMO: 066160

Lat: 47.4239N

Lon: 6.9411E

Elev: 597

StdP: 94.36

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-9.0	-6.9	-11.9	1.4	-6.4	-9.7	1.8	-5.1	11.0	7.8	9.8	7.4	2.8	70	0.499

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.1	28.9	19.4	26.9	18.7	25.2	18.0	20.2	26.8	19.4	25.7	18.5	24.3	2.5	50

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.9	13.8	23.5	17.1	13.1	21.9	16.3	12.5	21.2	60.8	27.0	57.6	25.9	54.7	24.4	25.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
8.3	6.9	5.9	DB	-11.9	31.7	2.9	2.3	-14.0	33.4	-15.6	34.7	-17.2	36.0	-19.3	37.8	
			WB	-12.3	22.4	2.8	1.0	-14.3	23.1	-15.9	23.6	-17.5	24.2	-19.5	24.9	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	9.6	1.1	2.2	5.4	8.9	12.8	16.5	18.4	18.1	14.0	10.4	5.2	2.3
	DBStd	7.28	4.50	4.54	4.21	4.01	3.67	3.80	3.46	3.60	3.40	3.94	4.13	4.39
	HDD10.0	1169	276	220	149	68	14	1	0	0	6	44	151	241
	HDD18.3	3292	533	453	401	284	174	80	43	49	136	246	394	498
	CDD10.0	1039	0	1	8	34	102	196	259	251	125	57	7	1
	CDD18.3	120	0	0	0	0	3	24	44	42	6	1	0	0
	CDH23.3	851	0	0	0	1	23	169	332	299	25	2	0	0
	CDH26.7	203	0	0	0	0	1	33	85	83	1	0	0	0
Wind	WSAvg	2.5	3.0	3.0	3.1	2.5	2.3	2.1	2.2	2.0	2.2	2.3	2.6	3.0
Precipitation	PrecAvg	1311	96	95	89	99	122	112	117	119	107	116	118	121
	PrecMax	1753	223	216	296	191	225	221	270	237	209	221	296	241
	PrecMin	934	14	23	21	16	58	42	44	23	40	11	14	7
	PrecStd	195	58	48	64	52	47	49	47	55	47	51	63	59
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.2	14.3	18.3	22.6	25.9	30.2	31.9	32.5	26.1	22.4	16.6	13.1
		MCWB	7.8	8.0	10.6	13.6	17.3	20.7	19.9	19.3	17.5	15.2	11.5	8.3
	2%	DB	10.4	11.7	16.0	19.7	23.3	27.3	29.0	28.8	23.7	19.7	14.1	11.1
		MCWB	7.4	7.0	9.5	12.3	16.0	19.3	19.3	19.2	17.2	14.4	10.3	8.0
	5%	DB	8.9	10.0	13.8	17.7	21.4	25.3	26.8	26.6	21.5	17.8	12.6	9.8
		MCWB	6.5	6.2	8.3	11.4	14.9	18.6	18.6	18.6	16.2	13.5	9.7	7.5
	10%	DB	7.2	8.3	11.8	15.6	19.3	23.2	24.9	24.4	19.5	16.0	11.1	8.4
		MCWB	5.2	5.5	7.6	10.1	13.9	17.3	17.8	17.9	15.2	12.8	8.7	6.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.5	9.0	11.6	14.4	18.6	21.9	21.2	21.4	19.1	16.2	12.5	9.9
		MCDB	10.9	12.5	16.6	20.9	24.5	28.1	29.0	27.4	23.6	20.3	14.8	11.4
	2%	WB	7.9	7.7	10.2	12.8	16.8	20.1	20.0	20.0	17.7	15.1	11.1	8.7
		MCDB	9.7	10.6	14.2	18.5	22.0	25.9	27.0	26.8	22.2	18.4	13.3	10.3
	5%	WB	6.7	6.8	9.0	11.7	15.5	18.9	19.1	19.1	16.7	14.1	9.9	7.7
		MCDB	8.5	9.5	12.9	16.8	20.2	24.4	25.7	25.6	20.6	17.1	12.1	9.5
	10%	WB	5.4	5.8	8.0	10.6	14.3	17.8	18.2	18.2	15.6	13.1	8.8	6.6
		MCDB	7.1	8.1	11.3	14.9	18.3	22.6	24.0	23.6	18.9	15.5	10.8	8.3
Mean Daily Temperature Range	5% DB	MDBR	4.8	5.7	7.2	8.2	8.4	8.8	9.1	8.7	7.6	6.7	5.3	4.9
		MCDBR	6.5	8.6	10.6	11.5	11.5	11.6	12.1	11.9	10.5	9.3	7.8	6.5
		MCWBR	4.5	5.5	6.1	6.3	6.2	6.1	5.3	5.2	5.5	5.4	5.1	4.6
	5% WB	MCDBR	5.8	7.4	9.2	10.5	10.5	10.9	11.0	10.7	9.2	8.5	7.1	5.9
		MCWBR	4.5	5.2	5.6	6.0	6.0	5.9	5.2	5.1	5.1	5.4	5.0	4.5
Clear-Sky Solar Irradiance	taub	0.296	0.319	0.351	0.386	0.393	0.397	0.395	0.389	0.368	0.349	0.316	0.293	
	taud	2.460	2.397	2.349	2.268	2.287	2.311	2.309	2.341	2.383	2.426	2.469	2.463	
	Ebn at Noon	795	845	867	866	871	867	863	853	839	798	760	752	
	Edh at Noon	65	86	105	125	127	125	124	115	100	83	65	58	
All-Sky Solar Radiation	RadAvg	1.09	1.91	3.14	4.34	5.05	5.96	5.70	4.96	3.76	2.36	1.25	0.89	
	RadStd	0.15	0.31	0.49	0.65	0.50	0.55	0.51	0.47	0.36	0.22	0.15	0.17	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (102 neighbors)	N/A	N/A	N/A	N/A	+0.39	+0.30	N/A	N/A	+52	+16

Nomenclature: See separate page