

PLAFFEIEN, Switzerland

WMO: 066280

Lat: 46.7478N

Lon: 7.2661E

Elev: 1041

StdP: 89.43

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -11.0	(c) -9.1	(d) -14.7	(e) 1.2	(f) -7.3	(g) -12.5	(h) 1.4	(i) -5.9	(j) 17.0	(k) 6.1	(l) 15.3	(m) 5.5	(n) 2.5	(o) 160	(p) 0.569

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 7.8	(c) 25.6	(d) 17.5	(e) 24.0	(f) 16.9	(g) 22.4	(h) 16.2	(i) 18.5	(j) 24.0	(k) 17.5	(l) 22.7	(m) 16.7	(n) 21.4	(o) 2.9	(p) 270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.3	13.2	21.5	15.4	12.4	20.5	14.7	11.8	19.6	56.7	24.2	53.6	22.8	50.9	21.5	23.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12.5	10.0	7.9	-12.9	27.9	2.5	1.6	-14.7	29.1	-16.1	30.0	-17.5	30.9	-19.3	32.1
			-13.4	20.4	2.5	1.1	-15.2	21.2	-16.7	21.8	-18.1	22.4	-20.0	23.2
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	7.6	-0.6	-0.2	3.3	6.5	10.6	14.5	16.3	15.9	12.0	8.6	3.4	0.6		
	DBStd	7.29	4.41	4.86	4.40	4.18	3.88	4.02	3.48	3.58	3.50	3.94	4.36	4.46		
	HDD10.0	1575	327	285	210	118	39	7	1	2	20	73	200	292		
	HDD18.3	3956	586	518	467	354	239	126	81	92	192	303	448	551		
	CDD10.0	709	0	0	2	14	59	142	198	186	79	28	2	0		
	CDD18.3	48	0	0	0	0	1	11	19	18	1	0	0	0		
	CDH23.3	206	0	0	0	0	2	47	85	72	0	0	0	0		
	CDH26.7	19	0	0	0	0	0	4	9	7	0	0	0	0		
(14) Wind	WSAvg	2.8	3.2	3.2	3.4	2.8	2.7	2.6	2.6	2.5	2.4	2.4	2.7	3.3		
(15) Precipitation	PrecAvg	1372	81	84	86	98	144	154	163	149	112	100	99	103		
	PrecMax	1735	217	267	248	180	239	284	321	244	179	189	214	235		
	PrecMin	1132	17	21	35	32	43	67	72	31	64	12	6	6		
	PrecStd	164	50	60	48	40	56	50	56	52	36	40	53	54		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.3	11.7	14.9	19.5	22.9	27.1	27.9	27.6	22.3	18.7	14.0	11.1		
		MCWB	5.3	5.1	8.6	11.3	15.3	18.3	18.0	18.0	16.3	12.8	8.7	5.0		
	2%	DB	8.5	9.2	13.0	16.8	20.6	24.6	25.6	25.3	20.6	16.8	12.0	9.1		
		MCWB	5.0	4.4	7.6	10.5	13.8	17.1	17.3	17.6	15.5	12.3	8.0	5.4		
	5%	DB	6.9	7.7	11.2	14.8	18.6	22.8	23.8	23.5	18.8	15.3	10.7	7.8		
		MCWB	3.8	3.8	6.4	9.4	12.8	16.3	16.8	16.9	14.5	11.5	7.3	4.6		
	10%	DB	5.4	6.1	9.4	12.9	16.9	21.0	22.1	21.7	17.2	13.9	9.4	6.6		
		MCWB	2.7	2.9	5.6	8.3	12.0	15.4	16.0	16.2	13.5	10.8	6.5	3.7		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.1	6.6	9.5	12.3	16.3	19.8	19.4	19.5	17.2	14.5	10.0	7.4		
		MCDB	9.2	9.4	13.5	17.8	21.6	25.6	25.4	24.9	21.0	16.8	12.6	9.1		
	2%	WB	5.7	5.2	8.0	10.9	14.7	18.0	18.2	18.4	16.1	13.1	8.8	6.0		
		MCDB	7.7	8.0	11.9	15.9	19.4	23.3	23.9	23.8	19.6	15.7	11.1	8.1		
	5%	WB	4.3	4.2	7.0	9.7	13.5	16.9	17.4	17.4	15.0	12.1	7.8	5.1		
		MCDB	6.3	6.9	10.5	14.2	17.8	21.8	22.6	22.3	18.1	14.5	10.0	7.3		
	10%	WB	3.0	3.2	5.9	8.6	12.2	15.9	16.5	16.5	13.9	11.1	6.8	4.1		
		MCDB	5.1	5.8	8.9	12.5	16.1	20.4	21.3	21.0	16.8	13.5	9.0	6.2		
(35) Mean Daily Temperature Range	5% DB	MDBR	4.8	5.3	6.3	7.2	7.5	7.7	7.8	7.3	6.5	5.9	5.0	4.9		
		MCDBR	6.4	7.0	8.4	9.5	9.8	9.6	9.6	9.1	8.1	7.5	6.5	6.3		
	5% WB	MCWBR	4.6	4.8	5.6	6.0	6.1	5.8	5.3	5.5	5.5	5.3	4.7	4.4		
		MCWBR	5.8	6.5	7.7	9.0	9.1	9.1	8.9	8.6	7.5	6.7	5.9	5.9		
(40) Clear-Sky Solar Irradiance	taub		0.262	0.286	0.321	0.356	0.368	0.370	0.369	0.360	0.341	0.320	0.289	0.262		
		taud	2.431	2.381	2.357	2.319	2.333	2.365	2.357	2.394	2.436	2.486	2.500	2.454		
	Ebn at Noon		849	892	904	899	896	894	889	884	873	842	809	808		
		Edh at Noon	67	87	104	119	122	119	118	109	96	78	63	58		
(44) All-Sky Solar Radiation	RadAvg		1.30	2.17	3.31	4.36	5.00	5.93	5.80	5.05	3.93	2.53	1.40	1.06		
	RadStd		0.15	0.32	0.48	0.63	0.45	0.56	0.50	0.46	0.35	0.26	0.18	0.17		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days					
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only		N/A	N/A	N/A	+0.90	+0.42	+0.30	N/A	N/A	+78	+21		
(47) Regional (111 neighbors)		N/A	N/A	N/A	+0.74	+0.42	+0.32	N/A	N/A	+57	+18		

Nomenclature: See separate page