

NAPF, Switzerland

WMO: 066390

Lat: 47.0047N

Lon: 7.9400E

Elev: 4613

StdP: 12.41

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	9.4	12.7	-5.2	4.9	27.5	1.1	6.9	26.4	33.8	34.4	30.4	34.0	6.1	10	0.652

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.5	74.0	61.4	71.1	60.0	68.5	58.8	63.6	71.3	61.7	68.8	60.0	66.7	5.3	350

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
60.6	94.0	68.0	58.8	87.9	65.6	57.2	82.8	63.9	31.5	71.5	30.0	68.9	28.6	66.7	73.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 28.4	24.6	21.1	6.3	77.9	5.5	3.1	2.4	80.1	-0.9	81.9	-4.0	83.6	-8.0	85.9		
(5)			5.4	67.5	5.4	2.0	1.6	68.9	-1.6	70.1	-4.6	71.2	-8.5	72.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	42.7	29.2	29.1	33.9	39.8	47.4	54.3	57.5	57.2	50.0	45.0	36.0	31.2		
	DBStd	13.09	8.03	9.27	8.16	8.54	7.73	8.16	7.05	7.25	7.11	8.01	8.84	8.47		
	HDD50	3554	645	586	498	320	143	47	15	17	88	190	422	583		
	HDD65	8202	1109	1006	963	755	545	332	248	259	449	619	869	1048		
	CDD50	872	0	0	0	15	63	176	249	240	89	36	4	0		
	CDD65	45	0	0	0	0	1	11	16	17	0	0	0	0		
	CDH74	85	0	0	0	0	0	22	33	30	0	0	0	0		
	CDH80	4	0	0	0	0	0	1	2	1	0	0	0	0		
	WSAvg	8.7	10.6	10.0	9.6	7.5	7.6	6.9	7.3	7.2	7.6	8.6	9.6	11.4		
	PrecAvg	50.7	3.1	3.1	3.3	3.9	5.4	5.4	5.7	5.2	4.1	3.9	3.8	3.9		
(15) Precipitation	PrecMax	63.6	8.0	7.7	10.2	7.9	9.1	9.6	11.5	9.9	7.1	6.9	8.3	8.5		
	PrecMin	37.9	0.6	1.1	1.3	0.8	1.5	2.3	1.8	0.9	1.9	0.3	0.2	0.0		
	PrecStd	7.0	1.9	1.8	2.0	1.9	2.2	1.8	2.2	2.3	1.6	1.6	2.0	2.1		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	50.6	51.4	53.8	63.1	69.6	77.1	77.7	77.6	67.8	63.8	57.2	50.9		
		MCWB	37.1	37.0	43.4	51.5	57.4	62.8	62.8	62.4	59.0	50.3	43.9	37.2		
	2%	DB	45.6	47.4	50.6	58.3	65.1	72.6	73.6	73.5	64.8	60.7	54.0	47.8		
		MCWB	35.3	35.8	41.3	48.2	54.6	61.0	61.3	60.8	56.8	50.1	43.0	36.3		
	5%	DB	42.5	44.2	48.0	54.8	61.9	69.3	70.5	70.6	62.4	57.9	51.3	44.7		
		MCWB	34.4	34.6	39.6	45.9	52.4	59.2	59.9	59.9	55.4	49.1	41.8	34.9		
	10%	DB	39.7	41.0	45.3	51.7	58.7	66.2	67.7	67.7	60.1	55.5	48.3	41.9		
		MCWB	33.5	34.0	38.3	43.8	50.8	57.3	58.4	58.8	53.8	48.2	41.1	34.7		
	0.4%	WB	41.1	40.5	45.5	52.5	59.5	66.2	65.7	65.8	61.2	55.5	47.2	41.8		
		MCDB	43.4	45.1	50.9	60.8	67.2	73.8	73.8	73.1	65.7	59.7	51.9	44.3		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	38.7	38.1	43.1	49.2	56.2	62.8	63.1	63.4	58.6	52.7	45.2	39.5		
		MCDB	41.9	42.7	48.2	56.7	63.3	70.5	71.1	70.8	63.1	56.8	50.2	43.3		
	5%	WB	36.6	36.5	41.1	46.9	53.6	60.4	61.2	61.2	56.6	50.9	43.6	38.0		
		MCDB	40.3	41.6	46.1	53.5	60.3	67.2	68.6	67.9	61.2	55.0	48.6	41.7		
	10%	WB	34.6	34.8	39.4	44.7	51.4	58.2	59.5	59.5	54.6	49.3	41.9	36.3		
		MCDB	38.6	40.1	44.2	50.9	57.3	64.7	66.4	66.1	58.9	53.9	47.1	40.1		
(35) Mean Daily Temperature Range	5% DB	MDBR	7.7	7.9	8.7	10.2	11.3	11.7	11.5	10.4	8.8	8.7	7.8	7.7		
		MCDBR	10.2	10.7	11.0	13.4	14.0	13.9	14.1	12.5	11.3	10.6	10.8	10.5		
		MCWBR	5.8	6.2	7.5	9.8	10.4	10.9	9.8	9.7	8.9	8.0	6.2	5.7		
		MCDBR	9.0	9.8	10.0	12.9	13.4	13.4	13.2	12.0	10.4	9.2	9.6	9.1		
	5% WB	MCWBR	6.9	7.1	7.6	9.6	10.4	10.9	10.0	9.9	9.0	7.9	6.7	6.7		
(40) Clear-Sky Solar Irradiance	taub		0.252	0.274	0.308	0.339	0.352	0.356	0.357	0.348	0.327	0.306	0.276	0.250		
	taud		2.454	2.410	2.395	2.359	2.364	2.387	2.371	2.409	2.458	2.508	2.522	2.467		
	Ebn at Noon		274	288	292	291	289	288	286	284	281	272	262	262		
	Edh at Noon		20	26	32	36	37	37	37	34	30	24	19	18		
(44) All-Sky Solar Radiation	RadAvg		409	685	1064	1387	1573	1847	1801	1567	1204	772	436	335		
	RadStd		49	95	154	207	151	171	159	148	115	81	57	53		

Historical Trends

DBAvg	Heating		Cooling			Degree-Days				
	99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
Station Only	N/A	N/A	N/A	+1.78	+1.03	+0.56	N/A	N/A	N/A	+16
Regional (120 neighbors)	N/A	N/A	N/A	+1.33	+0.77	+0.59	N/A	N/A	+103	+27

Nomenclature: See separate page