

MOEHLIN, Switzerland

WMO: 066410

Lat: 47.5722N

Lon: 7.8778E

Elev: 340

StdP: 97.31

Time Zone: 1.00 (EUC)

Period: 11-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-7.9	-4.8	-13.2	1.2	-8.6	-8.0	2.0	-4.0	9.9	2.8	9.2	3.0	3.0	110	0.491

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.3	31.6	20.7	29.4	20.3	27.3	19.4	21.8	28.6	20.9	27.6	20.0	26.1	2.7	300

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.6	14.9	24.8	18.7	14.1	23.1	17.9	13.4	21.8	65.1	28.8	61.7	27.7	58.5	26.3	25.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.7	7.6	6.7	DB	-10.0	34.3	3.7	1.4	-12.6	35.3	-14.8	36.1	-16.9	36.8	-19.6	37.8	(4)
(5)			WB	-10.9	23.9	3.7	0.7	-13.5	24.5	-15.7	24.9	-17.7	25.3	-20.4	25.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	10.8	2.2	2.3	6.6	10.4	13.7	18.1	19.8	15.7	11.4	6.1	3.2	(6)	
(7)		DBStd	7.25	3.66	4.33	3.29	3.70	3.49	3.31	3.28	3.38	3.00	3.40	3.34	3.13	(7)
(8)		HDD10.0	979	241	217	111	40	7	0	0	0	27	124	212	(8)	
(9)		HDD18.3	2933	499	449	363	238	148	44	22	26	89	216	368	471	(9)
(10)		CDD10.0	1272	1	1	6	52	122	242	303	297	172	69	6	1	(10)
(11)		CDD18.3	185	0	0	0	0	5	37	67	66	11	0	0	0	(11)
(12)		CDH23.3	1770	0	0	0	12	64	381	673	551	89	0	0	0	(12)
(13)		CDH26.7	577	0	0	0	1	8	123	244	188	13	0	0	0	(13)
(14)	Wind	WSAvg	2.5	3.0	3.0	2.7	2.2	2.0	1.9	1.9	2.0	2.6	2.9	3.4	(14)	
(15)	Precipitation	PrecAvg	1377	109	105	98	100	124	121	122	115	102	114	125	142	(15)
(16)		PrecMax	1834	259	260	345	205	210	252	249	271	197	226	299	297	(16)
(17)		PrecMin	1008	11	33	25	8	43	28	35	20	50	9	5	6	(17)
(18)		PrecStd	213	64	57	67	54	49	53	48	50	45	53	70	70	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.6	15.0	19.7	25.1	27.8	32.6	34.4	33.2	28.3	22.2	17.1	12.8	(19)
(20)			MCWB	10.9	9.6	11.3	15.0	19.6	22.4	21.1	21.0	19.2	16.0	12.8	10.1	(20)
(21)		2%	DB	10.2	12.3	17.8	22.3	25.0	30.1	32.1	31.0	26.3	19.9	14.7	11.1	(21)
(22)			MCWB	7.9	8.3	10.7	13.7	17.5	21.1	20.2	21.0	18.3	15.6	11.8	9.4	(22)
(23)		5%	DB	8.3	10.1	15.4	20.3	23.2	27.6	29.5	28.9	23.6	17.9	12.5	9.2	(23)
(24)			MCWB	6.8	7.3	9.6	13.3	16.6	20.0	19.6	20.3	17.6	14.6	10.5	7.9	(24)
(25)		10%	DB	6.9	7.7	13.1	18.0	21.0	25.2	27.1	26.5	21.4	16.1	10.6	7.7	(25)
(26)			MCWB	5.8	5.5	8.7	11.9	15.0	18.7	19.0	19.5	16.7	13.8	9.3	6.7	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.1	10.2	12.2	16.0	19.7	23.6	22.5	23.0	20.0	17.2	13.6	10.7	(27)
(28)			MCDWB	13.5	13.8	18.2	24.6	26.2	30.6	30.8	29.7	26.0	20.3	16.3	11.9	(28)
(29)		2%	WB	8.5	8.7	11.0	14.4	18.2	21.9	21.2	21.6	19.1	16.0	12.0	9.4	(29)
(30)			MCDWB	9.8	12.0	16.5	20.5	23.5	28.6	29.0	28.1	24.3	18.7	14.2	10.9	(30)
(31)		5%	WB	6.9	7.4	9.9	13.4	16.7	20.4	20.2	20.9	18.3	15.1	10.7	8.1	(31)
(32)			MCDWB	8.2	10.0	14.5	19.0	21.0	26.6	27.2	27.4	22.5	17.1	12.3	9.1	(32)
(33)		10%	WB	5.9	5.8	8.9	12.2	15.5	19.2	19.5	19.9	17.2	14.1	9.4	6.8	(33)
(34)			MCDWB	6.8	7.6	12.5	16.9	19.5	24.3	25.6	25.6	20.3	15.7	10.4	7.6	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	4.8	6.6	9.6	10.5	10.3	10.8	11.3	10.9	9.9	7.6	5.3	4.8	(35)
(36)			MCDBR	7.5	11.0	14.9	15.2	14.3	14.7	15.7	14.4	13.1	10.3	8.3	6.9	(36)
(37)			MCWBR	5.6	7.2	8.4	7.3	6.9	6.7	5.8	5.5	6.2	6.1	5.5	5.1	(37)
(38)		5% WB	MCDWB	7.2	10.6	13.0	13.9	12.5	13.7	13.3	13.1	11.6	9.2	7.8	6.4	(38)
(39)			MCWBR	5.4	7.1	7.6	7.1	6.5	6.7	5.6	5.3	5.7	5.8	5.4	5.0	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.309	0.336	0.371	0.407	0.417	0.421	0.421	0.414	0.390	0.367	0.331	0.306	(40)	
(41)		taud	2.438	2.355	2.295	2.222	2.238	2.271	2.266	2.300	2.345	2.392	2.441	2.440	(41)	
(42)		Ebn at Noon	772	820	842	844	848	845	839	828	813	773	735	728	(42)	
(43)		Edh at Noon	67	89	110	131	134	130	129	120	104	86	67	60	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.08	1.90	3.13	4.33	5.03	5.87	5.62	4.89	3.68	2.30	1.23	0.88	(44)	
(45)		RadStd	0.14	0.29	0.46	0.64	0.51	0.54	0.51	0.48	0.36	0.22	0.15	0.16	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (116 neighbors)		N/A	N/A	N/A	+0.74	+0.40	+0.31	N/A	N/A	+55	+14

Nomenclature: See separate page