

BEZNAU, Switzerland

WMO: 066460

Lat: 47.5572N

Lon: 8.2333E

Elev: 327

StdP: 97.46

Time Zone: 1.00 (EUC)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -7.5	(c) -5.3	(d) -11.3	(e) 1.5	(f) -5.9	(g) -8.2	(h) 1.9	(i) -3.7	(j) 6.3	(k) 7.3	(l) 5.4	(m) 6.1	(n) 1.5	(o) 40	(p) 0.442

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.4	32.1	20.7	29.9	20.2	27.9	19.5	22.0	28.8	21.1	27.6	20.2	26.1	1.8	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
20.0	15.3	24.0	19.1	14.4	22.8	18.3	13.7	21.8	65.5	28.5	62.4	27.6	59.3	26.3	26.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 4.9	(b) 4.1	(c) 3.4	(e) -10.7	(f) 34.8	(g) 3.0	(h) 1.4	(i) -12.9	(j) 35.8	(k) -14.6	(l) 36.6	(m) -16.3	(n) 37.4	(o) -18.5	(p) 38.4		
(a) 4.9	(b) 4.1	(c) 3.4	(e) -10.7	(f) 24.0	(g) 3.2	(h) 1.1	(i) -12.9	(j) 24.8	(k) -14.8	(l) 25.4	(m) -16.5	(n) 26.0	(o) -18.8	(p) 26.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	10.9	1.8	2.2	6.4	10.8	14.3	18.5	20.4	19.9	15.8	11.3	6.2	2.6		
	DBStd	7.50	3.61	4.02	3.37	3.47	3.57	3.29	3.11	3.11	3.03	3.52	3.47	3.29		
	HDD10.0	1010	256	220	117	32	5	0	0	0	1	29	121	230		
	HDD18.3	2923	514	453	369	226	133	38	14	19	86	219	364	488		
	CDD10.0	1338	1	1	6	57	138	256	323	308	175	68	7	1		
	CDD18.3	208	0	0	0	0	7	43	79	68	11	0	0	0		
	CDH23.3	2055	0	0	0	16	114	450	789	593	91	2	0	0		
	CDH26.7	697	0	0	0	2	20	146	304	209	16	0	0	0		
(14) Wind	WSAvg	1.0	1.2	1.1	1.1	1.0	1.1	1.0	1.0	0.9	0.8	0.8	1.0	1.1		
(15) Precipitation	PrecAvg	1326	118	109	98	92	115	113	115	107	91	106	120	143		
	PrecMax	1825	297	286	355	188	196	213	220	239	184	220	291	331		
	PrecMin	948	14	23	21	4	35	43	30	19	36	6	4	1		
	PrecStd	220	73	70	74	49	44	46	45	44	40	54	68	81		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.7	15.6	20.1	25.9	29.7	33.1	35.1	33.9	28.6	22.4	17.6	12.6		
		MCWB	9.8	9.4	11.4	15.5	18.8	21.8	21.2	20.7	19.2	16.2	13.0	9.8		
	2%	DB	10.0	12.1	18.1	23.1	26.2	30.5	32.5	31.4	26.1	20.1	14.9	10.5		
		MCWB	7.8	7.8	10.5	13.4	16.9	20.6	20.5	20.9	18.6	15.4	12.0	8.7		
	5%	DB	8.1	9.8	15.6	21.2	24.3	28.1	30.1	29.1	23.6	18.0	12.8	8.8		
		MCWB	6.5	7.0	9.6	13.3	16.0	19.7	19.9	20.5	17.6	14.5	10.7	7.2		
	10%	DB	6.6	7.5	13.1	18.8	21.9	25.8	27.7	26.7	21.6	16.2	10.9	7.3		
		MCWB	5.4	5.4	8.6	12.2	15.3	18.5	19.2	19.6	16.7	14.0	9.5	6.0		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.5	10.4	12.5	15.8	19.6	23.4	22.9	23.1	20.5	17.4	13.8	10.2		
		MCDB	12.2	13.9	17.9	23.8	26.1	30.7	30.7	29.1	26.1	20.6	16.3	11.5		
	2%	WB	8.1	8.3	11.1	14.5	18.2	21.6	21.7	21.9	19.2	16.2	12.3	9.0		
		MCDB	9.4	11.4	16.4	21.4	23.8	28.4	28.7	28.3	24.0	18.6	14.4	10.5		
	5%	WB	6.7	7.0	10.0	13.4	16.9	20.3	20.8	21.0	18.3	15.2	10.9	7.6		
		MCDB	8.0	9.4	14.8	19.8	22.0	26.1	27.5	27.3	22.3	17.2	12.6	8.6		
	10%	WB	5.5	5.5	8.9	12.5	15.7	19.2	19.9	20.1	17.3	14.3	9.7	6.2		
		MCDB	6.5	7.3	12.6	18.1	20.6	24.4	26.0	25.6	20.5	15.9	10.8	7.2		
(35) Mean Daily Temperature Range	5% DB	MDBR	4.9	7.0	10.4	11.6	10.8	10.9	11.4	11.1	10.1	8.0	5.6	4.8		
		MCDBR	7.4	11.7	16.0	16.9	15.6	15.6	16.4	15.2	13.5	10.8	8.5	7.0		
		MCWBR	5.5	7.5	8.9	8.0	6.9	6.5	5.4	5.8	6.5	6.4	5.5	5.4		
		MCWBR	7.2	10.8	13.9	15.5	13.5	14.2	14.1	13.6	11.9	9.7	8.0	6.7		
(40) Clear-Sky Solar Irradiance	taub	taub	0.310	0.338	0.375	0.406	0.418	0.422	0.423	0.415	0.390	0.368	0.332	0.306		
		taud	2.431	2.344	2.282	2.228	2.237	2.273	2.265	2.300	2.349	2.386	2.437	2.434		
		Ebn at Noon	771	817	838	845	847	845	837	827	813	771	733	727		
		Edh at Noon	67	90	112	130	134	130	129	120	104	86	67	60		
(44) All-Sky Solar Radiation	RadAvg	RadAvg	1.11	1.93	3.15	4.32	5.01	5.79	5.56	4.85	3.64	2.27	1.24	0.91		
		RadStd	0.13	0.28	0.44	0.62	0.51	0.53	0.51	0.49	0.37	0.23	0.15	0.15		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (114 neighbors)		N/A	N/A	N/A	+0.73	+0.42	+0.33	N/A	N/A	+56	+15

Nomenclature: See separate page