

EGOLZWIL, Switzerland

WMO: 066480

Lat: 47.1794N

Lon: 8.0047E

Elev: 1713

StdP: 13.81

Time Zone: 1.00 (EUC)

Period: 11-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	14.7	19.9	8.0	8.8	13.3	16.5	13.5	21.3	26.5	47.1	22.9	44.1	7.0	50	0.493

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.5	87.0	68.7	83.7	67.6	80.3	66.4	70.8	82.6	69.0	80.2	67.6	77.8	6.6	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
67.3	106.8	75.1	65.5	100.4	73.1	64.1	95.4	71.4	35.7	83.4	34.1	80.8	32.9	78.1	78.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 22.0	18.1	14.5	9.4	91.6	6.6	2.5	4.6	93.4	0.8	94.8	-2.9	96.2	-7.7	98.0		
(5)			7.7	73.7	5.6	2.5	3.6	75.5	0.4	77.0	-2.7	78.4	-6.8	80.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	50.0	34.0	34.0	42.1	49.2	55.6	63.8	67.2	66.2	58.9	50.9	41.2	35.4
	DBStd	13.55	6.81	8.19	6.18	6.57	6.45	6.15	5.61	5.76	5.43	6.36	6.02	6.06
	HDD50	2103	497	448	250	93	22	0	0	0	1	69	270	453
	HDD65	5764	961	867	710	473	297	94	42	57	195	437	714	917
	CDD50	2094	1	0	5	70	194	415	533	503	268	98	7	0
	CDD65	280	0	0	0	0	5	59	110	95	11	0	0	0
	CDH74	2656	0	0	0	9	72	590	1047	828	110	0	0	0
	CDH80	770	0	0	0	0	6	175	343	241	5	0	0	0
Wind	WSAvg	4.3	5.2	4.6	5.1	4.3	4.7	4.4	4.2	3.4	3.7	3.4	3.9	4.7
Precipitation	PrecAvg	54.9	3.4	3.4	3.7	4.3	5.9	5.9	6.1	5.8	4.3	4.0	4.0	4.1
	PrecMax	68.6	8.2	8.6	10.0	8.6	9.4	9.1	11.9	11.7	8.0	7.0	8.1	8.9
	PrecMin	42.0	0.4	1.3	1.4	1.0	1.9	2.8	2.1	1.2	2.1	0.2	0.1	0.0
	PrecStd	7.1	2.1	1.9	2.0	2.0	2.2	1.6	2.4	2.5	1.7	1.6	2.0	2.2
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	53.1	59.4	65.5	75.0	80.4	89.6	92.1	89.8	80.7	71.0	62.1	52.8
		MCWB	49.3	48.5	51.7	58.5	64.5	71.8	69.9	69.1	65.9	60.0	55.6	49.9
	2%	DB	49.7	53.3	62.3	70.9	75.6	84.9	87.7	85.7	77.6	67.3	57.9	50.2
		MCWB	45.9	47.1	50.3	56.0	61.5	68.9	67.8	69.0	64.8	58.8	53.0	47.7
	5%	DB	45.4	48.6	58.4	67.8	72.5	80.9	84.0	82.5	73.6	64.1	53.6	47.5
		MCWB	42.9	44.1	49.0	55.1	59.8	67.2	66.8	67.9	63.1	58.0	50.8	45.7
	10%	DB	42.8	44.6	54.2	63.4	68.9	76.6	79.8	78.9	69.8	60.6	49.9	44.5
		MCWB	40.9	40.9	46.8	53.0	57.7	65.0	65.5	66.9	61.8	56.5	47.8	43.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	50.3	50.1	53.3	59.5	65.4	73.4	72.1	72.5	67.8	62.0	56.7	50.4
		MCDB	53.3	57.1	62.5	72.1	76.4	86.2	87.7	83.5	77.2	66.8	60.9	51.7
	2%	WB	46.9	46.7	51.0	57.3	63.7	71.0	69.6	70.5	65.9	60.2	53.8	47.9
		MCDB	49.1	52.8	59.8	67.7	72.5	81.8	82.9	81.6	73.8	64.9	56.7	49.3
	5%	WB	43.1	44.3	49.3	55.3	61.2	68.5	68.1	68.9	64.2	58.6	51.0	45.9
		MCDB	44.9	48.7	57.3	65.6	68.3	78.4	79.7	79.8	71.7	62.5	53.7	47.5
	10%	WB	41.1	41.4	47.5	53.1	58.9	66.5	66.6	67.5	62.5	57.1	48.1	43.3
		MCDB	42.7	44.2	53.5	61.0	66.2	74.8	77.2	77.3	68.1	60.1	49.4	44.4
Mean Daily Temperature Range	5% DB	MDBR	10.2	12.8	17.4	19.3	18.1	17.8	19.5	19.3	17.4	14.5	10.7	10.3
		MCDBR	14.1	21.5	25.9	28.2	24.8	25.7	26.6	24.7	23.1	20.2	17.6	13.7
		MCWBR	10.8	14.1	15.1	14.8	11.5	11.3	9.9	10.1	11.2	12.6	13.0	11.2
	5% WB	MCDBR	13.2	20.8	23.9	26.3	21.2	22.4	23.1	22.9	20.3	17.7	16.3	13.1
		MCWBR	10.5	14.3	14.3	13.9	11.0	10.6	9.5	10.3	10.6	11.9	12.5	11.2
Clear-Sky Solar Irradiance	taub	0.289	0.315	0.353	0.387	0.400	0.404	0.406	0.397	0.373	0.349	0.314	0.286	
	taud	2.425	2.358	2.316	2.266	2.276	2.308	2.297	2.336	2.386	2.435	2.470	2.439	
	Ebn at Noon	255	270	274	274	274	273	271	269	265	254	243	242	
	Edh at Noon	21	28	34	40	41	40	40	37	32	26	21	19	
All-Sky Solar Radiation	RadAvg	390	662	1044	1383	1579	1846	1791	1559	1188	756	422	319	
	RadStd	47	94	151	205	154	171	160	150	115	78	54	52	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (121 neighbors)	N/A	N/A	N/A	+1.33	+0.77	+0.59	N/A	N/A	+103	+27

Nomenclature: See separate page