

EGOLZWIL, Switzerland

WMO: 066480

Lat: 47.1794N

Lon: 8.0047E

Elev: 522

StdP: 95.21

Time Zone: 1.00 (EUC)

Period: 11-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-9.6	-6.7	-13.3	1.3	-10.4	-8.6	1.9	-6.0	11.9	8.4	10.2	6.7	3.1	50	0.493

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.8	30.6	20.4	28.7	19.8	26.8	19.1	21.6	28.1	20.6	26.8	19.8	25.4	2.9	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.6	15.3	24.0	18.6	14.3	22.8	17.8	13.6	21.9	65.2	28.6	61.5	27.1	58.7	25.6	25.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.8	8.1	6.5	-12.6	33.1	3.7	1.4	-15.2	34.1	-17.4	34.9	-19.4	35.7	-22.1	36.7		
(5)			-13.5	23.2	3.1	1.4	-15.8	24.2	-17.6	25.0	-19.3	25.8	-21.5	26.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	10.0	1.1	1.1	5.6	9.6	13.1	17.7	19.6	19.0	14.9	10.5	5.1	1.9
	DBStd	7.53	3.78	4.55	3.43	3.65	3.58	3.42	3.12	3.20	3.02	3.53	3.34	3.37
	HDD10.0	1168	276	249	139	52	12	0	0	0	1	38	150	252
	HDD18.3	3202	534	482	394	263	165	52	23	32	108	243	397	509
	CDD10.0	1163	1	0	3	39	108	231	296	279	149	54	4	0
	CDD18.3	156	0	0	0	0	3	33	61	53	6	0	0	0
	CDH23.3	1476	0	0	0	5	40	328	582	460	61	0	0	0
	CDH26.7	428	0	0	0	0	3	97	191	134	3	0	0	0
(14) Wind	WSAvg	1.9	2.3	2.1	2.3	1.9	2.1	2.0	1.9	1.5	1.7	1.5	1.7	2.1
(15) Precipitation	PrecAvg	1394	86	87	95	108	149	151	156	147	109	101	101	105
	PrecMax	1743	208	219	254	219	238	232	303	296	204	179	206	225
	PrecMin	1068	11	32	36	26	49	71	54	31	54	6	2	0
	PrecStd	180	53	49	51	50	56	41	60	63	42	41	51	57
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.7	15.2	18.6	23.9	26.9	32.0	33.4	32.1	27.1	21.7	16.7	11.6
		MCWB	9.6	9.2	11.0	14.7	18.1	22.1	21.1	20.6	18.8	15.5	13.1	9.9
	2%	DB	9.8	11.8	16.8	21.6	24.2	29.4	30.9	29.8	25.4	19.6	14.4	10.1
		MCWB	7.7	8.4	10.2	13.3	16.4	20.5	19.9	20.5	18.2	14.9	11.7	8.7
	5%	DB	7.5	9.2	14.7	19.9	22.5	27.2	28.9	28.0	23.1	17.8	12.0	8.6
		MCWB	6.0	6.7	9.4	12.9	15.4	19.6	19.3	20.0	17.3	14.5	10.4	7.6
	10%	DB	6.0	7.0	12.3	17.5	20.5	24.8	26.5	26.0	21.0	15.9	9.9	7.0
		MCWB	4.9	5.0	8.2	11.7	14.3	18.3	18.6	19.4	16.6	13.6	8.8	6.1
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.2	10.0	11.8	15.3	18.6	23.0	22.3	22.5	19.9	16.7	13.7	10.2
		MCDB	11.8	14.0	17.0	22.3	24.7	30.1	30.9	28.6	25.1	19.3	16.1	11.0
	2%	WB	8.3	8.2	10.6	14.0	17.6	21.7	20.9	21.4	18.8	15.7	12.1	8.8
		MCDB	9.5	11.5	15.5	19.9	22.5	27.6	28.3	27.6	23.2	18.3	13.7	9.6
	5%	WB	6.2	6.8	9.6	13.0	16.2	20.3	20.1	20.5	17.9	14.8	10.6	7.7
		MCDB	7.2	9.3	14.1	18.7	20.2	25.8	26.5	26.6	22.1	16.9	12.0	8.6
	10%	WB	5.1	5.2	8.6	11.7	15.0	19.2	19.2	19.7	16.9	13.9	9.0	6.3
		MCDB	6.0	6.8	12.0	16.1	19.0	23.8	25.1	25.2	20.0	15.6	9.7	6.9
(35) Mean Daily Temperature Range	5% DB	MDBR	5.7	7.1	9.7	10.7	10.0	9.9	10.8	10.7	9.7	8.1	5.9	5.7
		MCDBR	7.8	11.9	14.4	15.7	13.8	14.3	14.8	13.7	12.8	11.2	9.8	7.6
	5% WB	MCWBR	6.0	7.8	8.4	8.2	6.4	6.3	5.5	5.6	6.2	7.0	7.2	6.2
		MCDWR	7.3	11.5	13.3	14.6	11.8	12.5	12.8	12.7	11.3	9.8	9.0	7.3
(40) Clear-Sky Solar Irradiance	taub		0.289	0.315	0.353	0.387	0.400	0.404	0.406	0.397	0.373	0.349	0.314	0.286
		taud	2.425	2.358	2.316	2.266	2.276	2.308	2.297	2.336	2.386	2.435	2.470	2.439
	Ebn at Noon		804	850	865	865	864	861	854	847	835	800	765	763
		Edh at Noon	67	89	108	125	129	126	125	116	100	82	65	59
(44) All-Sky Solar Radiation	RadAvg		1.23	2.09	3.29	4.36	4.98	5.82	5.65	4.91	3.75	2.38	1.33	1.01
	RadStd		0.15	0.29	0.47	0.65	0.49	0.54	0.50	0.47	0.36	0.25	0.17	0.16

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (121 neighbors)	N/A	N/A	N/A	+0.74	+0.43	+0.33	N/A	N/A	+57	+15

Nomenclature: See separate page