

GISWIL, Switzerland

WMO: 066570

Lat: 46.849N

Lon: 8.190E

Elev: 475

StdP: 95.75

Time Zone: 1.00 (EUC)

Period: 11-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-8.7	-6.4	-12.1	1.4	-8.5	-8.6	1.9	-5.0	8.2	9.2	6.8	8.2	1.7	80	0.462

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.3	30.2	20.7	28.3	20.1	26.4	19.1	21.7	28.3	20.7	26.7	19.9	25.3	1.6	40

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.6	15.2	24.2	18.6	14.3	23.0	17.9	13.6	22.1	65.4	28.6	61.9	26.8	58.8	25.5	25.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 6.5	4.8	3.4	-12.8	33.3	2.7	1.3	-14.7	34.2	-16.3	35.0	-17.9	35.7	-19.9	36.6		
(5)			-13.3	23.7	2.8	1.0	-15.3	24.4	-16.9	25.0	-18.5	25.6	-20.5	26.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	9.9	1.2	1.0	5.3	9.4	13.0	17.5	19.2	18.8	14.9	10.4	5.1	1.7		
	DBStd	7.38	3.77	4.03	3.11	3.38	3.32	3.21	2.88	2.83	2.81	3.19	3.47	3.60		
	HDD10.0	1174	273	251	147	50	10	0	0	0	1	34	151	257		
	HDD18.3	3223	531	484	403	268	167	53	24	29	108	246	396	514		
	CDD10.0	1122	1	0	2	32	104	226	285	273	147	47	5	1		
	CDD18.3	130	0	0	0	0	2	29	51	44	4	0	0	0		
	CDH23.3	1332	0	0	0	10	50	331	491	402	46	1	0	0		
	CDH26.7	364	0	0	0	0	4	99	152	107	2	0	0	0		
(14) Wind	WSAvg	1.1	1.3	1.1	1.2	1.3	1.2	1.1	1.1	1.0	0.9	0.9	1.0	1.2		
(15) Precipitation	PrecAvg	1561	95	99	105	118	166	171	178	172	123	106	112	115		
	PrecMax	1951	240	284	238	234	277	270	342	393	240	182	262	273		
	PrecMin	1208	7	32	43	33	39	91	71	41	54	5	1	5		
	PrecStd	187	58	63	50	49	65	42	67	71	43	43	58	63		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	15.8	15.0	18.8	24.8	27.0	32.6	33.0	31.7	26.7	22.1	20.4	14.8		
		MCWB	10.0	8.8	10.7	13.6	17.1	21.9	22.2	21.1	19.1	15.2	10.1	8.1		
	2%	DB	11.2	11.7	16.8	22.3	24.7	29.5	30.3	29.5	24.8	19.4	15.2	11.3		
		MCWB	7.6	6.9	9.7	13.0	16.7	20.7	20.6	20.8	18.4	14.3	10.8	8.1		
	5%	DB	8.2	9.0	14.8	20.4	22.9	27.0	28.2	27.5	22.7	17.4	12.1	9.1		
		MCWB	5.9	5.5	9.2	12.5	15.1	19.4	20.0	20.2	17.2	13.5	9.8	6.9		
	10%	DB	6.4	6.6	12.3	17.7	20.6	24.8	26.0	25.5	20.7	15.6	10.0	7.0		
		MCWB	4.8	4.5	7.8	11.3	14.4	18.1	19.0	19.3	16.3	13.1	8.5	5.5		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.2	9.8	11.8	15.0	18.7	22.9	23.1	22.6	19.8	16.1	12.1	9.7		
		MCDB	14.8	13.4	17.2	22.9	26.0	30.4	31.3	28.4	24.6	19.3	15.3	12.8		
	2%	WB	7.7	7.4	10.4	13.8	17.3	21.3	21.5	21.5	18.9	15.0	11.0	8.3		
		MCDB	9.9	11.2	15.8	20.4	22.7	27.9	28.6	27.6	23.9	17.4	14.2	10.8		
	5%	WB	6.3	5.9	9.3	12.6	16.0	20.1	20.5	20.6	17.8	14.2	9.9	6.9		
		MCDB	8.0	8.5	13.7	19.0	20.8	26.3	26.6	26.3	21.5	16.3	12.6	8.8		
	10%	WB	5.1	4.6	8.2	11.6	14.9	18.9	19.6	19.8	16.9	13.5	8.8	5.6		
		MCDB	6.1	6.6	12.0	16.8	19.3	23.7	25.0	24.7	20.0	15.3	10.1	6.9		
(35) Mean Daily Temperature Range	5% DB	MDBR	6.6	8.2	11.4	12.6	11.2	11.2	11.3	11.4	10.2	9.1	7.2	6.9		
		MCDBR	9.9	13.6	16.6	18.4	16.1	16.0	16.0	15.0	13.5	12.7	11.1	9.5		
		MCWBR	6.9	8.7	10.2	9.7	8.2	8.0	7.5	7.4	7.5	7.9	6.9	6.3		
	5% WB	MCDBR	9.6	12.5	15.7	16.6	14.2	14.8	14.1	14.0	12.3	10.8	10.7	9.0		
		MCWBR	7.0	8.3	9.8	9.3	7.7	7.7	7.0	7.2	7.0	7.1	6.9	6.5		
(40) Clear-Sky Solar Irradiance	taub		0.294	0.328	0.382	0.432	0.452	0.457	0.458	0.443	0.408	0.373	0.327	0.291		
	taud		2.313	2.213	2.123	2.067	2.087	2.139	2.140	2.193	2.266	2.326	2.365	2.336		
	Ebn at Noon		789	826	828	820	817	814	807	802	796	767	740	747		
	Edh at Noon		75	103	132	153	156	149	147	134	114	92	72	66		
(44) All-Sky Solar Radiation	RadAvg		1.39	2.30	3.49	4.40	4.90	5.74	5.64	4.91	3.79	2.46	1.43	1.15		
	RadStd		0.17	0.30	0.50	0.67	0.48	0.53	0.50	0.46	0.37	0.27	0.20	0.17		

Historical Trends

		Heating		Cooling		Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46) Station Only	DBAvg	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(47) Regional (121 neighbors)		N/A	N/A	N/A	+0.72	+0.40	+0.31	N/A	N/A	+57

Nomenclature: See separate page