

AADORF-TAENIKON, Switzerland

WMO: 066790

Lat: 47.4800N

Lon: 8.9050E

Elev: 1770

StdP: 13.78

Time Zone: 1.00 (EUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	12.7	17.3	7.7	8.7	13.4	13.0	11.4	18.8	19.4	45.6	17.1	45.3	3.5	60	0.483

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.5	86.3	67.8	82.8	66.6	79.4	65.4	69.4	82.0	67.8	79.7	66.3	77.1	4.7	50

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
65.0	98.8	75.4	63.5	93.7	73.3	62.2	89.2	71.3	34.5	82.2	33.1	80.1	31.9	77.2	76.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 15.8	12.4	10.5	5.5	91.6	5.8	4.1	1.3	94.5	-2.1	96.9	-5.3	99.2	-9.5	102.2		
(5)			4.8	72.8	5.7	1.5	0.8	73.9	-2.5	74.8	-5.7	75.7	-9.8	76.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	49.0	32.8	33.3	40.8	48.5	55.7	63.2	65.8	64.9	57.4	49.8	40.2	34.0		
	DBStd	13.84	8.30	8.61	7.41	6.54	6.84	6.38	5.50	5.64	5.88	6.79	6.82	7.43		
	HDD50	2310	533	467	292	105	21	1	0	0	9	87	300	495		
	HDD65	6077	997	887	750	496	297	108	58	74	236	470	744	960		
	CDD50	1936	1	1	7	59	199	398	491	461	230	82	7	0		
	CDD65	227	0	0	0	0	10	56	84	70	7	0	0	0		
	CDH74	2290	0	0	0	10	159	584	835	632	70	0	0	0		
	CDH80	633	0	0	0	1	44	153	245	187	3	0	0	0		
	WSAvg	3.6	4.2	4.2	4.3	3.7	3.9	3.4	3.3	3.1	2.9	2.9	3.5	4.1		
	PrecAvg	52.5	3.1	3.2	3.5	3.8	5.7	5.9	5.9	5.8	4.3	3.6	3.8	3.9		
(15) Precipitation	PrecMax	66.7	7.5	8.3	9.5	7.6	11.5	9.6	11.1	10.2	9.0	6.8	8.4	8.6		
	PrecMin	41.4	0.2	1.0	1.0	0.5	1.3	2.4	2.3	0.8	2.0	0.1	0.0	0.0		
	PrecStd	6.6	1.9	1.7	1.9	1.9	2.5	1.8	2.4	2.3	1.8	1.7	2.1	2.1		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	54.6	57.5	66.2	74.8	85.0	88.9	90.6	90.4	79.6	70.8	61.7	53.7		
		MCWB	47.3	46.8	51.5	56.9	63.3	69.3	68.3	67.5	65.1	59.8	52.9	47.1		
	2%	DB	51.1	52.6	61.4	70.5	77.9	84.3	86.2	85.1	76.1	66.9	57.1	50.6		
		MCWB	45.6	44.5	49.2	55.1	61.8	67.6	67.6	67.8	63.9	58.3	50.9	46.1		
	5%	DB	48.1	49.0	57.5	66.6	73.6	80.8	82.3	80.9	72.0	63.5	53.5	47.8		
		MCWB	43.2	42.9	47.7	53.6	59.2	65.8	66.5	66.7	62.1	56.6	48.9	44.0		
	10%	DB	44.7	45.4	53.5	62.5	69.3	76.8	78.7	76.8	68.2	60.3	50.4	45.0		
		MCWB	41.1	40.8	45.8	51.7	57.7	64.3	65.1	65.4	60.4	55.3	46.8	41.8		
	0.4%	WB	49.2	47.7	52.8	58.3	65.6	72.2	71.4	71.1	67.2	61.8	53.9	48.8		
		MCDB	53.4	55.4	62.7	72.0	78.9	85.4	85.5	83.5	76.4	68.1	59.3	51.5		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	46.1	45.3	50.4	56.2	63.0	68.9	69.2	69.0	65.0	59.3	51.6	46.5		
		MCDB	50.1	51.4	58.6	68.5	75.2	81.0	82.2	81.2	73.4	65.0	56.2	50.0		
	5%	WB	43.5	43.2	48.5	54.1	60.8	66.9	67.5	67.4	62.9	57.4	49.4	44.5		
		MCDB	47.6	48.5	56.0	65.1	71.1	78.1	79.6	78.8	70.6	62.2	53.1	47.7		
	10%	WB	41.1	40.9	46.5	52.1	58.5	65.0	65.9	65.8	61.0	55.6	47.1	42.1		
		MCDB	44.6	45.4	53.0	61.0	67.5	75.4	76.8	75.5	67.1	59.6	49.9	44.8		
(35) Mean Daily Temperature Range	5% DB	MDBR	10.1	13.1	17.3	20.3	19.0	19.2	19.5	18.7	17.1	14.5	11.0	9.8		
		MCDBR	13.7	19.6	25.5	29.4	27.9	26.6	27.2	26.3	23.2	20.0	16.6	13.2		
		MCWBR	9.4	12.7	15.3	15.9	13.9	12.3	11.7	11.8	12.7	12.4	11.2	9.6		
		MCDBR	12.7	18.2	22.7	26.9	24.0	24.3	24.5	24.0	21.2	18.6	15.3	12.0		
	5% WB	MCWBR	9.3	12.3	14.0	14.8	12.5	11.7	11.2	11.3	12.0	12.3	10.8	9.3		
(40) Clear-Sky Solar Irradiance	taub		0.288	0.312	0.347	0.383	0.396	0.402	0.404	0.396	0.370	0.342	0.311	0.283		
	taud		2.455	2.390	2.359	2.289	2.291	2.314	2.302	2.338	2.393	2.461	2.495	2.461		
	Ebn at Noon		255	271	276	276	275	274	271	268	265	256	244	243		
	Edh at Noon		21	27	33	39	40	40	40	36	31	25	20	18		
(44) All-Sky Solar Radiation	RadAvg		363	628	1012	1372	1585	1817	1754	1532	1147	719	399	298		
	RadStd		39	85	135	196	159	169	161	159	118	78	48	46		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
	N/A	N/A	N/A	N/A	N/A	+0.88	N/A	N/A	N/A	N/A
Regional (117 neighbors)	N/A	N/A	N/A	+1.28	+0.76	+0.61	N/A	N/A	+103	+29

Nomenclature: See separate page