

GENEVA COINTRIN, Switzerland

WMO: 067000

Lat: 46.2475N

Lon: 6.1278E

Elev: 430

StdP: 96.26

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-5.9	-4.1	-10.4	1.6	-3.5	-8.7	1.9	-2.4	11.7	1.0	9.7	3.6	2.8	260	0.475

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.2	31.4	19.8	29.5	19.2	27.7	18.6	20.7	28.7	20.0	27.4	19.2	26.0	3.6	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.2	13.8	22.9	17.5	13.2	22.4	16.8	12.6	21.9	61.4	28.8	58.9	27.5	56.4	26.1	24.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9.1	7.8	6.6	-8.3	34.2	2.2	2.0	-9.9	35.6	-11.2	36.8	-12.4	38.0	-14.0	39.5
			-9.1	22.1	2.2	0.7	-10.6	22.6	-11.9	23.0	-13.1	23.4	-14.7	23.9
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	11.2	2.2	3.2	7.0	10.6	14.8	18.7	20.7	20.1	16.0	11.8	6.2	2.9
	DBStd	7.40	3.45	3.56	3.47	3.43	3.28	3.58	3.18	3.10	3.18	3.30	3.41	3.45
	HDD10.0	937	243	191	104	33	3	0	0	0	1	21	121	220
	HDD18.3	2824	501	424	352	231	117	38	13	17	84	203	365	478
	CDD10.0	1385	1	0	11	52	151	262	332	314	179	76	6	1
	CDD18.3	232	0	0	0	0	7	51	88	73	13	0	0	0
	CDH23.3	2016	0	0	0	7	83	459	773	606	85	2	0	0
	CDH26.7	614	0	0	0	0	13	134	258	199	9	0	0	0
Wind	WSAvg	2.3	2.3	2.5	2.7	2.6	2.3	2.3	2.1	1.9	2.1	1.9	2.2	2.4
Precipitation	PrecAvg	937	77	70	69	65	77	84	75	82	88	83	92	82
	PrecMax	1376	199	190	282	146	191	196	176	247	272	213	295	199
	PrecMin	550	8	1	5	2	5	2	9	5	6	2	6	0
	PrecStd	174	45	46	49	39	36	43	41	48	65	50	56	46
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.5	15.0	19.9	24.3	28.4	32.6	34.1	34.1	28.1	23.0	16.9	13.1
		MCWB	9.0	8.6	11.4	14.1	17.5	20.4	20.2	20.1	18.4	15.6	12.0	9.7
	2%	DB	10.7	12.4	17.2	21.6	25.6	30.1	31.6	31.0	25.9	20.4	14.5	11.0
		MCWB	7.9	7.9	10.1	12.8	16.3	19.4	19.6	19.6	17.8	14.9	11.0	8.5
	5%	DB	9.0	10.5	15.1	19.6	23.4	28.1	29.6	28.9	23.8	18.5	12.6	9.6
		MCWB	6.7	6.9	9.3	11.8	15.3	18.7	19.2	19.2	16.8	14.3	10.1	7.5
	10%	DB	7.5	8.8	13.3	17.5	21.5	26.0	27.5	26.8	21.8	17.0	11.1	8.1
		MCWB	5.6	5.9	8.5	11.0	14.4	17.9	18.6	18.6	16.1	13.5	9.1	6.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.9	9.6	12.1	14.7	18.6	21.9	21.5	21.5	19.7	16.7	12.7	10.2
		MCDB	12.1	13.3	17.6	22.3	26.3	30.1	31.0	29.8	25.9	20.8	15.3	12.1
	2%	WB	8.2	8.3	10.8	13.4	17.1	20.3	20.6	20.6	18.5	15.8	11.5	8.9
		MCDB	10.1	11.7	15.5	20.1	23.6	27.8	28.9	28.3	23.9	19.0	13.7	10.5
	5%	WB	7.0	7.3	9.9	12.3	16.1	19.4	19.8	19.8	17.5	14.9	10.4	7.7
		MCDB	8.9	10.1	14.3	18.3	21.8	26.2	27.4	26.9	22.4	17.9	12.3	9.3
	10%	WB	5.7	6.1	8.9	11.4	15.1	18.5	19.1	19.0	16.7	14.0	9.4	6.5
		MCDB	7.3	8.5	12.9	16.7	20.0	24.7	26.0	25.4	20.9	16.5	11.0	8.0
Mean Daily Temperature Range	5% DB	MDBR	5.4	7.3	9.4	10.0	10.1	10.8	11.2	11.0	9.6	7.9	6.2	5.3
		MCDBR	7.8	10.9	13.0	14.1	14.1	14.1	14.6	14.6	12.5	10.3	8.5	7.4
		MCWBR	5.5	7.0	7.2	6.6	6.3	5.5	5.0	5.3	5.5	5.7	5.5	5.3
	5% WB	MCDBR	7.4	9.6	11.6	12.8	12.3	12.9	12.9	13.1	10.9	9.3	7.7	6.5
MCWBR		5.4	6.5	6.7	6.2	5.8	5.3	4.8	5.2	5.0	5.2	5.3	4.9	
Clear-Sky Solar Irradiance	taub	0.292	0.315	0.351	0.388	0.397	0.397	0.394	0.386	0.368	0.351	0.318	0.290	
	taud	2.449	2.397	2.359	2.285	2.305	2.341	2.343	2.376	2.410	2.451	2.488	2.468	
	Ebn at Noon	815	860	873	868	870	869	867	860	845	807	774	774	
	Edh at Noon	68	87	105	124	126	122	120	112	99	83	66	60	
All-Sky Solar Radiation	RadAvg	1.35	2.21	3.38	4.42	5.09	6.05	5.95	5.17	4.02	2.57	1.44	1.11	
	RadStd	0.16	0.31	0.46	0.60	0.47	0.53	0.50	0.42	0.33	0.26	0.18	0.17	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	+0.45	+0.36	N/A	N/A	N/A	N/A
(47) Regional (74 neighbors)		N/A	N/A	N/A	N/A	+0.34	+0.23	N/A	N/A	N/A	N/A

Nomenclature: See separate page