

LA DOLE, Switzerland

WMO: 067020

Lat: 46.4247N

Lon: 6.0994E

Elev: 1670

StdP: 82.80

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-13.3	-11.4	-24.4	0.5	-1.9	-20.6	0.7	-2.5	23.7	-2.5	22.2	-4.9	10.3	80	0.921

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	6.0	21.4	14.8	19.9	14.1	18.4	13.5	16.0	19.8	15.0	18.6	14.0	17.3	5.1	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
14.5	12.7	18.0	13.5	11.9	16.9	12.6	11.1	15.8	51.3	19.8	48.0	18.6	45.0	17.4	20.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 20.3	18.0	15.5	DB	-14.7	23.5	2.9	2.1	-16.8	25.0	-18.4	26.2	-20.0	27.4	-22.1	28.9	(4)
(5)			WB	-15.2	18.0	2.9	1.1	-17.3	18.7	-19.0	19.4	-20.6	20.0	-22.7	20.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	4.5	-2.5	-2.7	-0.4	2.6	6.7	10.4	12.2	12.4	8.8	6.1	0.9	-1.4	(6)	
	DBStd	6.94	4.07	4.84	4.36	4.38	4.17	4.32	3.84	3.95	3.90	4.24	4.66	4.44	(7)	
	HDD10.0	2324	389	357	322	226	119	47	22	20	67	130	273	353	(8)	
	HDD18.3	5069	647	590	580	473	362	239	193	188	285	378	523	612	(9)	
	CDD10.0	304	0	0	0	2	16	60	89	94	32	10	1	0	(10)	
	CDD18.3	8	0	0	0	0	0	2	2	4	0	0	0	0	(11)	
	CDH23.3	16	0	0	0	0	0	4	4	7	0	0	0	0	(12)	
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)	
(14) Wind	WSAvg	7.5	9.0	9.0	8.4	7.0	6.8	6.3	6.3	5.9	6.4	7.1	8.6	9.2	(14)	
(15) Precipitation	PrecAvg	1278	99	92	88	98	107	105	106	112	123	123	123	120	(15)	
	PrecMax	1608	254	263	339	179	181	202	212	242	296	237	331	281	(16)	
	PrecMin	959	15	7	14	28	28	39	45	11	37	15	17	2	(17)	
	PrecStd	174	59	60	67	49	43	47	44	49	69	58	72	62	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	8.5	9.5	10.6	14.8	18.4	23.2	23.5	24.2	19.1	16.2	12.2	9.6	(19)	
		MCWB	0.7	1.5	4.3	8.4	12.4	16.0	15.2	15.0	13.7	10.0	5.8	1.0	(20)	
	2%	DB	6.2	7.2	8.8	12.4	16.2	20.5	21.1	21.4	17.1	14.4	10.0	7.4	(21)	
		MCWB	0.2	1.0	3.7	7.1	11.0	14.5	14.6	14.6	12.7	8.7	4.7	1.1	(22)	
	5%	DB	4.3	5.4	7.1	10.5	14.4	18.6	19.3	19.8	15.6	12.9	8.5	5.8	(23)	
		MCWB	0.3	0.3	2.7	6.0	9.8	13.6	13.9	13.9	11.7	8.0	4.2	0.6	(24)	
	10%	DB	2.8	3.5	5.7	8.7	12.6	16.9	17.8	18.1	14.1	11.5	7.0	4.3	(25)	
		MCWB	-0.1	-0.3	2.0	4.9	8.9	12.7	13.3	13.5	10.8	7.7	3.8	0.7	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	3.8	3.4	5.9	9.2	13.3	17.6	17.1	17.2	15.2	11.4	7.7	4.5	(27)	
		MCDB	4.5	5.9	8.9	13.5	17.1	21.7	21.0	21.4	17.8	14.1	9.8	5.6	(28)	
	2%	WB	2.6	2.3	4.6	7.6	11.7	15.5	15.7	15.8	13.4	10.3	6.3	3.3	(29)	
		MCDB	3.7	4.3	7.0	11.4	15.2	19.3	19.5	19.7	16.0	12.3	8.1	4.4	(30)	
	5%	WB	1.5	1.3	3.6	6.4	10.5	14.2	14.7	14.7	12.3	9.4	5.4	2.5	(31)	
		MCDB	2.8	3.6	6.0	9.7	13.6	17.6	18.2	18.3	14.8	11.5	7.2	3.7	(32)	
	10%	WB	0.5	0.5	2.6	5.3	9.3	13.0	13.7	13.8	11.3	8.5	4.4	1.6	(33)	
		MCDB	2.0	2.9	5.0	8.1	12.0	16.1	17.0	17.2	13.5	10.6	6.3	3.1	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	4.2	4.6	4.9	5.5	5.9	6.3	6.4	6.0	5.5	5.1	4.4	4.5	(35)	
		MCDBR	5.5	6.1	6.2	7.5	7.5	7.7	7.7	7.1	6.8	6.1	5.6	5.8	(36)	
	5% WB	MCWBR	3.4	3.9	4.4	5.1	5.6	6.3	5.7	5.7	5.8	4.7	4.2	3.5	(37)	
		MCWBR	4.5	5.1	5.8	7.2	7.2	7.5	7.3	6.9	6.4	5.4	5.0	4.5	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.245	0.262	0.287	0.313	0.321	0.323	0.321	0.316	0.302	0.290	0.265	0.244	(40)	
		taud	2.528	2.509	2.507	2.454	2.465	2.483	2.477	2.504	2.531	2.565	2.579	2.540	(41)	
	Edn at Noon	Edn at Noon	889	935	950	946	945	941	937	932	921	887	854	851	(42)	
		Edh at Noon	61	77	90	104	107	106	105	98	87	72	58	54	(43)	
(44) All-Sky Solar Radiation	RadAvg	RadAvg	1.30	2.16	3.35	4.42	5.09	6.03	5.89	5.12	3.99	2.54	1.41	1.06	(44)	
	RadStd	RadStd	0.15	0.32	0.46	0.62	0.47	0.55	0.50	0.43	0.33	0.25	0.17	0.17	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (75 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page