

NYON-CHANGINS, Switzerland

WMO: 067050

Lat: 46.4011N

Lon: 6.2278E

Elev: 1417

StdP: 13.96

Time Zone: 1.00 (EUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	20.9	24.2	10.9	10.1	23.9	15.0	12.4	26.5	27.5	29.5	23.2	35.7	9.0	340	0.475

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.4	86.8	67.5	83.3	66.7	80.2	65.6	69.3	82.6	68.0	80.3	66.6	78.1	6.7	150

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
64.8	96.7	75.2	63.5	92.3	73.8	62.2	88.2	72.4	34.2	83.0	33.0	80.7	32.0	78.2	75.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 22.9	19.0	15.8	DB	16.5	91.6	4.1	3.9	13.5	94.4	11.1	96.6	8.9	98.8	5.9	101.6	(4)
(5)			WB	14.5	72.2	4.2	1.6	11.4	73.4	9.0	74.3	6.7	75.3	3.6	76.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	51.7	35.7	36.8	43.9	51.3	57.2	65.7	68.8	67.4	60.5	52.9	43.1	36.7
	DBStd	13.30	6.51	6.65	6.49	6.23	6.03	6.17	5.63	5.71	5.43	5.92	5.83	6.16
	HDD50	1759	445	370	204	58	9	0	0	0	2	42	217	412
	HDD65	5209	910	789	653	411	250	67	27	39	152	376	658	877
	CDD50	2395	1	0	16	97	232	470	582	540	317	131	9	0
	CDD65	372	0	0	0	0	9	87	145	113	18	0	0	0
	CDH74	2767	0	0	0	3	73	675	1110	816	89	1	0	0
	CDH80	736	0	0	0	0	7	169	321	234	5	0	0	0
Wind	WSAvg	5.7	5.7	6.3	6.9	6.2	5.8	5.6	5.3	4.9	5.4	4.8	5.5	5.8
Precipitation	PrecAvg	50.3	3.9	3.6	3.5	3.9	4.2	4.1	4.2	4.2	4.4	4.8	4.8	4.7
	PrecMax	63.3	10.0	10.4	13.3	7.0	7.1	8.0	8.3	9.5	11.7	9.3	13.0	11.1
	PrecMin	37.8	0.6	0.3	0.6	1.1	1.1	1.5	1.8	0.4	1.5	0.6	0.7	0.1
	PrecStd	6.9	2.3	2.4	2.6	1.9	1.7	1.9	1.7	1.9	2.7	2.3	2.8	2.4
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	53.6	56.7	64.6	73.7	80.2	88.9	91.3	92.4	80.5	71.7	60.5	54.1
		MCWB	47.7	47.6	51.1	57.3	63.5	68.7	68.0	67.8	64.2	59.7	52.7	48.6
	2%	DB	50.5	51.7	60.7	69.5	75.7	84.8	87.0	85.6	76.7	67.2	56.8	50.0
		MCWB	46.1	44.5	49.1	55.2	61.3	67.7	67.1	67.4	63.9	58.4	51.2	46.7
	5%	DB	47.7	48.5	57.5	66.5	72.1	81.1	83.4	81.8	73.3	64.0	53.9	47.8
		MCWB	44.3	43.1	48.0	53.7	59.5	66.3	66.3	66.9	62.0	57.5	50.2	44.7
	10%	DB	45.0	45.8	54.4	63.1	68.7	77.8	80.1	78.2	70.1	61.4	51.4	45.4
		MCWB	42.0	41.5	46.5	52.2	57.7	64.5	65.2	65.3	60.8	56.1	48.1	42.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	49.5	48.3	52.7	58.8	65.5	71.8	70.6	70.8	67.4	61.6	54.1	49.5
		MCDB	52.3	54.4	60.8	70.8	76.8	85.1	85.6	84.3	76.7	68.1	58.0	52.0
	2%	WB	46.7	45.9	50.8	56.4	62.9	69.2	68.9	69.0	65.1	60.0	52.2	47.2
		MCDB	49.8	51.2	58.2	67.8	73.2	81.7	82.5	82.1	73.7	64.9	55.8	49.6
	5%	WB	44.5	43.8	49.1	54.5	60.7	67.2	67.6	67.5	63.4	58.4	50.5	45.2
		MCDB	47.6	47.9	55.9	64.8	69.8	78.7	80.3	79.5	71.2	62.8	53.4	47.6
	10%	WB	42.3	41.7	47.3	52.7	58.6	65.4	66.3	66.1	61.7	56.7	48.5	43.1
		MCDB	45.0	45.6	53.7	62.0	67.0	76.2	77.9	77.1	68.8	60.9	51.2	45.3
Mean Daily Temperature Range	5% DB	MDBR	8.6	10.8	14.1	16.6	16.6	18.0	18.4	17.6	15.4	12.5	9.6	8.2
		MCDBR	12.0	15.4	19.8	22.4	22.3	22.9	23.6	22.9	20.1	16.3	12.9	11.1
		MCWBR	8.6	10.4	11.4	12.0	11.8	10.7	9.7	10.0	10.2	9.8	9.0	8.6
	5% WB	MCDBR	11.6	14.1	17.5	20.8	20.4	21.5	21.2	21.2	17.3	14.7	11.7	10.0
		MCWBR	8.5	10.1	10.5	11.6	11.3	10.6	9.4	9.7	9.3	9.1	8.6	8.1
Clear-Sky Solar Irradiance	taub	0.292	0.316	0.352	0.389	0.398	0.399	0.396	0.388	0.369	0.352	0.318	0.291	
	taud	2.449	2.398	2.360	2.284	2.304	2.340	2.340	2.373	2.409	2.449	2.488	2.468	
	Ebn at Noon	258	272	276	275	276	275	274	272	267	255	245	245	
	Edh at Noon	22	28	33	39	40	39	38	36	31	26	21	19	
All-Sky Solar Radiation	RadAvg	425	699	1068	1397	1604	1903	1868	1625	1269	813	455	347	
	RadStd	49	100	148	194	145	174	159	139	106	81	57	54	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (80 neighbors)	N/A	N/A	N/A	N/A	+0.63	+0.45	N/A	N/A	N/A	N/A

Nomenclature: See separate page