

PULLY, Switzerland

WMO: 067110

Lat: 46.5122N

Lon: 6.6675E

Elev: 1516

StdP: 13.91

Time Zone: 1.00 (EUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 22.1	(c) 25.4	(d) 11.9	(e) 10.6	(f) 24.1	(g) 15.7	(h) 12.9	(i) 27.4	(j) 13.4	(k) 40.7	(l) 12.0	(m) 38.0	(n) 7.0	(o) 30	(p) 0.406

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	15.5	85.6	67.8	82.5	66.8	79.8	65.8	69.5	81.5	68.2	79.5	67.0	77.4	3.4	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
65.4	99.2	74.7	64.1	94.9	73.9	62.9	90.9	72.8	34.4	82.1	33.3	79.8	32.3	77.4	75.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 12.1	(b) 10.5	(c) 9.2	(e) 19.5	(f) 90.6	(g) 4.2	(h) 3.0	(i) 16.5	(j) 92.8	(k) 14.0	(l) 94.5	(m) 11.6	(n) 96.2	(o) 8.5	(p) 98.4		
(a) 12.1	(b) 10.5	(c) 9.2	(e) 17.4	(f) 72.2	(g) 3.9	(h) 1.1	(i) 14.6	(j) 73.0	(k) 12.3	(l) 73.6	(m) 10.1	(n) 74.3	(o) 7.2	(p) 75.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	53.0	37.0	37.8	44.9	52.6	58.5	66.8	70.0	68.7	61.6	54.3	44.8	38.4		
	DBStd	13.29	6.35	6.77	6.61	6.77	6.51	6.41	5.74	5.72	5.43	5.93	5.85	5.90		
	HDD50	1551	403	342	183	50	8	0	0	0	1	30	173	361		
	HDD65	4836	867	762	624	373	218	54	19	27	127	333	606	826		
	CDD50	2659	1	1	25	128	271	505	619	579	350	163	17	0		
	CDD65	467	0	0	0	1	17	109	173	141	26	0	0	0		
	CDH74	2559	0	0	0	3	71	613	1055	755	62	0	0	0		
	CDH80	579	0	0	0	0	6	130	263	178	2	0	0	0		
	WSAvg	3.6	3.6	3.8	3.8	3.8	3.7	3.6	3.5	3.4	3.7	3.4	3.5	3.6		
	PrecAvg	44.8	3.3	3.0	2.9	3.4	4.0	3.9	4.1	4.1	3.9	4.1	4.1	3.9		
(15) Precipitation	PrecMax	56.4	8.7	8.1	12.8	6.5	7.5	9.1	8.7	8.6	9.0	7.7	10.9	7.6		
	PrecMin	32.6	0.8	0.3	0.9	0.6	1.3	1.7	1.4	0.8	1.3	0.8	0.4	0.0		
	PrecStd	6.8	2.0	1.9	2.4	1.8	1.8	1.9	1.7	1.8	2.0	2.0	2.4	1.9		
	PrecStd	6.8	2.0	1.9	2.4	1.8	1.8	1.9	1.7	1.8	2.0	2.0	2.4	1.9		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	53.6	55.0	63.7	74.1	79.9	87.4	89.8	90.2	79.2	70.2	60.7	54.2		
		MCWB	48.6	46.6	50.6	57.0	62.9	68.7	68.2	68.2	65.5	60.0	53.5	48.5		
	2%	DB	50.6	51.1	59.8	69.7	75.7	83.7	86.1	84.5	75.7	66.6	57.2	50.4		
		MCWB	46.1	44.8	49.1	55.2	61.2	67.2	67.6	67.9	64.3	58.6	51.5	46.6		
	5%	DB	48.2	48.6	57.0	66.5	72.0	80.6	82.8	81.1	72.8	64.0	54.7	48.3		
		MCWB	44.6	43.4	47.8	53.6	59.3	66.0	66.7	67.0	63.0	57.9	50.7	45.4		
	10%	DB	45.6	46.4	54.2	63.1	69.1	77.4	79.8	78.0	70.0	61.9	52.6	46.4		
		MCWB	42.6	42.0	46.7	52.1	57.7	64.7	65.7	65.8	61.7	56.8	49.2	43.8		
	0.4%	WB	49.4	48.4	52.1	59.1	65.2	71.1	71.0	71.0	67.8	62.0	54.8	49.8		
		MCDB	52.7	52.9	59.4	69.7	76.3	83.3	84.0	82.8	75.8	66.6	58.3	52.7		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	46.9	45.8	50.6	56.4	62.7	68.9	69.2	69.3	65.7	60.5	52.9	47.5		
		MCDB	49.6	50.5	57.2	67.6	72.7	80.3	81.8	81.0	72.8	64.7	56.1	49.5		
	5%	WB	44.9	44.1	49.0	54.4	60.8	67.3	68.0	68.0	64.1	58.9	51.1	45.6		
		MCDB	47.7	47.9	55.4	64.5	69.6	78.2	79.7	78.6	71.2	63.0	54.1	47.8		
	10%	WB	42.7	42.1	47.4	52.8	58.9	65.7	66.7	66.6	62.5	57.4	49.4	43.9		
		MCDB	45.5	45.9	53.5	61.9	67.0	75.7	77.6	76.2	68.9	61.2	52.2	46.2		
(35) Mean Daily Temperature Range	5% DB	MDBR	6.8	8.7	11.5	13.8	14.0	14.8	15.5	14.3	12.6	9.7	7.3	6.4		
		MCDBR	9.3	11.7	15.1	18.1	18.3	18.2	18.9	18.0	15.5	12.1	10.0	8.2		
		MCWBR	6.8	7.9	8.4	9.3	9.0	8.4	8.2	8.2	7.8	7.2	6.6	6.3		
		MCDBR	8.7	10.8	13.5	16.7	16.5	16.9	17.2	16.4	13.9	10.7	9.2	7.7		
	5% WB	MCWBR	6.9	7.7	7.9	8.9	8.7	8.5	8.1	8.2	7.5	6.6	6.5	6.3		
		MCWBR	6.9	7.7	7.9	8.9	8.7	8.5	8.1	8.2	7.5	6.6	6.5	6.3		
(40) Clear-Sky Solar Irradiance	taub		0.289	0.315	0.356	0.395	0.406	0.406	0.404	0.394	0.374	0.353	0.318	0.288		
	taud		2.419	2.361	2.325	2.256	2.273	2.317	2.316	2.355	2.396	2.440	2.476	2.445		
	Ebn at Noon		258	271	275	273	273	273	272	270	266	254	244	245		
	Edh at Noon		22	29	34	40	41	40	39	36	32	26	21	19		
(44) All-Sky Solar Radiation	RadAvg		437	715	1071	1387	1580	1876	1849	1610	1266	821	461	356		
	RadStd		49	102	153	196	136	177	159	146	110	85	62	56		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	+0.92	N/A	N/A	N/A	N/A
(47) Regional (98 neighbors)	N/A	N/A	N/A	N/A	N/A	+0.72	N/A	N/A	+103	+34

Nomenclature: See separate page