

PULLY, Switzerland

WMO: 067110

Lat: 46.5122N

Lon: 6.6675E

Elev: 462

StdP: 95.90

Time Zone: 1.00 (EUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -5.5	(c) -3.7	(d) -11.2	(e) 1.5	(f) -4.4	(g) -9.1	(h) 1.8	(i) -2.5	(j) 6.0	(k) 4.8	(l) 5.3	(m) 3.3	(n) 3.1	(o) 30	(p) 0.406

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 8.6	(c) 29.8	(d) 19.9	(e) 28.1	(f) 19.3	(g) 26.5	(h) 18.8	(i) 20.8	(j) 27.5	(k) 20.1	(l) 26.4	(m) 19.4	(n) 25.2	(o) 1.5	(p) 200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
18.5	14.2	23.7	17.9	13.6	23.3	17.2	13.0	22.7	62.1	27.8	59.6	26.6	57.3	25.2	24.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
5.4	4.7	4.1	-6.9	32.6	2.3	1.7	-8.6	33.8	-10.0	34.7	-11.3	35.7	-13.0	36.9		
			-8.1	22.3	2.2	0.6	-9.7	22.8	-11.0	23.1	-12.2	23.5	-13.8	23.9		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	11.7	2.8	3.2	7.2	11.4	14.7	19.3	21.1	20.4	16.5	12.4	7.1	3.5
	DBStd	7.39	3.53	3.76	3.67	3.76	3.61	3.56	3.19	3.18	3.02	3.29	3.25	3.28
	HDD10.0	862	224	190	102	28	4	0	0	0	1	17	96	201
	HDD18.3	2687	482	423	347	207	121	30	11	15	71	185	337	459
	CDD10.0	1477	1	1	14	71	151	281	344	322	194	91	9	0
	CDD18.3	259	0	0	0	1	9	61	96	78	14	0	0	0
	CDH23.3	1422	0	0	0	2	39	341	586	419	34	0	0	0
	CDH26.7	322	0	0	0	0	3	72	146	99	1	0	0	0
Wind	WSAvg	1.6	1.6	1.7	1.7	1.7	1.6	1.6	1.6	1.5	1.6	1.5	1.6	1.6
Precipitation	PrecAvg	1137	85	76	74	86	102	100	103	98	105	105	99	
	PrecMax	1432	220	206	324	164	191	231	222	219	228	195	277	192
	PrecMin	827	21	8	22	15	32	43	35	20	32	20	11	0
	PrecStd	173	51	49	62	45	46	48	42	46	52	50	62	49
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.0	12.8	17.6	23.4	26.6	30.8	32.1	32.3	26.2	21.2	15.9	12.3
		MCWB	9.2	8.1	10.3	13.9	17.2	20.4	20.1	20.1	18.6	15.5	11.9	9.2
	2%	DB	10.4	10.6	15.5	21.0	24.3	28.7	30.0	29.2	24.3	19.2	14.0	10.2
		MCWB	7.8	7.1	9.5	12.9	16.2	19.6	19.8	19.9	17.9	14.8	10.9	8.1
	5%	DB	9.0	9.2	13.9	19.2	22.2	27.0	28.2	27.3	22.6	17.8	12.6	9.1
		MCWB	7.0	6.3	8.8	12.0	15.1	18.9	19.3	19.4	17.2	14.4	10.4	7.4
	10%	DB	7.6	8.0	12.3	17.3	20.6	25.2	26.6	25.6	21.1	16.6	11.4	8.0
		MCWB	5.9	5.6	8.2	11.2	14.3	18.2	18.7	18.8	16.5	13.8	9.6	6.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.7	9.1	11.2	15.0	18.4	21.7	21.7	21.6	19.9	16.7	12.7	9.9
		MCDB	11.5	11.6	15.2	21.0	24.6	28.5	28.9	28.2	24.3	19.2	14.6	11.5
	2%	WB	8.3	7.7	10.3	13.5	17.0	20.5	20.7	20.7	18.7	15.8	11.6	8.6
		MCDB	9.8	10.3	14.0	19.8	22.6	26.8	27.7	27.2	22.7	18.1	13.4	9.7
	5%	WB	7.2	6.7	9.5	12.5	16.0	19.6	20.0	20.0	17.8	14.9	10.6	7.6
		MCDB	8.7	8.8	13.0	18.1	20.9	25.7	26.5	25.9	21.8	17.2	12.3	8.8
	10%	WB	6.0	5.6	8.5	11.6	15.0	18.7	19.3	19.2	17.0	14.1	9.7	6.6
		MCDB	7.5	7.7	11.9	16.6	19.5	24.3	25.3	24.6	20.5	16.2	11.2	7.9
Mean Daily Temperature Range	5% DB	MDBR	3.8	4.8	6.4	7.7	7.8	8.2	8.6	7.9	7.0	5.4	4.1	3.6
		MCDBR	5.1	6.5	8.4	10.0	10.2	10.1	10.5	10.0	8.6	6.7	5.6	4.5
		MCWBR	3.8	4.4	4.7	5.1	5.0	4.7	4.6	4.6	4.3	4.0	3.7	3.5
	5% WB	MCDBR	4.9	6.0	7.5	9.3	9.1	9.4	9.6	9.1	7.7	5.9	5.1	4.3
		MCWBR	3.8	4.3	4.4	5.0	4.8	4.7	4.5	4.5	4.2	3.7	3.6	3.5
Clear-Sky Solar Irradiance	taub	0.289	0.315	0.356	0.395	0.406	0.406	0.404	0.394	0.374	0.353	0.318	0.288	
	taud	2.419	2.361	2.325	2.256	2.273	2.317	2.316	2.355	2.396	2.440	2.476	2.445	
	Ebn at Noon	812	855	866	860	861	861	857	852	838	801	770	771	
	Edh at Noon	69	90	108	127	130	125	123	114	100	83	66	61	
All-Sky Solar Radiation	RadAvg	1.38	2.25	3.38	4.37	4.98	5.91	5.83	5.08	3.99	2.59	1.45	1.12	
	RadStd	0.16	0.32	0.48	0.62	0.43	0.56	0.50	0.46	0.35	0.27	0.20	0.18	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	+0.51	N/A	N/A	N/A	N/A	
(47) Regional (98 neighbors)		N/A	N/A	N/A	N/A	+0.40	+0.30	N/A	N/A	+57	+19	

Nomenclature: See separate page