

AIGLE, Switzerland

WMO: 067120

Lat: 46.3267N

Lon: 6.9244E

Elev: 383

StdP: 96.81

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-7.9	-5.3	-10.9	1.5	-5.3	-8.8	1.9	-3.3	10.5	6.1	9.0	6.0	1.4	180	0.473

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.5	28.9	20.4	27.4	19.7	26.0	19.1	21.2	27.2	20.4	26.0	19.7	24.8	3.1	330

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.2	14.6	23.9	18.4	13.9	23.2	17.7	13.3	22.5	63.3	27.3	60.4	26.2	57.8	25.0	25.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
8.2	6.5	5.4	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
			-11.3	31.2	3.6	1.8	-13.9	32.5	-16.1	33.6	-18.1	34.6	-20.8	35.9		
			-11.7	23.1	3.6	1.0	-14.3	23.8	-16.4	24.4	-18.4	24.9	-21.0	25.6		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	10.7	1.8	2.9	6.7	10.3	14.4	18.0	19.7	19.2	15.1	11.2	5.9	2.6
	DBStd	7.14	3.70	3.65	3.35	3.43	3.15	3.15	2.78	2.77	2.81	3.13	3.56	3.50
	HDD10.0	988	254	199	110	37	4	0	0	0	1	24	129	229
	HDD18.3	2945	513	432	361	241	126	44	18	23	103	223	374	487
	CDD10.0	1238	0	1	8	47	141	239	301	284	153	60	6	1
	CDD18.3	154	0	0	0	1	5	34	61	49	5	0	0	0
	CDH23.3	1114	0	0	0	3	37	258	459	332	24	1	0	0
	CDH26.7	208	0	0	0	0	2	44	96	65	0	0	0	0
Wind	WSAvg	2.0	1.9	2.1	2.3	2.5	2.3	2.1	2.0	1.8	1.6	1.6	1.8	2.0
Precipitation	PrecAvg	1309	91	86	81	96	124	129	136	130	113	108	107	107
	PrecMax	1604	243	214	282	168	228	287	336	246	224	224	225	240
	PrecMin	1065	21	20	28	21	39	59	55	20	51	16	0	1
	PrecStd	167	54	54	54	45	56	53	57	54	46	48	58	55
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.0	14.2	18.0	23.2	26.2	29.7	31.2	30.9	25.8	21.2	18.0	13.3
		MCWB	7.4	8.1	11.2	13.8	17.6	20.7	20.6	21.2	19.0	15.3	10.5	7.7
	2%	DB	9.5	11.3	15.8	20.8	24.2	28.0	29.0	28.4	23.8	19.3	14.2	10.1
		MCWB	6.6	7.3	10.2	12.9	16.7	20.1	20.2	20.5	18.1	14.7	10.3	7.6
	5%	DB	8.0	9.7	14.2	19.0	22.4	26.3	27.5	26.7	22.2	17.8	12.4	8.7
		MCWB	5.8	6.4	9.3	12.1	15.6	19.0	19.7	19.7	17.3	13.9	9.9	6.8
	10%	DB	6.7	8.1	12.5	17.1	20.7	24.6	26.0	25.1	20.6	16.3	10.9	7.5
		MCWB	4.9	5.6	8.5	11.2	14.9	18.2	19.1	19.1	16.4	13.3	9.0	5.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.8	9.1	11.9	14.8	19.0	22.0	22.1	22.4	20.0	16.5	12.2	9.1
		MCDB	10.8	12.1	16.2	21.0	24.4	28.3	28.4	28.4	24.2	19.3	14.8	11.1
	2%	WB	7.1	7.8	10.9	13.6	17.5	20.7	21.1	21.2	18.7	15.5	11.0	8.0
		MCDB	8.8	10.7	14.7	19.6	22.8	26.6	27.2	27.0	22.7	18.1	13.2	9.4
	5%	WB	6.0	6.8	9.8	12.6	16.4	19.7	20.3	20.3	17.7	14.6	10.1	7.1
		MCDB	7.7	9.3	13.3	18.0	21.1	25.2	26.0	25.5	21.4	17.0	12.3	8.6
	10%	WB	5.0	5.6	8.8	11.6	15.4	18.8	19.6	19.4	16.8	13.6	9.1	6.0
		MCDB	6.7	7.8	11.9	16.3	19.6	23.6	24.8	24.2	19.9	15.8	10.9	7.3
Mean Daily Temperature Range	5% DB	MDBR	6.1	7.0	8.8	9.8	9.3	10.0	10.5	9.9	9.3	8.5	7.0	5.9
		MCDBR	7.1	9.1	11.3	13.0	12.3	12.7	13.1	12.6	11.1	10.1	8.6	6.8
		MCWBR	4.8	6.0	6.6	6.8	6.3	6.3	6.0	6.2	6.2	6.2	5.6	4.7
	5% WB	MCDBR	6.7	8.5	10.3	12.1	11.1	11.6	11.6	11.3	10.3	8.9	7.9	6.4
		MCWBR	4.9	5.9	6.3	6.6	6.0	6.1	5.8	5.9	6.0	5.8	5.4	4.6
Clear-Sky Solar Irradiance	taub	0.282	0.311	0.357	0.400	0.416	0.416	0.413	0.401	0.379	0.355	0.317	0.283	
	taud	2.358	2.290	2.240	2.208	2.231	2.283	2.287	2.331	2.379	2.426	2.451	2.403	
	Ebn at Noon	817	857	862	854	852	852	849	845	833	800	771	775	
	Edh at Noon	73	96	118	134	135	129	127	117	102	85	68	63	
All-Sky Solar Radiation	RadAvg	1.43	2.30	3.41	4.38	5.00	5.94	5.89	5.13	4.03	2.61	1.49	1.17	
	RadStd	0.16	0.32	0.47	0.60	0.43	0.54	0.49	0.44	0.34	0.28	0.20	0.18	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	+0.72	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (98 neighbors)	N/A	N/A	N/A	N/A	+0.39	+0.29	N/A	N/A	+57	+19

Nomenclature: See separate page