

VISP, Switzerland

WMO: 067270

Lat: 46.3028N

Lon: 7.8431E

Elev: 2106

StdP: 13.61

Time Zone: 1.00 (EUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 11.6	(c) 15.5	(d) 4.0	(e) 7.3	(f) 18.5	(g) 8.5	(h) 9.2	(i) 20.6	(j) 30.7	(k) 40.4	(l) 27.7	(m) 39.3	(n) 2.0	(o) 110	(p) 0.579

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 24.7	(c) 88.8	(d) 65.9	(e) 85.8	(f) 64.8	(g) 82.8	(h) 63.8	(i) 67.5	(j) 84.7	(k) 66.2	(l) 82.2	(m) 64.8	(n) 79.4	(o) 11.5	(p) 270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) 62.1	(b) 90.3	(c) 70.6	(d) 60.8	(e) 85.9	(f) 70.0	(g) 59.5	(h) 82.0	(i) 69.4	(j) 33.1	(k) 85.0	(l) 32.0	(m) 82.5	(n) 31.0	(o) 79.5	(p) 73.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 28.1	(b) 24.6	(c) 21.6	(e) 6.1	(f) 93.4	(g) 6.0	(h) 2.2	(i) 1.8	(j) 95.0	(k) -1.7	(l) 96.3	(m) -5.1	(n) 97.6	(o) -9.4	(p) 99.2		
			DB													
			WB													
				5.8	70.2	5.6	1.4	1.7	71.2	-1.6	72.0	-4.8	72.7	-8.9	73.7	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	50.5	30.3	35.0	44.3	52.1	58.0	66.1	68.4	66.8	59.8	51.9	40.4	31.4		
	DBStd	14.84	8.01	7.20	6.62	5.82	6.01	5.84	4.98	5.05	5.22	6.41	8.25	7.79		
	HDD50	2216	610	420	195	46	8	0	0	0	1	55	303	578		
	HDD65	5648	1075	839	641	389	226	57	25	39	170	406	739	1042		
	CDD50	2381	0	0	19	108	257	482	571	521	294	114	14	1		
	CDD65	337	0	0	0	0	10	88	131	95	13	0	0	0		
	CDH74	4043	0	0	0	24	218	1086	1478	1064	169	4	0	0		
	CDH80	1284	0	0	0	0	40	371	512	343	18	0	0	0		
(14) Wind	WSAvg	6.9	5.1	6.5	8.2	9.4	8.7	7.3	7.3	6.3	6.1	6.0	6.3	5.2		
(15) Precipitation	PrecAvg	41.1	2.7	2.7	2.7	3.1	4.3	4.1	4.1	4.1	3.1	3.3	3.7	3.3		
	PrecMax	54.8	6.9	7.7	5.2	5.7	8.6	7.1	8.7	8.2	7.7	10.0	10.4	8.6		
	PrecMin	28.3	0.7	0.6	0.7	0.7	1.4	2.0	1.6	1.5	1.6	0.2	0.8	0.2		
	PrecStd	5.4	1.6	1.8	1.3	1.4	2.0	1.3	1.4	1.5	1.4	1.9	2.1	1.9		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	51.3	58.1	69.0	77.2	84.4	92.4	91.9	91.8	82.6	73.8	62.8	54.8		
		MCWB	41.9	44.5	49.6	55.6	61.2	65.9	66.9	66.6	63.6	57.6	49.0	44.7		
	2%	DB	47.5	52.8	65.2	72.9	79.7	87.9	88.6	87.4	78.8	70.0	59.2	50.1		
		MCWB	40.4	41.7	48.2	54.1	59.2	65.3	65.7	66.2	62.2	55.9	48.3	42.5		
	5%	DB	44.4	49.3	61.4	69.0	75.6	84.5	85.6	83.7	75.1	66.7	56.3	45.5		
		MCWB	38.9	39.9	46.7	51.9	57.5	64.0	64.9	65.0	60.2	54.5	46.9	40.6		
	10%	DB	41.3	45.9	57.5	65.6	71.8	80.6	82.5	80.2	71.7	63.8	53.1	42.3		
		MCWB	37.0	38.1	44.7	50.4	55.5	62.4	64.0	63.9	58.5	53.0	46.0	38.5		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	44.7	45.9	51.2	56.6	62.7	68.6	69.2	69.1	65.2	59.7	51.9	45.6		
		MCDB	48.1	54.5	65.1	74.1	80.9	87.4	86.6	87.1	78.3	68.9	57.1	52.3		
	2%	WB	41.8	43.1	49.1	54.7	60.3	66.6	67.5	67.4	63.2	57.6	49.6	43.7		
		MCDB	46.0	51.4	62.3	71.4	76.3	84.2	84.7	84.0	76.1	66.4	55.5	48.9		
	5%	WB	39.5	40.8	47.4	52.9	58.5	65.0	66.1	65.8	61.5	56.0	48.0	41.2		
		MCDB	43.8	47.6	59.0	67.2	72.4	81.4	82.3	80.4	72.7	64.0	54.8	45.1		
	10%	WB	37.3	38.8	45.7	51.1	56.7	63.4	64.7	64.5	59.8	54.4	46.3	38.9		
		MCDB	41.0	45.0	55.7	63.8	69.0	78.0	79.4	77.3	69.4	61.9	53.2	41.8		
(35) Mean Daily Temperature Range	5% DB	MDBR	12.3	16.3	21.2	22.5	22.6	24.3	24.7	23.6	22.2	20.5	14.3	11.0		
		MCDBR	14.4	22.3	28.6	29.8	30.4	31.2	30.5	30.8	27.6	23.8	17.7	13.4		
	5% WB	MCWBR	9.4	12.7	14.6	14.5	12.8	12.0	11.4	12.7	12.9	12.1	9.9	8.6		
		MCWBR	12.3	20.0	25.4	27.4	26.7	27.9	27.5	27.6	25.0	20.9	15.3	11.3		
(40) Clear-Sky Solar Irradiance	taub		0.288	0.325	0.392	0.454	0.479	0.486	0.481	0.461	0.424	0.384	0.328	0.285		
		taud	2.234	2.117	1.980	1.926	1.956	2.006	2.031	2.095	2.169	2.232	2.284	2.269		
	Ebn at Noon		252	263	259	253	252	251	250	249	247	239	234	240		
		Edh at Noon	26	36	48	56	56	54	52	47	40	32	25	23		
(44) All-Sky Solar Radiation	RadAvg		471	755	1121	1400	1577	1866	1860	1616	1261	818	479	388		
	RadStd		56	100	157	200	141	164	154	136	109	92	69	56		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
	N/A	N/A	N/A	N/A	N/A	+0.77	N/A	N/A	N/A	N/A
Regional (114 neighbors)	N/A	N/A	N/A	+1.31	+0.74	+0.56	N/A	N/A	+103	+29

Nomenclature: See separate page