

VISP, Switzerland

WMO: 067270

Lat: 46.3028N

Lon: 7.8431E

Elev: 642

StdP: 93.85

Time Zone: 1.00 (EUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-11.4	-9.2	-15.6	1.0	-7.5	-13.0	1.3	-6.3	13.7	4.7	12.4	4.0	0.9	110	0.579

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.7	31.6	18.8	29.9	18.2	28.2	17.7	19.7	29.3	19.0	27.9	18.2	26.3	5.1	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
16.7	12.9	21.5	16.0	12.3	21.1	15.3	11.7	20.8	59.2	29.4	56.5	28.0	54.2	26.4	23.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.6	11.0	9.7	DB	-14.4	34.1	3.3	1.2	-16.8	35.0	-18.7	35.7	-20.6	36.4	-23.0	37.3	(4)
(5)			WB	-14.6	21.2	3.1	0.8	-16.8	21.8	-18.7	22.2	-20.4	22.6	-22.7	23.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	10.3	-0.9	1.7	6.8	11.1	14.5	18.9	20.2	19.3	15.4	11.1	4.6	-0.3	(6)	
	DBStd	8.24	4.45	4.00	3.68	3.24	3.34	3.24	2.77	2.81	2.90	3.56	4.58	4.33	(7)	
	HDD10.0	1231	339	233	108	26	4	0	0	0	1	31	168	321	(8)	
	HDD18.3	3138	597	466	356	216	126	32	14	22	94	226	411	579	(9)	
	CDD10.0	1323	0	0	11	60	143	268	317	289	163	63	8	1	(10)	
	CDD18.3	187	0	0	0	0	6	49	73	53	7	0	0	0	(11)	
	CDH23.3	2246	0	0	0	13	121	603	821	591	94	2	0	0	(12)	
	CDH26.7	713	0	0	0	0	22	206	284	191	10	0	0	0	(13)	
(14) Wind	WSAvg	3.1	2.3	2.9	3.7	4.2	3.9	3.3	3.3	2.8	2.7	2.7	2.8	2.3	(14)	
(15) Precipitation	PrecAvg	1045	69	68	69	78	110	103	104	103	80	83	95	84	(15)	
	PrecMax	1392	175	196	133	144	218	180	220	208	196	255	264	219	(16)	
	PrecMin	720	19	14	18	18	36	50	41	37	41	6	20	5	(17)	
	PrecStd	136	41	45	34	35	51	32	35	39	35	48	53	47	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.7	14.5	20.5	25.1	29.1	33.6	33.3	33.2	28.1	23.2	17.1	12.7	(19)	
		MCWB	5.5	6.9	9.8	13.1	16.2	18.8	19.4	19.2	17.6	14.2	9.4	7.1	(20)	
	2%	DB	8.6	11.6	18.4	22.7	26.5	31.1	31.5	30.8	26.0	21.1	15.1	10.0	(21)	
		MCWB	4.7	5.4	9.0	12.3	15.1	18.5	18.7	19.0	16.8	13.3	9.0	5.8	(22)	
	5%	DB	6.9	9.6	16.4	20.5	24.2	29.2	29.8	28.7	24.0	19.3	13.5	7.5	(23)	
		MCWB	3.8	4.4	8.1	11.1	14.1	17.8	18.3	18.4	15.7	12.5	8.3	4.8	(24)	
	10%	DB	5.2	7.7	14.1	18.7	22.1	27.0	28.1	26.8	22.1	17.6	11.7	5.7	(25)	
		MCWB	2.8	3.4	7.1	10.2	13.1	16.9	17.8	17.7	14.7	11.7	7.8	3.6	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.1	7.7	10.7	13.6	17.1	20.3	20.7	20.6	18.4	15.4	11.0	7.6	(27)	
		MCDB	8.9	12.5	18.4	23.4	27.2	30.8	30.3	30.6	25.7	20.5	13.9	11.3	(28)	
	2%	WB	5.4	6.1	9.5	12.6	15.7	19.2	19.7	19.6	17.3	14.2	9.8	6.5	(29)	
		MCDB	7.8	10.8	16.8	21.9	24.6	29.0	29.3	28.9	24.5	19.1	13.0	9.4	(30)	
	5%	WB	4.2	4.9	8.5	11.6	14.7	18.4	18.9	18.8	16.4	13.3	8.9	5.1	(31)	
		MCDB	6.6	8.7	15.0	19.6	22.4	27.5	27.9	26.9	22.6	17.8	12.7	7.3	(32)	
	10%	WB	2.9	3.8	7.6	10.6	13.7	17.4	18.2	18.0	15.4	12.5	8.0	3.8	(33)	
		MCDB	5.0	7.2	13.2	17.7	20.5	25.6	26.3	25.2	20.8	16.6	11.8	5.5	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	6.8	9.1	11.8	12.5	12.6	13.5	13.7	13.1	12.3	11.4	7.9	6.1	(35)	
		MCDBR	8.0	12.4	15.9	16.6	16.9	17.3	17.0	17.1	15.3	13.2	9.8	7.4	(36)	
	5% WB	MCWBR	5.2	7.1	8.1	8.1	7.1	6.7	6.3	7.0	7.2	6.7	5.5	4.8	(37)	
		MCWBR	6.8	11.1	14.1	15.2	14.8	15.5	15.3	15.3	13.9	11.6	8.5	6.3	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.288	0.325	0.392	0.454	0.479	0.486	0.481	0.461	0.424	0.384	0.328	0.285	(40)	
		taud	2.234	2.117	1.980	1.926	1.956	2.006	2.031	2.095	2.169	2.232	2.284	2.269	(41)	
	Ebn at Noon	Ebn at Noon	795	828	815	799	793	790	787	786	780	753	738	756	(42)	
		Edh at Noon	82	114	152	177	178	171	164	148	126	102	79	71	(43)	
(44) All-Sky Solar Radiation	RadAvg	RadAvg	1.48	2.38	3.54	4.41	4.97	5.88	5.87	5.09	3.97	2.58	1.51	1.22	(44)	
	RadStd	RadStd	0.18	0.31	0.49	0.63	0.44	0.52	0.48	0.43	0.34	0.29	0.22	0.17	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (114 neighbors)	N/A	N/A	N/A	+0.73	+0.41	+0.31	N/A	N/A	+57	+16

Nomenclature: See separate page