

INTERLAKEN AP, Switzerland

WMO: 067340

Lat: 46.6722N

Lon: 7.8703E

Elev: 1898

StdP: 13.72

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	17.0	20.1	11.0	10.3	19.0	13.8	11.9	21.7	15.1	39.5	13.3	36.9	4.3	200	0.491

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.0	84.7	67.7	81.2	66.1	78.0	64.7	68.8	81.3	67.3	78.4	65.8	75.7	6.7	280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
64.7	98.2	72.9	63.3	93.4	71.7	62.0	89.2	70.5	34.0	81.6	32.8	78.7	31.6	75.9	74.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
14.2	12.0	10.4	DB	12.4	89.7	4.9	3.0	8.8	91.9	6.0	93.7	3.2	95.4	-0.4	97.5
			WB	11.4	71.9	4.6	1.5	8.0	73.0	5.3	73.8	2.7	74.7	-0.6	75.7

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	49.6	32.4	34.8	42.4	49.1	56.6	63.2	66.6	65.5	58.4	50.8	40.4	33.9
	DBStd	13.57	6.26	6.78	6.71	6.62	6.32	6.45	5.63	5.62	5.56	5.64	6.37	6.10
	HDD50	2180	545	424	245	95	16	1	0	0	5	58	293	498
	HDD65	5864	1009	844	701	476	267	107	49	63	207	439	739	963
	CDD50	2034	0	0	9	69	221	398	513	480	256	84	4	0
	CDD65	247	0	0	0	0	7	54	98	79	9	0	0	0
	CDH74	1765	0	0	0	6	90	437	662	523	47	0	0	0
	CDH80	423	0	0	0	0	9	105	176	131	2	0	0	0
	WSAvg	3.6	3.3	3.5	4.0	4.5	4.2	4.0	3.9	3.4	3.2	3.0	3.2	3.4
	PrecAvg	52.2	3.2	3.3	3.3	3.8	5.6	5.7	6.1	6.1	4.1	3.4	3.8	3.8
(15) Precipitation	PrecMax	64.9	7.9	9.8	7.3	7.7	9.5	9.3	12.6	11.8	6.8	5.9	9.9	9.9
	PrecMin	38.9	0.5	1.0	1.3	1.4	2.0	2.7	2.6	1.5	1.9	0.1	0.3	0.1
	PrecStd	5.6	1.9	2.1	1.5	1.4	2.2	1.6	2.2	2.0	1.3	1.4	2.0	2.0
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	51.0	56.1	65.4	74.5	80.9	87.6	89.2	88.7	78.3	69.5	58.8	51.1
		MCWB	44.8	45.7	50.8	56.9	62.7	68.2	68.6	68.2	65.2	58.5	50.8	44.0
	2%	DB	45.6	50.8	61.3	69.6	76.4	83.1	84.9	83.5	74.8	65.6	54.4	46.8
		MCWB	41.9	42.7	48.7	54.6	60.4	66.5	67.7	67.7	63.6	57.0	48.9	43.4
	5%	DB	42.7	47.0	57.3	65.6	72.6	79.1	80.9	79.7	71.2	62.2	51.4	44.3
		MCWB	40.1	41.2	47.0	52.5	58.6	64.6	66.2	66.4	61.7	55.7	47.5	42.0
	10%	DB	40.5	43.6	53.4	61.7	68.7	75.3	77.3	76.1	67.8	59.3	49.0	42.0
		MCWB	38.2	39.2	44.9	50.7	57.0	63.0	64.8	64.9	60.2	54.3	45.9	39.9
	0.4%	WB	46.2	47.3	52.2	58.1	64.7	70.2	71.1	70.6	66.6	60.5	52.0	46.2
		MCDB	49.2	53.5	62.3	71.8	77.2	85.0	85.0	83.1	76.0	65.8	55.9	48.8
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	42.5	44.0	49.8	55.4	62.0	67.6	68.6	68.6	64.4	58.4	49.8	44.0
		MCDB	44.9	49.4	59.3	67.4	73.4	79.7	81.3	80.5	73.3	63.3	53.7	46.1
	5%	WB	40.4	41.5	47.7	53.3	59.9	65.7	67.1	67.1	62.6	56.6	48.0	42.1
		MCDB	42.4	46.4	55.7	63.7	69.9	76.7	78.3	77.6	69.8	61.1	51.1	44.3
	10%	WB	38.4	39.4	45.7	51.4	57.9	64.0	65.6	65.5	60.9	54.7	46.1	40.1
		MCDB	40.3	43.1	52.5	60.5	67.0	73.6	75.3	74.5	66.6	58.7	48.8	42.0
(35) Mean Daily Temperature Range	5% DB	MDBR	9.7	12.8	16.5	17.8	17.7	17.7	18.0	17.3	15.7	14.0	11.0	9.0
		MCDBR	12.3	18.4	23.8	25.3	24.9	24.4	24.1	23.6	20.7	18.1	14.5	11.6
		MCWBR	9.2	11.7	13.4	13.2	12.0	11.4	10.6	10.9	11.3	10.9	9.7	8.6
	5% WB	MCDBR	11.7	16.9	21.6	23.5	22.3	22.7	22.0	21.7	19.5	16.7	13.5	10.9
		MCWBR	9.0	11.3	12.5	12.7	11.3	10.9	10.3	10.7	10.8	10.5	9.2	8.3
(40) Clear-Sky Solar Irradiance	taub		0.285	0.317	0.370	0.420	0.441	0.445	0.444	0.429	0.398	0.364	0.319	0.283
	taud		2.309	2.216	2.124	2.078	2.106	2.159	2.164	2.217	2.282	2.341	2.372	2.339
	Ebn at Noon		255	267	267	264	263	262	260	259	256	247	239	241
	Edh at Noon		24	33	42	48	49	46	46	42	36	29	23	21
	RadAvg		445	730	1100	1394	1562	1845	1817	1581	1231	801	462	365
(45) All-Sky Solar Radiation	RadStd		53	98	158	208	145	171	158	144	113	86	63	55

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
	N/A	N/A	N/A	+1.35	+1.19	+1.06	N/A	N/A	+117	N/A
Regional (118 neighbors)	N/A	N/A	N/A	+1.30	+0.74	+0.58	N/A	N/A	+103	+29

Nomenclature: See separate page