

INTERLAKEN AP, Switzerland

WMO: 067340

Lat: 46.6722N

Lon: 7.8703E

Elev: 579

StdP: 94.56

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-8.3	-6.6	-11.7	1.5	-7.2	-10.1	1.7	-5.7	6.8	4.2	5.9	2.7	1.9	200	0.491

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.0	29.3	19.8	27.3	19.0	25.6	18.1	20.4	27.4	19.6	25.8	18.8	24.3	3.0	280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
18.2	14.0	22.7	17.4	13.3	22.0	16.7	12.7	21.4	61.3	27.5	58.3	26.0	55.6	24.4	23.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 6.4	5.4	4.6	-10.9	32.1	2.7	1.7	-12.9	33.3	-14.5	34.3	-16.0	35.2	-18.0	36.4		
(5)			-11.4	22.2	2.6	0.8	-13.3	22.8	-14.8	23.2	-16.3	23.7	-18.1	24.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	9.8	0.2	1.6	5.8	9.5	13.7	17.4	19.2	18.6	14.7	10.5	4.6	1.1	(6)
(7)		DBStd	7.54	3.48	3.77	3.73	3.68	3.51	3.58	3.13	3.12	3.09	3.14	3.54	3.39	(7)
(8)		HDD10.0	1211	303	236	136	53	9	1	0	0	3	32	163	277	(8)
(9)		HDD18.3	3258	561	469	389	264	148	59	27	35	115	244	411	535	(9)
(10)		CDD10.0	1130	0	0	5	38	123	221	285	267	142	47	2	0	(10)
(11)		CDD18.3	137	0	0	0	0	4	30	54	44	5	0	0	0	(11)
(12)		CDH23.3	981	0	0	0	3	50	243	368	291	26	0	0	0	(12)
(13)		CDH26.7	235	0	0	0	0	5	58	98	73	1	0	0	0	(13)
(14)	Wind	WSAvg	1.6	1.5	1.6	1.8	2.0	1.9	1.8	1.7	1.5	1.4	1.3	1.4	1.5	(14)
(15)	Precipitation	PrecAvg	1327	81	84	85	97	141	145	155	156	105	87	97	96	(15)
(16)		PrecMax	1648	200	249	185	195	241	237	320	300	173	149	251	251	(16)
(17)		PrecMin	987	13	26	33	35	52	68	66	37	49	2	7	3	(17)
(18)		PrecStd	142	47	53	37	35	56	40	57	52	32	36	50	52	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.6	13.4	18.6	23.6	27.2	30.9	31.8	31.5	25.7	20.8	14.9	10.6	(19)
(20)			MCWB	7.1	7.6	10.5	13.8	17.1	20.1	20.4	20.1	18.4	14.7	10.4	6.7	(20)
(21)		2%	DB	7.6	10.4	16.3	20.9	24.7	28.4	29.4	28.6	23.8	18.6	12.4	8.2	(21)
(22)			MCWB	5.5	5.9	9.3	12.6	15.8	19.2	19.9	19.8	17.5	13.9	9.4	6.4	(22)
(23)		5%	DB	6.0	8.4	14.1	18.7	22.6	26.2	27.2	26.5	21.8	16.8	10.8	6.8	(23)
(24)			MCWB	4.5	5.1	8.3	11.4	14.8	18.1	19.0	19.1	16.5	13.2	8.6	5.6	(24)
(25)		10%	DB	4.7	6.5	11.9	16.5	20.4	24.1	25.2	24.5	19.9	15.2	9.5	5.5	(25)
(26)			MCWB	3.4	4.0	7.2	10.4	13.9	17.2	18.2	18.3	15.6	12.4	7.7	4.4	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.9	8.5	11.2	14.5	18.2	21.2	21.7	21.5	19.2	15.8	11.1	7.9	(27)
(28)			MCD B	9.6	11.9	16.8	22.1	25.1	29.5	29.4	28.4	24.4	18.8	13.3	9.3	(28)
(29)		2%	WB	5.8	6.7	9.9	13.0	16.7	19.8	20.3	20.4	18.0	14.7	9.9	6.7	(29)
(30)			MCD B	7.1	9.7	15.2	19.7	23.0	26.5	27.4	27.0	22.9	17.4	12.0	7.8	(30)
(31)		5%	WB	4.7	5.3	8.7	11.9	15.5	18.7	19.5	19.5	17.0	13.7	8.9	5.6	(31)
(32)			MCD B	5.8	8.0	13.2	17.6	21.1	24.8	25.7	25.3	21.0	16.2	10.6	6.9	(32)
(33)		10%	WB	3.6	4.1	7.6	10.8	14.4	17.8	18.7	18.6	16.0	12.6	7.8	4.5	(33)
(34)			MCD B	4.6	6.2	11.4	15.8	19.4	23.1	24.1	23.6	19.2	14.9	9.3	5.5	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	5.4	7.1	9.2	9.9	9.8	9.9	10.0	9.6	8.7	7.8	6.1	5.0	(35)
(36)			MCD BR	6.8	10.2	13.2	14.0	13.8	13.5	13.4	13.1	11.5	10.1	8.1	6.5	(36)
(37)			MCWBR	5.1	6.5	7.4	7.3	6.7	6.3	5.9	6.1	6.3	6.1	5.4	4.8	(37)
(38)		5% WB	MCD BR	6.5	9.4	12.0	13.0	12.4	12.6	12.2	12.1	10.8	9.3	7.5	6.1	(38)
(39)			MCWBR	5.0	6.3	6.9	7.1	6.3	6.1	5.7	5.9	6.0	5.8	5.1	4.6	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.285	0.317	0.370	0.420	0.441	0.445	0.444	0.429	0.398	0.364	0.319	0.283	(40)	
(41)		taud	2.309	2.216	2.124	2.078	2.106	2.159	2.164	2.217	2.282	2.341	2.372	2.339	(41)	
(42)		Ebn at Noon	804	841	841	832	828	825	819	816	808	780	754	761	(42)	
(43)		Edh at Noon	76	103	132	152	153	146	144	131	112	91	72	66	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.40	2.30	3.47	4.39	4.92	5.82	5.73	4.98	3.88	2.52	1.46	1.15	(44)	
(45)		RadStd	0.17	0.31	0.50	0.66	0.46	0.54	0.50	0.46	0.36	0.27	0.20	0.17	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	+0.75	+0.66	+0.59	N/A	N/A	+65	N/A
(47) Regional (118 neighbors)		N/A	N/A	N/A	+0.72	+0.41	+0.32	N/A	N/A	+57	+16

Nomenclature: See separate page