

ACQUAROSSA-COMPROVASCO, Switzerland

WMO: 067560

Lat: 46.4594N

Lon: 8.9356E

Elev: 552

StdP: 94.87

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -5.2	(c) -3.9	(d) -18.3	(e) 0.8	(f) 0.3	(g) -15.7	(h) 1.0	(i) 1.2	(j) 9.7	(k) 6.5	(l) 8.7	(m) 6.3	(n) 1.6	(o) 340	(p) 0.477

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 11.1	(c) 29.2	(d) 19.6	(e) 27.5	(f) 18.9	(g) 26.0	(h) 18.0	(i) 21.2	(j) 26.4	(k) 20.2	(l) 25.3	(m) 19.4	(n) 24.0	(o) 3.6	(p) 170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.5	15.2	23.5	18.6	14.3	22.3	17.7	13.6	21.4	63.9	26.5	60.5	25.4	57.5	24.3	25.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 8.1	(b) 6.9	(c) 5.9	(e) -7.5	(f) 31.6	(g) 2.0	(h) 1.9	(i) -9.0	(j) 33.0	(k) -10.1	(l) 34.1	(m) -11.3	(n) 35.2	(o) -12.7	(p) 36.6		
			DB													
			WB													
				(e) -9.0	(f) 22.7	(g) 2.0	(h) 1.2	(i) -10.4	(j) 23.6	(k) -11.6	(l) 24.4	(m) -12.7	(n) 25.1	(o) -14.1	(p) 26.0	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	11.1	2.2	3.5	7.6	10.8	14.4	18.3	20.0	19.3	15.5	11.4	6.4	3.1
	DBStd	6.91	2.94	3.36	3.65	3.25	2.92	3.10	2.52	2.59	2.64	2.96	3.15	3.21
	HDD10.0	894	241	183	92	29	2	0	0	0	1	19	112	216
	HDD18.3	2806	498	416	333	227	126	39	13	19	91	214	357	473
	CDD10.0	1289	1	2	17	52	138	248	309	287	166	63	4	1
	CDD18.3	159	0	0	0	0	4	37	63	48	6	0	0	0
	CDH23.3	1142	0	0	0	7	49	299	456	297	32	2	0	0
	CDH26.7	242	0	0	0	0	5	66	99	71	2	0	0	0
Wind	WSAvg	1.9	1.9	2.0	2.3	2.4	2.2	2.1	1.9	1.7	1.7	1.7	1.7	1.7
Precipitation	PrecAvg	1562	69	60	70	129	163	167	148	173	169	164	175	74
	PrecMax	2165	227	236	245	392	493	389	326	290	459	615	710	211
	PrecMin	826	5	5	3	16	37	42	36	28	16	11	12	1
	PrecStd	337	54	51	56	92	100	84	63	60	126	124	163	49
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	15.6	15.8	21.1	24.1	27.1	30.9	31.1	32.0	26.3	22.2	17.0	14.6
		MCWB	7.5	6.6	10.1	13.5	16.7	19.7	19.7	19.7	17.5	14.3	8.9	6.6
	2%	DB	10.6	12.5	18.2	21.5	24.5	28.6	29.2	28.5	24.1	19.5	13.8	11.2
		MCWB	4.5	5.6	8.8	11.7	15.2	19.0	19.9	19.7	17.2	12.8	8.0	4.7
	5%	DB	8.1	10.3	16.1	19.5	22.7	26.7	27.6	26.4	22.2	17.6	12.0	8.9
		MCWB	3.0	4.4	7.9	10.6	14.2	18.2	19.1	18.9	15.8	12.4	7.8	4.3
	10%	DB	6.2	8.4	13.8	17.3	20.7	24.9	26.0	24.6	20.5	15.7	10.7	7.3
		MCWB	2.1	3.4	6.9	9.7	13.4	17.2	18.3	18.0	14.9	12.2	7.5	3.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.9	8.1	10.8	14.1	18.3	22.1	22.8	22.1	19.5	16.0	11.4	8.1
		MCDB	13.9	13.0	17.9	22.1	24.5	27.9	28.0	27.3	23.9	18.6	13.1	10.6
	2%	WB	5.3	6.2	9.7	12.7	16.6	20.5	21.3	20.9	18.2	14.8	10.2	6.6
		MCDB	8.8	10.7	15.5	19.1	21.9	26.1	26.4	26.1	22.1	17.1	11.7	8.9
	5%	WB	4.0	5.0	8.8	11.6	15.4	19.4	20.3	19.9	17.1	13.9	9.3	5.5
		MCDB	7.0	9.0	14.1	17.0	20.3	24.5	25.4	24.6	20.4	15.9	10.6	7.6
	10%	WB	2.9	4.1	7.8	10.6	14.4	18.2	19.4	19.0	16.2	13.0	8.5	4.4
		MCDB	5.3	7.4	12.6	15.1	18.8	23.1	24.3	23.1	19.0	14.8	9.8	6.7
Mean Daily Temperature Range	5% DB	MDBR	6.4	7.6	9.5	9.8	9.9	10.7	11.1	10.2	9.2	7.7	6.6	6.3
		MCDBR	9.2	10.3	13.0	13.8	13.8	13.6	13.3	12.8	11.7	10.3	8.8	8.5
		MCWBR	5.2	5.7	6.3	6.3	6.4	6.4	6.1	6.1	5.9	5.5	5.0	4.8
	5% WB	MCDBR	8.0	9.2	11.3	11.5	11.5	11.9	11.8	11.1	10.0	7.9	6.2	6.9
		MCWBR	5.0	5.5	5.8	5.7	6.0	6.4	6.2	5.9	5.6	4.7	4.0	4.4
Clear-Sky Solar Irradiance	taub	0.290	0.324	0.383	0.448	0.466	0.479	0.470	0.458	0.427	0.389	0.329	0.286	
	taud	2.253	2.149	2.025	1.951	2.031	2.064	2.104	2.150	2.199	2.256	2.314	2.294	
	Ebn at Noon	793	830	824	804	805	795	797	789	777	748	737	755	
	Edh at Noon	80	110	146	172	165	161	153	140	122	100	77	69	
All-Sky Solar Radiation	RadAvg	1.61	2.58	3.79	4.47	4.80	5.65	5.65	4.89	3.81	2.52	1.56	1.34	
	RadStd	0.20	0.30	0.55	0.72	0.48	0.49	0.48	0.43	0.37	0.30	0.24	0.17	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.27	N/A	N/A	N/A	+0.66	N/A	N/A	N/A	+77	+44
(47) Regional (119 neighbors)		N/A	N/A	N/A	+0.73	+0.41	+0.31	N/A	N/A	+59	+16

Nomenclature: See separate page