

CIMETTA, Switzerland

WMO: 067590

Lat: 46.2006N

Lon: 8.7917E

Elev: 5407

StdP: 12.04

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	12.6	15.7	-13.8	3.2	25.9	-10.1	3.9	25.1	21.1	29.4	18.6	28.2	6.6	340	0.622

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.4	69.5	58.7	67.1	57.7	64.9	56.7	61.9	66.5	60.1	64.7	58.5	62.9	4.6	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
60.1	95.0	64.6	58.3	88.9	62.8	56.7	84.0	61.1	30.6	66.6	29.2	64.9	28.0	63.1	70.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 19.7	16.2	13.7	10.1	73.0	4.5	3.9	6.8	75.9	4.2	78.1	1.7	80.3	-1.6	83.2		
(5)			7.6	64.3	3.9	2.6	4.8	66.2	2.6	67.7	0.4	69.2	-2.4	71.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	42.6	29.5	29.6	34.0	39.1	46.8	54.1	57.7	57.4	50.2	44.2	36.0	31.4		
	DBStd	12.16	7.04	8.00	7.59	6.75	6.10	6.28	4.95	5.31	5.70	6.57	7.23	7.37		
	HDD50	3477	635	572	496	332	137	30	5	6	65	198	423	578		
	HDD65	8198	1100	991	960	776	565	331	231	244	443	645	869	1043		
	CDD50	765	0	1	1	5	37	151	243	234	72	18	3	0		
	CDD65	13	0	0	0	0	0	2	4	7	0	0	0	0		
	CDH74	9	0	0	0	0	0	6	1	2	0	0	0	0		
	CDH80	1	0	0	0	0	0	1	0	0	0	0	0	0		
	WSAvg	5.4	5.4	5.2	5.7	6.0	5.9	5.4	5.4	5.1	5.0	5.0	5.6	5.2		
	PrecAvg	68.0	2.9	2.6	3.2	5.8	7.6	7.1	6.6	7.0	7.5	7.1	7.6	2.9		
(15) Precipitation	PrecMax	100.7	9.6	10.9	10.9	15.7	21.8	17.6	12.8	12.6	17.4	22.7	29.2	8.9		
	PrecMin	39.1	0.0	0.2	0.2	0.5	2.8	1.1	1.2	0.8	0.8	0.4	0.1	0.0		
	PrecStd	14.9	2.4	2.4	2.5	3.8	4.1	3.7	3.1	2.9	5.1	4.8	6.9	2.3		
	PrecStd	14.9	2.4	2.4	2.5	3.8	4.1	3.7	3.1	2.9	5.1	4.8	6.9	2.3		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	51.3	53.6	54.3	59.0	64.8	71.7	72.0	72.9	66.5	61.9	57.4	52.9		
		MCWB	36.3	37.1	39.7	45.8	53.3	58.5	62.6	60.5	55.9	48.9	42.2	36.6		
	2%	DB	46.9	49.2	50.2	54.3	60.8	67.7	68.8	69.9	62.6	57.8	52.1	47.7		
		MCWB	34.2	35.5	37.5	43.8	50.9	57.7	59.5	58.5	54.2	46.3	40.6	34.5		
	5%	DB	43.4	44.5	47.4	51.0	57.8	65.0	66.2	67.1	59.8	55.2	48.6	44.5		
		MCWB	32.7	32.9	36.1	42.0	48.9	56.4	58.0	57.7	52.8	45.4	38.6	32.8		
	10%	DB	39.7	41.0	44.4	48.1	55.2	62.6	64.3	64.6	57.5	52.6	45.3	41.6		
		MCWB	30.4	31.4	35.0	40.6	47.2	55.4	57.0	56.6	51.4	44.5	37.0	31.8		
	0.4%	WB	38.4	38.7	41.7	48.6	55.3	63.2	64.8	63.8	59.2	52.8	45.6	38.6		
		MCDB	47.6	49.9	50.4	54.4	61.9	67.5	69.4	70.4	63.4	56.7	52.7	47.5		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	35.8	36.2	39.5	45.9	52.9	60.4	62.0	61.4	56.7	50.3	42.8	36.7		
		MCDB	43.7	46.2	46.3	51.9	58.8	65.0	66.1	66.8	60.2	53.0	48.0	42.3		
	5%	WB	33.6	34.2	37.8	43.7	50.6	58.3	60.2	59.8	54.9	48.8	40.9	35.1		
		MCDB	39.8	42.4	43.9	49.0	55.9	62.9	64.5	64.5	58.1	51.4	44.7	40.1		
	10%	WB	31.6	32.2	36.4	41.7	48.7	56.6	58.5	58.2	53.1	47.1	39.6	33.7		
		MCDB	37.1	39.1	42.2	46.6	53.4	61.1	62.7	62.5	56.3	50.1	43.2	39.1		
(35) Mean Daily Temperature Range	5% DB	MDBR	7.5	7.5	8.3	8.9	9.6	9.3	9.4	8.9	8.1	7.7	7.0	7.3		
		MCDBR	10.4	10.5	11.1	12.5	11.8	10.9	11.3	10.8	10.4	10.5	10.4	10.2		
		MCWBR	7.0	6.3	6.9	8.0	8.5	9.3	9.8	9.1	8.6	8.3	7.2	6.9		
		MCDBR	8.9	9.9	9.6	11.4	10.4	10.0	10.7	10.0	9.5	8.3	7.8	8.4		
	5% WB	MCWBR	6.7	6.8	6.7	7.7	8.1	9.0	9.5	8.8	8.0	7.1	6.1	6.5		
		MCWBR	6.7	6.8	6.7	7.7	8.1	9.0	9.5	8.8	8.0	7.1	6.1	6.5		
(40) Clear-Sky Solar Irradiance	taub		0.247	0.272	0.313	0.359	0.370	0.382	0.372	0.366	0.349	0.326	0.281	0.246		
	taud		2.391	2.360	2.315	2.249	2.294	2.299	2.323	2.355	2.387	2.437	2.480	2.433		
	Ebn at Noon		277	290	290	284	284	280	281	279	274	265	261	266		
	Edh at Noon		22	28	35	41	40	40	39	36	32	26	21	19		
(44) All-Sky Solar Radiation	RadAvg		496	788	1184	1421	1588	1857	1868	1607	1237	792	485	414		
	RadStd		64	98	165	210	149	147	147	128	110	102	76	55		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.67	N/A	N/A	+1.78	+1.30	+0.90	-229	-378	+194	+5
(47) Regional (117 neighbors)		N/A	N/A	N/A	+1.30	+0.72	+0.54	N/A	N/A	+104	+29

Nomenclature: See separate page