

CIMETTA, Switzerland

WMO: 067590

Lat: 46.2006N

Lon: 8.7917E

Elev: 1648

StdP: 83.03

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-10.8	-9.0	-25.4	0.5	-3.4	-23.4	0.6	-3.8	9.4	-1.4	8.3	-2.1	2.9	340	0.622

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	5.2	20.9	14.9	19.5	14.3	18.3	13.7	16.6	19.2	15.6	18.2	14.7	17.2	2.0	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
15.6	13.6	18.1	14.6	12.7	17.1	13.7	12.0	16.2	53.3	19.2	50.1	18.3	47.3	17.3	21.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.8	7.3	6.1	-12.2	22.8	2.5	2.2	-14.0	24.4	-15.4	25.6	-16.9	26.8	-18.7	28.4		
(5)			-13.5	18.0	2.1	1.5	-15.1	19.0	-16.3	19.8	-17.5	20.7	-19.1	21.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	5.9	-1.4	-1.3	1.1	4.0	8.2	12.3	14.3	14.1	10.1	6.8	2.2	-0.4
	DBStd	6.76	3.91	4.44	4.22	3.75	3.39	3.49	2.75	2.95	3.17	3.65	4.02	4.09
	HDD10.0	1932	353	318	276	184	76	17	3	3	36	110	235	321
	HDD18.3	4554	611	551	533	431	314	184	128	136	246	358	483	579
	CDD10.0	425	0	1	1	3	21	84	135	130	40	10	2	0
	CDD18.3	7	0	0	0	0	0	1	2	4	0	0	0	0
	CDH23.3	5	0	0	0	0	0	3	1	1	0	0	0	0
	CDH26.7	1	0	0	0	0	0	1	0	0	0	0	0	0
(14) Wind	WSAvg	2.4	2.4	2.3	2.6	2.7	2.6	2.4	2.4	2.3	2.2	2.2	2.5	2.3
(15) Precipitation	PrecAvg	1726	73	67	81	148	194	180	167	178	190	180	194	74
	PrecMax	2559	244	278	277	400	553	447	325	319	442	576	742	225
	PrecMin	993	0	4	6	13	71	27	31	21	20	10	3	0
	PrecStd	378	62	62	63	97	104	94	80	74	130	122	176	58
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.7	12.0	12.4	15.0	18.2	22.1	22.2	22.7	19.2	16.6	14.1	11.6
		MCWB	2.4	2.8	4.3	7.6	11.8	14.7	17.0	15.8	13.3	9.4	5.7	2.6
	2%	DB	8.3	9.5	10.1	12.4	16.0	19.8	20.4	21.0	17.0	14.3	11.2	8.7
		MCWB	1.2	2.0	3.1	6.5	10.5	14.3	15.3	14.7	12.3	7.9	4.8	1.4
	5%	DB	6.3	6.9	8.6	10.6	14.3	18.3	19.0	19.5	15.4	12.9	9.2	6.9
		MCWB	0.4	0.5	2.3	5.6	9.4	13.6	14.5	14.3	11.6	7.4	3.7	0.5
	10%	DB	4.3	5.0	6.9	9.0	12.9	17.0	17.9	18.1	14.2	11.4	7.4	5.3
		MCWB	-0.9	-0.4	1.7	4.8	8.4	13.0	13.9	13.7	10.8	6.9	2.8	-0.1
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	3.6	3.7	5.4	9.2	13.0	17.3	18.2	17.6	15.1	11.5	7.5	3.7
		MCDB	8.7	10.0	10.2	12.5	16.6	19.7	20.8	21.3	17.4	13.7	11.5	8.6
	2%	WB	2.1	2.4	4.2	7.7	11.6	15.8	16.7	16.4	13.7	10.2	6.0	2.6
		MCDB	6.5	7.9	7.9	11.1	14.9	18.3	18.9	19.3	15.7	11.7	8.9	5.7
	5%	WB	0.9	1.2	3.2	6.5	10.3	14.6	15.7	15.4	12.7	9.3	5.0	1.7
		MCDB	4.3	5.8	6.6	9.4	13.3	17.2	18.0	18.1	14.5	10.8	7.1	4.5
	10%	WB	-0.2	0.1	2.4	5.4	9.3	13.7	14.7	14.6	11.7	8.4	4.2	0.9
		MCDB	2.9	4.0	5.7	8.1	11.9	16.2	17.1	16.9	13.5	10.0	6.2	3.9
(35) Mean Daily Temperature Range	5% DB	MDBR	4.1	4.2	4.6	4.9	5.3	5.2	5.2	4.9	4.5	4.3	3.9	4.1
		MCDBR	5.8	5.8	6.2	6.9	6.5	6.0	6.3	6.0	5.8	5.8	5.8	5.6
		MCWBR	3.9	3.5	3.9	4.5	4.7	5.2	5.5	5.1	4.8	4.6	4.0	3.8
	5% WB	MCDBR	5.0	5.5	5.3	6.3	5.8	5.5	5.9	5.5	5.3	4.6	4.3	4.6
		MCWBR	3.7	3.8	3.7	4.3	4.5	5.0	5.3	4.9	4.5	3.9	3.4	3.6
(40) Clear-Sky Solar Irradiance	taub		0.247	0.272	0.313	0.359	0.370	0.382	0.372	0.366	0.349	0.326	0.281	0.246
	taud		2.391	2.360	2.315	2.249	2.294	2.299	2.323	2.355	2.387	2.437	2.480	2.433
	Ebn at Noon		874	913	914	895	895	883	887	880	864	836	823	839
	Edh at Noon		69	89	109	128	127	127	123	114	101	83	65	60
(44) All-Sky Solar Radiation	RadAvg		1.56	2.48	3.73	4.48	5.01	5.85	5.89	5.07	3.90	2.50	1.53	1.30
	RadStd		0.20	0.31	0.52	0.66	0.47	0.46	0.46	0.40	0.35	0.32	0.24	0.17

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	+0.37	N/A	N/A	+0.99	+0.72	+0.50	-127	-210	+108	+3
(47)	Regional (117 neighbors)	N/A	N/A	N/A	+0.72	+0.40	+0.30	N/A	N/A	+58	+16

Nomenclature: See separate page