

WEISSFLUHJOCH, Switzerland

WMO: 067800

Lat: 46.8333N

Lon: 9.8064E

Elev: 8750

StdP: 10.61

Time Zone: 1.00 (EUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-5.0	-1.2	-27.7	1.6	20.2	-22.0	2.3	20.0	40.9	12.9	34.9	15.3	13.7	0	0.909

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	10.8	59.4	47.7	56.5	46.8	54.0	45.7	49.9	56.2	48.2	54.4	46.8	52.4	7.9	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
47.1	66.7	51.7	45.4	62.3	50.2	43.9	58.9	49.0	23.4	56.2	22.3	54.3	21.4	52.5	57.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 33.2	27.9	24.2	DB	-8.4	66.6	4.6	3.7	-11.7	69.2	-14.4	71.4	-16.9	73.4	-20.3	76.1	(4)
(5)			WB	-8.8	53.1	4.4	1.9	-12.0	54.5	-14.6	55.6	-17.1	56.7	-20.4	58.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	29.7	16.8	15.9	20.0	25.8	32.0	40.6	44.4	44.5	38.1	33.6	25.0	19.4	(6)
(7)		DBStd	12.93	8.19	9.19	8.23	7.07	7.05	7.71	7.10	7.26	7.68	8.52	9.03	8.78	(7)
(8)		HDD50	7455	1031	954	931	727	557	292	197	198	360	508	751	949	(8)
(9)		HDD65	12868	1496	1374	1396	1177	1022	732	639	636	808	973	1201	1414	(9)
(10)		CDD50	63	0	0	0	0	0	11	23	27	2	0	0	0	(10)
(11)		CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	(11)
(12)		CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0	(12)
(13)		CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)
(14)	Wind	WSAvg	11.0	13.3	12.7	12.1	11.6	11.0	9.4	8.8	8.3	8.5	10.1	12.3	13.4	(14)
(15)	Precipitation	PrecAvg	46.1	2.8	2.9	2.8	2.8	3.8	5.4	5.7	6.0	4.0	3.3	3.6	3.0	(15)
(16)		PrecMax	62.3	7.0	9.8	6.3	6.7	6.5	10.4	9.3	10.4	7.4	7.8	10.2	8.4	(16)
(17)		PrecMin	36.3	0.3	0.7	0.5	0.6	1.3	2.6	3.0	1.5	1.5	0.2	0.0	0.2	(17)
(18)		PrecStd	5.8	1.8	2.0	1.5	1.2	1.6	1.9	1.5	1.9	1.6	1.6	2.0	1.9	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	36.8	38.7	38.7	42.9	51.2	60.7	62.4	63.0	56.4	52.6	45.6	38.8	(19)
(20)			MCWB	26.6	25.5	26.5	33.7	41.4	46.5	49.0	49.0	43.9	39.4	33.2	26.2	(20)
(21)		2%	DB	34.2	35.2	35.4	40.2	47.3	56.7	59.0	59.7	53.0	49.0	41.3	35.8	(21)
(22)			MCWB	25.2	24.9	25.9	32.4	39.3	46.1	48.2	48.1	43.0	38.2	30.8	24.9	(22)
(23)		5%	DB	30.7	31.1	32.9	37.6	44.5	53.8	56.0	56.4	50.0	46.3	38.7	33.3	(23)
(24)			MCWB	23.8	23.3	25.2	31.9	37.9	45.2	47.4	47.1	41.8	36.5	29.7	24.1	(24)
(25)		10%	DB	27.8	27.7	30.3	35.0	41.8	50.9	53.4	53.6	47.4	43.8	36.1	30.6	(25)
(26)			MCWB	22.6	22.2	24.6	30.2	36.2	44.0	46.1	45.9	40.6	35.2	28.4	24.3	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	30.3	29.7	30.5	35.8	43.2	50.1	52.2	52.1	47.1	42.6	36.9	30.3	(27)
(28)			MCD B	33.9	33.8	34.1	39.7	47.9	55.4	58.2	57.9	52.7	48.7	42.3	31.9	(28)
(29)		2%	WB	27.7	26.7	28.6	34.1	40.6	47.7	49.9	50.0	44.9	40.3	33.9	28.7	(29)
(30)			MCD B	30.5	30.2	31.6	38.0	45.5	53.8	56.5	56.4	50.0	45.6	38.3	31.3	(30)
(31)		5%	WB	25.6	24.8	27.1	32.5	38.6	46.2	48.3	48.3	43.4	38.7	31.8	26.9	(31)
(32)			MCD B	29.1	29.6	30.1	36.7	43.2	52.0	54.3	54.6	48.1	43.9	35.3	30.0	(32)
(33)		10%	WB	23.5	22.8	25.7	30.6	36.9	44.6	46.8	46.7	41.7	37.1	30.2	25.2	(33)
(34)			MCD B	27.4	27.8	29.1	34.3	40.9	50.1	52.2	52.4	46.1	41.7	33.6	29.3	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	8.5	8.3	8.3	8.1	8.1	9.4	10.8	10.8	9.6	9.1	8.0	8.5	(35)
(36)			MCDBR	9.8	9.5	8.8	8.9	10.3	12.2	13.7	13.8	12.5	11.2	9.0	9.4	(36)
(37)			MCWBR	6.6	5.9	5.9	6.2	7.2	7.9	8.5	8.4	8.9	7.9	6.2	6.1	(37)
(38)		5% WB	MCDBR	9.6	9.6	7.7	8.2	9.5	11.5	12.8	13.1	11.4	10.1	8.1	8.8	(38)
(39)			MCWBR	8.6	7.9	6.2	6.1	6.8	7.8	8.5	8.4	8.1	7.5	6.9	7.8	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.195	0.209	0.236	0.267	0.280	0.287	0.287	0.283	0.263	0.244	0.218	0.194	(40)	
(41)		taud	2.439	2.405	2.399	2.455	2.526	2.541	2.537	2.568	2.622	2.651	2.594	2.475	(41)	
(42)		Ebn at Noon	304	318	320	316	313	310	308	307	307	301	293	293	(42)	
(43)		Edh at Noon	20	26	31	33	32	31	31	29	25	21	17	17	(43)	
(44)	All-Sky Solar Radiation	RadAvg	470	766	1148	1405	1540	1782	1770	1543	1185	783	470	390	(44)	
(45)		RadStd	55	92	154	211	159	158	152	146	120	92	69	52	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (113 neighbors)		N/A	N/A	N/A	+1.19	+0.74	+0.61	N/A	N/A	+104	+27

Nomenclature: See separate page