

DISENTIS-SEDRUN, Switzerland

WMO: 067820

Lat: 46.7067N

Lon: 8.8533E

Elev: 3871

StdP: 12.75

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	10.7	14.4	-1.2	5.9	16.2	2.9	7.4	19.2	8.6	31.0	7.4	31.9	2.0	330	0.533

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.5	79.7	60.9	76.4	59.8	73.4	58.6	62.7	76.1	61.1	73.0	59.8	70.4	4.3	70

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
58.3	83.8	65.1	56.8	79.5	63.7	55.6	76.1	62.9	30.2	76.3	29.0	73.3	28.1	70.6	68.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9.7	8.1	7.0	6.0	84.3	5.1	2.9	2.3	86.4	-0.6	88.1	-3.5	89.7	-7.2	91.9
			4.6	65.4	4.7	1.6	1.2	66.5	-1.5	67.4	-4.1	68.3	-7.5	69.5
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	45.6	30.0	31.2	37.6	44.0	51.3	58.2	61.1	60.6	53.9	48.0	38.0	31.9
	DBStd	13.31	7.33	8.32	7.64	7.09	6.59	7.25	6.30	6.26	6.54	7.17	8.32	8.12
	HDD50	2901	620	525	386	201	63	14	4	4	36	121	365	562
	HDD65	7166	1085	945	849	630	424	221	151	163	334	527	810	1027
	CDD50	1284	0	0	1	21	105	262	346	332	153	59	5	0
	CDD65	77	0	0	0	0	1	19	29	27	1	0	0	0
	CDH74	569	0	0	0	0	9	166	204	182	8	0	0	0
	CDH80	77	0	0	0	0	0	25	24	28	0	0	0	0
	WSAvg	2.2	1.6	1.9	2.3	2.7	2.5	2.6	2.8	2.5	2.4	2.1	1.7	1.6
	PrecAvg	53.0	2.9	2.7	2.9	4.1	5.2	5.4	5.1	5.8	5.3	4.8	5.6	3.2
(15) Precipitation	PrecMax	71.9	7.2	8.2	6.8	11.1	15.4	10.4	9.6	8.9	14.2	17.3	22.4	6.8
	PrecMin	34.9	0.7	0.5	0.3	0.6	1.4	2.0	2.4	1.3	0.8	0.6	0.9	0.2
	PrecStd	9.1	1.6	1.9	1.7	2.5	3.2	2.4	1.8	1.7	3.6	3.3	4.7	1.7
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4% DB	49.2	53.2	60.2	67.6	75.0	83.2	83.0	83.5	74.9	68.3	59.2	51.1	
	0.4% MCWB	37.9	39.3	44.5	49.5	56.6	61.6	62.5	61.9	58.6	53.1	47.4	40.2	
	2% DB	44.9	47.9	55.8	62.6	70.2	78.7	79.0	78.8	71.2	64.1	54.6	47.5	
	2% MCWB	36.7	37.5	42.4	47.6	53.9	60.1	60.9	61.2	56.8	51.3	44.8	39.1	
	5% DB	42.3	44.3	52.0	58.8	66.4	74.9	75.9	75.1	67.6	60.9	51.4	44.8	
	5% MCWB	35.2	35.5	40.9	46.0	52.3	58.7	59.6	60.2	55.0	49.9	43.2	37.4	
	10% DB	39.7	41.5	48.4	55.1	62.6	71.2	72.6	71.5	64.0	57.8	48.8	42.0	
	10% MCWB	33.6	34.2	39.4	44.1	50.6	57.2	58.8	58.8	54.0	48.5	41.8	35.3	
	0.4% WB	40.6	41.0	45.9	50.9	58.1	63.8	64.6	64.5	60.2	55.0	48.5	42.4	
	0.4% MCDB	44.3	50.1	57.1	64.5	71.8	78.9	78.6	77.3	70.8	63.7	55.4	48.1	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2% WB	38.2	38.4	43.6	48.6	55.4	61.5	62.6	62.5	58.3	53.0	46.0	40.2	
	2% MCDB	43.2	45.6	53.4	60.7	67.4	75.3	76.0	75.3	67.9	61.1	52.4	45.6	
	5% WB	36.2	36.6	41.7	46.7	53.4	59.7	61.0	60.9	56.6	51.3	44.2	38.5	
	5% MCDB	41.0	42.9	50.1	56.7	64.0	72.1	72.6	71.9	64.8	58.3	49.7	43.2	
	10% WB	34.4	34.9	39.9	44.9	51.5	58.0	59.6	59.5	55.0	49.7	42.6	36.7	
	10% MCDB	38.5	40.6	47.3	53.6	60.5	69.0	70.2	69.0	61.9	55.9	47.9	40.9	
(35) Mean Daily Temperature Range	MDBR	10.3	12.1	14.7	15.5	16.1	17.8	17.5	16.2	15.1	13.8	10.6	9.6	
	5% DB MCDBR	12.4	15.5	19.3	20.8	21.7	23.9	22.7	22.1	20.1	17.8	14.0	12.3	
	5% DB MCWBR	7.5	8.9	10.3	10.1	10.3	10.1	9.1	9.1	9.3	9.3	7.9	7.4	
	5% WB MCDBR	11.1	14.3	17.7	18.7	19.4	21.9	20.4	19.6	17.4	15.6	12.6	11.2	
	5% WB MCWBR	7.3	8.7	9.6	9.4	9.6	9.9	8.9	8.7	8.4	8.5	7.4	7.3	
(40) Clear-Sky Solar Irradiance	taub	0.262	0.291	0.343	0.393	0.413	0.422	0.419	0.408	0.374	0.343	0.296	0.260	
	taud	2.308	2.232	2.151	2.108	2.160	2.193	2.204	2.252	2.329	2.385	2.405	2.347	
	Ebn at Noon	265	278	277	272	271	268	267	265	265	256	250	253	
	Edh at Noon	23	32	40	47	46	45	44	40	34	28	22	20	
(44) All-Sky Solar Radiation	RadAvg	481	781	1165	1408	1528	1788	1775	1542	1192	784	477	400	
	RadStd	59	93	167	224	153	161	156	141	118	91	69	53	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	+1.15	+1.06	+0.97	N/A	N/A	+131	+29
Regional (119 neighbors)	N/A	N/A	N/A	+1.30	+0.76	+0.58	N/A	N/A	+104	+29

Nomenclature: See separate page