

DISENTIS-SEDRUN, Switzerland

WMO: 067820

Lat: 46.7067N

Lon: 8.8533E

Elev: 1180

StdP: 87.93

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-11.8	-9.8	-18.5	0.8	-8.8	-16.1	1.1	-7.1	3.8	-0.6	3.3	-0.1	0.9	330	0.533

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.7	26.5	16.1	24.7	15.4	23.0	14.8	17.0	24.5	16.2	22.8	15.4	21.4	1.9	70

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
14.6	12.0	18.4	13.8	11.4	17.6	13.1	10.9	17.2	52.5	24.6	49.6	22.9	47.4	21.5	20.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 4.3	3.6	3.1	DB	-14.4	29.0	2.8	1.6	-16.5	30.2	-18.1	31.2	-19.7	32.1	-21.8	33.3	(4)
(5)			WB	-15.2	18.5	2.6	0.9	-17.1	19.2	-18.6	19.7	-20.1	20.2	-21.9	20.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	7.5	-1.1	-0.4	3.1	6.7	10.7	14.6	16.1	15.9	12.2	8.9	3.3	-0.1	(6)	
	DBStd	7.40	4.07	4.62	4.24	3.94	3.66	4.03	3.50	3.48	3.63	3.99	4.62	4.51	(7)	
	HDD10.0	1612	344	292	214	112	35	8	2	2	20	67	203	312	(8)	
	HDD18.3	3981	603	525	472	350	236	123	84	91	186	293	450	571	(9)	
	CDD10.0	713	0	0	1	12	58	146	192	184	85	33	3	0	(10)	
	CDD18.3	43	0	0	0	0	1	11	16	15	1	0	0	0	(11)	
	CDH23.3	316	0	0	0	0	5	92	113	101	4	0	0	0	(12)	
	CDH26.7	43	0	0	0	0	0	14	13	16	0	0	0	0	(13)	
(14) Wind	WSAvg	1.0	0.7	0.9	1.0	1.2	1.1	1.2	1.2	1.1	1.1	0.9	0.8	0.7	(14)	
(15) Precipitation	PrecAvg	1347	73	69	73	105	133	136	130	148	135	122	143	81	(15)	
	PrecMax	1825	184	208	172	282	390	264	245	226	360	439	569	172	(16)	
	PrecMin	887	19	13	8	14	36	50	60	33	20	14	22	4	(17)	
	PrecStd	230	41	48	43	64	82	60	45	43	91	85	120	42	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	9.6	11.8	15.7	19.8	23.9	28.5	28.3	28.6	23.9	20.2	15.1	10.6	(19)	
		MCWB	3.3	4.0	7.0	9.7	13.7	16.4	17.0	16.6	14.8	11.7	8.5	4.5	(20)	
	2%	DB	7.2	8.9	13.2	17.0	21.2	26.0	26.1	26.0	21.8	17.9	12.5	8.6	(21)	
		MCWB	2.6	3.1	5.8	8.7	12.2	15.6	16.0	16.2	13.8	10.7	7.1	3.9	(22)	
	5%	DB	5.7	6.9	11.1	14.9	19.1	23.9	24.4	23.9	19.8	16.0	10.8	7.1	(23)	
		MCWB	1.8	1.9	4.9	7.8	11.3	14.8	15.4	15.7	12.8	10.0	6.2	3.0	(24)	
	10%	DB	4.3	5.3	9.1	12.8	17.0	21.8	22.6	21.9	17.8	14.3	9.3	5.6	(25)	
		MCWB	0.9	1.2	4.1	6.7	10.3	14.0	14.9	14.9	12.2	9.2	5.4	1.8	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	4.8	5.0	7.7	10.5	14.5	17.7	18.1	18.0	15.7	12.8	9.2	5.8	(27)	
		MCDB	6.8	10.0	13.9	18.0	22.1	26.1	25.9	25.2	21.5	17.6	13.0	9.0	(28)	
	2%	WB	3.5	3.6	6.4	9.2	13.0	16.4	17.0	16.9	14.6	11.7	7.8	4.5	(29)	
		MCDB	6.2	7.6	11.9	15.9	19.7	24.0	24.4	24.0	19.9	16.1	11.3	7.6	(30)	
	5%	WB	2.4	2.6	5.4	8.2	11.9	15.4	16.1	16.1	13.6	10.7	6.8	3.6	(31)	
		MCDB	5.0	6.1	10.1	13.7	17.8	22.3	22.6	22.1	18.2	14.6	9.9	6.2	(32)	
	10%	WB	1.3	1.6	4.4	7.2	10.8	14.5	15.3	15.3	12.8	9.9	5.9	2.6	(33)	
		MCDB	3.6	4.8	8.5	12.0	15.8	20.6	21.2	20.5	16.6	13.3	8.8	5.0	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	5.7	6.7	8.2	8.6	9.0	9.9	9.7	9.0	8.4	7.7	5.9	5.3	(35)	
		MCDBR	6.9	8.6	10.7	11.6	12.0	13.3	12.6	12.3	11.1	9.9	7.8	6.8	(36)	
	5% WB	MCWBR	4.1	5.0	5.7	5.6	5.7	5.6	5.0	5.0	5.2	5.2	4.4	4.1	(37)	
		MCWBR	6.1	8.0	9.9	10.4	10.8	12.2	11.3	10.9	9.7	8.7	7.0	6.2	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.262	0.291	0.343	0.393	0.413	0.422	0.419	0.408	0.374	0.343	0.296	0.260	(40)	
		taud	2.308	2.232	2.151	2.108	2.160	2.193	2.204	2.252	2.329	2.385	2.405	2.347	(41)	
	Ebn at Noon		836	875	872	858	853	845	842	836	834	808	788	798	(42)	
		Edh at Noon	74	100	127	147	145	141	138	126	107	87	69	64	(43)	
(44) All-Sky Solar Radiation	RadAvg		1.52	2.46	3.67	4.44	4.82	5.64	5.59	4.86	3.76	2.47	1.50	1.26	(44)	
	RadStd		0.18	0.29	0.53	0.70	0.48	0.51	0.49	0.45	0.37	0.29	0.22	0.17	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	+0.64	+0.59	+0.54	N/A	N/A	+73	+16
(47) Regional (119 neighbors)		N/A	N/A	N/A	+0.72	+0.42	+0.32	N/A	N/A	+58	+16

Nomenclature: See separate page