

DAVOS, Switzerland

WMO: 067840

Lat: 46.8130N

Lon: 9.8435E

Elev: 1592

StdP: 83.61

Time Zone: 1.00 (EUC)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-16.6	-14.3	-23.4	0.6	-14.4	-19.9	0.8	-13.0	8.9	-1.8	7.6	-2.1	1.0	20	0.675

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.1	24.2	13.9	22.4	13.3	20.7	12.7	15.0	21.4	14.2	20.2	13.5	19.0	3.8	30

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12.9	11.3	16.6	12.1	10.7	15.6	11.3	10.1	14.8	47.8	21.3	45.2	20.3	43.0	19.3	18.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.4	6.9	6.0	-19.5	26.9	2.8	1.3	-21.5	27.9	-23.1	28.6	-24.6	29.4	-26.6	30.4		
(5)			-20.0	16.7	2.6	0.8	-21.9	17.3	-23.5	17.8	-24.9	18.3	-26.8	18.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	4.5	-4.8	-4.0	-0.4	3.9	7.5	11.9	13.2	13.0	9.2	6.2	0.9	-3.3		
	DBStd	7.54	4.05	4.88	4.30	3.73	3.67	3.70	3.44	3.39	3.51	4.09	4.57	4.41		
	HDD10.0	2367	458	393	324	185	94	23	12	12	56	125	274	411		
	HDD18.3	5064	716	626	582	434	336	195	162	167	274	377	524	669		
	CDD10.0	349	0	0	0	1	17	79	111	104	31	7	0	0		
	CDD18.3	4	0	0	0	0	0	1	2	1	0	0	0	0		
	CDH23.3	79	0	0	0	0	0	20	33	27	0	0	0	0		
	CDH26.7	3	0	0	0	0	0	2	1	1	0	0	0	0		
(14) Wind	WSAvg	2.2	1.5	1.8	2.1	2.4	2.6	2.7	2.7	2.5	2.4	2.1	1.9	1.7		
(15) Precipitation	PrecAvg	1172	71	74	70	71	97	138	144	152	102	85	91	77		
	PrecMax	1583	178	250	160	169	164	263	236	265	189	199	258	214		
	PrecMin	923	7	18	13	15	32	66	76	37	38	5	0	6		
	PrecStd	148	46	51	37	31	40	47	39	47	40	41	52	49		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	6.0	8.7	12.2	17.1	21.4	26.0	26.2	25.7	21.6	18.9	13.6	7.9		
		MCWB	1.4	2.1	3.9	7.8	10.9	13.7	14.3	14.1	12.7	9.7	6.6	2.9		
	2%	DB	4.0	6.0	10.2	14.8	18.9	23.3	24.1	23.9	19.4	16.5	10.9	5.5		
		MCWB	0.8	0.9	3.1	6.7	10.0	13.3	14.1	14.2	11.7	8.9	5.4	1.6		
	5%	DB	2.2	4.2	8.4	12.9	16.7	21.4	22.2	21.9	17.7	14.6	8.9	3.5		
		MCWB	-0.1	0.0	2.4	5.8	9.1	12.7	13.4	13.5	11.2	8.1	4.4	0.6		
	10%	DB	0.9	2.3	6.4	10.7	14.5	19.2	20.2	19.8	15.6	12.5	6.9	2.0		
		MCWB	-0.7	-0.7	1.6	4.5	8.1	12.0	12.7	12.9	10.2	7.4	3.5	0.0		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	2.7	3.1	4.9	8.4	12.2	15.5	16.0	16.2	14.0	11.1	7.5	3.7		
		MCDB	4.1	6.5	10.0	15.2	18.7	21.6	22.5	22.3	19.2	16.1	11.9	6.5		
	2%	WB	1.4	1.7	3.8	7.4	10.8	14.2	15.0	15.1	12.6	9.9	6.0	2.3		
		MCDB	3.0	4.9	8.7	13.7	16.7	20.8	21.7	21.2	17.3	14.4	9.7	4.2		
	5%	WB	0.4	0.5	2.8	6.2	9.7	13.4	14.1	14.1	11.7	8.9	4.8	1.3		
		MCDB	1.8	3.2	7.3	11.6	15.3	19.7	20.1	19.7	16.1	13.1	8.1	2.9		
	10%	WB	-0.7	-0.4	1.8	5.1	8.7	12.6	13.4	13.3	10.8	8.0	3.8	0.2		
		MCDB	0.8	2.1	5.8	9.9	13.7	18.1	18.7	18.5	14.6	11.6	6.6	1.8		
(35) Mean Daily Temperature Range	5% DB	MDBR	7.8	9.3	9.5	9.7	9.5	10.0	10.1	9.8	9.3	9.6	7.8	7.1		
		MCDBR	8.6	10.9	12.3	13.3	13.4	13.8	13.7	13.3	12.8	12.9	10.4	8.4		
	5% WB	MCWBR	6.3	7.0	6.9	6.7	6.5	6.2	5.9	5.9	6.7	6.9	6.2	5.6		
		MCWBR	7.6	9.4	10.7	12.2	11.7	12.2	11.9	11.8	11.0	11.0	9.4	7.2		
(40) Clear-Sky Solar Irradiance	taub		0.226	0.246	0.282	0.323	0.339	0.346	0.345	0.339	0.311	0.286	0.255	0.225		
		taud	2.374	2.322	2.293	2.319	2.385	2.405	2.404	2.440	2.506	2.552	2.517	2.414		
	Edn at Noon		900	942	947	932	925	917	913	906	908	887	859	861		
		Edh at Noon	68	90	109	118	115	114	113	104	89	72	60	58		
(44) All-Sky Solar Radiation	RadAvg		1.49	2.43	3.63	4.43	4.85	5.61	5.58	4.87	3.74	2.48	1.49	1.24		
	RadStd		0.17	0.29	0.48	0.66	0.50	0.49	0.48	0.46	0.38	0.29	0.22	0.16		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (113 neighbors)	N/A	N/A	N/A	+0.66	+0.41	+0.34	N/A	N/A	+58	+15

Nomenclature: See separate page