

PIZ CORVATSCH, Switzerland

WMO: 067910

Lat: 46.4181N

Lon: 9.8211E

Elev: 3299

StdP: 67.48

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	-23.5	-21.6	-35.3	0.2	-11.1	-32.4	0.3	-10.8	15.6	-10.9	13.6	-11.7	6.8	40	0.977

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	4.1	9.2	5.1	8.0	4.5	7.0	3.8	6.2	8.2	5.3	7.2	4.5	6.3	2.5	280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5.3	8.3	7.1	4.2	7.7	6.1	3.4	7.3	5.3	28.7	8.3	26.3	7.3	24.2	6.4	10.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 13.0	11.3	10.0	DB	-24.9	10.9	2.6	1.5	-26.8	12.0	-28.3	12.8	-29.8	13.7	-31.7	14.7	(4)
(5)			WB	-25.2	8.0	2.5	1.1	-27.0	8.8	-28.4	9.4	-29.8	10.1	-31.6	10.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	-4.9	-11.4	-11.7	-10.2	-7.7	-3.5	0.6	2.7	2.8	-0.6	-2.9	-7.6	-10.2	(6)
(7)		DBStd	6.64	4.44	4.87	4.53	3.81	3.35	3.72	3.24	3.20	3.58	3.97	4.84	4.74	(7)
(8)		HDD10.0	5447	663	608	625	529	418	283	226	222	318	401	527	625	(8)
(9)		HDD18.3	8488	922	842	883	779	676	533	484	481	568	659	777	883	(9)
(10)		CDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(10)
(11)		CDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(11)
(12)		CDH23.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(12)
(13)		CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)
(14)	Wind	WSAvg	4.5	6.0	5.5	5.3	4.2	3.9	3.4	3.2	3.1	3.5	4.5	5.3	5.9	(14)
(15)	Precipitation	PrecAvg	970	50	32	41	69	100	110	107	108	95	105	106	48	(15)
(16)		PrecMax	1513	173	138	155	161	231	275	219	189	247	314	470	123	(16)
(17)		PrecMin	551	2	0	0	0	41	28	51	16	7	0	0	0	(17)
(18)		PrecStd	222	41	30	31	47	45	58	37	38	69	71	114	32	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	-0.3	0.2	-0.8	1.1	5.1	10.4	10.4	10.8	7.6	5.5	2.7	-0.1	(19)
(20)			MCWB	-5.4	-5.5	-5.5	-3.2	1.5	4.5	6.5	6.3	2.0	-0.7	-3.2	-5.7	(20)
(21)		2%	DB	-2.3	-1.8	-2.1	-0.1	3.5	8.1	9.0	9.2	6.1	4.1	1.0	-1.9	(21)
(22)			MCWB	-6.5	-6.8	-5.9	-3.4	0.3	4.3	5.5	4.9	1.4	-1.4	-4.3	-6.7	(22)
(23)		5%	DB	-4.0	-3.6	-3.3	-1.3	2.2	6.7	7.8	8.0	5.1	3.0	-0.3	-3.2	(23)
(24)			MCWB	-7.3	-7.5	-6.6	-4.1	-0.4	3.6	4.7	4.5	1.0	-1.6	-4.4	-7.1	(24)
(25)		10%	DB	-5.3	-5.4	-4.5	-2.7	0.9	5.4	6.7	7.0	4.0	1.9	-1.8	-4.3	(25)
(26)			MCWB	-8.2	-8.3	-7.1	-4.8	-1.2	2.8	3.9	3.9	0.6	-2.2	-5.1	-7.4	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	-3.7	-3.9	-3.7	-1.3	2.6	6.4	7.9	7.6	4.6	1.7	-0.8	-3.8	(27)
(28)			MADB	-2.7	-1.6	-2.5	-0.2	4.2	8.5	9.4	9.4	5.9	3.2	0.4	-2.3	(28)
(29)		2%	WB	-5.5	-5.9	-4.8	-2.4	1.2	5.1	6.3	6.3	3.5	0.7	-2.3	-4.9	(29)
(30)			MADB	-3.8	-3.8	-3.5	-1.1	2.8	7.3	8.2	8.1	4.8	2.0	-1.1	-3.9	(30)
(31)		5%	WB	-6.6	-6.9	-5.8	-3.5	0.2	4.1	5.3	5.4	2.6	-0.1	-3.3	-5.8	(31)
(32)			MADB	-4.6	-4.4	-4.4	-2.1	1.5	6.1	7.2	7.2	3.9	1.1	-2.0	-4.5	(32)
(33)		10%	WB	-7.7	-7.9	-6.6	-4.4	-0.8	3.2	4.5	4.5	1.7	-0.9	-4.2	-6.8	(33)
(34)			MADB	-5.9	-5.4	-5.1	-3.2	0.4	5.0	6.2	6.3	3.0	0.6	-2.8	-5.1	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	4.3	4.4	4.2	3.9	3.7	3.9	4.3	4.1	3.6	3.6	3.8	4.3	(35)
(36)			MADB	4.5	4.7	4.2	3.9	4.0	4.7	5.2	4.8	4.0	3.6	3.7	4.1	(36)
(37)			MCWBR	3.9	3.4	3.4	3.8	4.4	4.7	5.2	5.1	4.6	3.3	2.9	3.1	(37)
(38)		5% WB	MADB	5.0	5.1	4.1	3.6	3.7	4.5	4.8	4.5	3.6	3.3	3.3	4.4	(38)
(39)			MCWBR	5.0	4.6	3.9	3.8	4.0	4.7	5.0	5.0	4.5	3.6	3.4	4.2	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.187	0.202	0.231	0.265	0.276	0.285	0.281	0.276	0.261	0.241	0.210	0.186	(40)	
(41)		taud	2.430	2.394	2.380	2.398	2.485	2.494	2.504	2.537	2.568	2.609	2.564	2.460	(41)	
(42)		Ebn at Noon	977	1014	1015	998	991	979	979	976	969	954	938	944	(42)	
(43)		Edh at Noon	64	83	100	109	104	104	102	94	83	67	56	55	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1.61	2.57	3.80	4.49	4.88	5.68	5.71	4.95	3.84	2.54	1.56	1.34	(44)	
(45)		RadStd	0.20	0.30	0.52	0.68	0.49	0.46	0.46	0.43	0.37	0.32	0.24	0.17	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	+1.02	+0.70	+0.57	N/A	N/A	N/A	N/A
(47) Regional (103 neighbors)		+0.33	N/A	N/A	+0.71	+0.44	+0.34	N/A	N/A	+61	+15

Nomenclature: See separate page