

POSCHIAVO-ROBBIA, Switzerland

WMO: 067940

Lat: 46.3472N

Lon: 10.0631E

Elev: 3542

StdP: 12.91

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	12.5	15.7	-7.3	4.2	26.2	-2.4	5.5	26.1	31.9	42.5	28.8	40.6	2.5	50	0.563

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	20.6	79.5	62.7	76.5	61.8	73.9	60.3	65.2	75.2	63.7	72.8	62.2	70.7	8.1	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
61.9	94.4	68.9	60.4	89.4	67.3	59.0	85.1	66.0	32.2	75.2	30.9	72.6	29.8	70.9	71.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 25.2	21.2	17.9	DB	7.4	83.7	3.9	3.3	4.6	86.0	2.3	87.9	0.1	89.8	-2.7	92.1	(4)
(5)			WB	6.2	67.6	3.8	1.8	3.5	68.9	1.2	70.0	-0.9	71.0	-3.7	72.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	46.3	30.0	32.1	39.2	45.6	52.5	59.3	62.0	61.5	54.2	47.5	38.9	32.5	(6)	
	DBStd	12.51	5.95	6.51	6.48	5.39	4.85	5.50	4.31	4.48	4.81	5.30	5.93	6.48	(7)	
	HDD50	2643	620	502	336	151	28	3	0	0	16	110	333	544	(8)	
	HDD65	6857	1084	922	799	583	389	182	112	127	325	543	782	1009	(9)	
	CDD50	1310	0	0	3	18	105	282	371	356	142	32	1	0	(10)	
	CDD65	48	0	0	0	0	0	12	19	17	0	0	0	0	(11)	
	CDH74	574	0	0	0	0	13	174	208	174	5	0	0	0	(12)	
	CDH80	66	0	0	0	0	1	22	16	27	0	0	0	0	(13)	
	WSAvg	4.4	4.9	4.9	5.7	5.3	4.9	4.4	4.2	3.5	3.4	3.4	3.9	4.5	(14)	
	PrecAvg	36.2	1.8	1.2	1.5	2.4	3.4	4.2	4.1	4.2	3.5	3.9	4.2	1.8	(15)	
(16) Precipitation	PrecMax	56.7	6.9	4.9	6.3	5.4	8.2	10.4	8.0	7.1	9.1	11.8	17.5	4.6	(16)	
	PrecMin	21.2	0.1	0.0	0.0	0.0	1.1	1.3	1.9	0.6	0.3	0.0	0.0	0.0	(17)	
	PrecStd	8.1	1.5	1.1	1.3	1.6	1.5	2.1	1.3	1.3	2.4	2.7	4.2	1.2	(18)	
(20) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	54.4	55.8	63.2	69.4	75.4	82.7	82.1	83.2	73.9	67.7	59.3	55.6	(19)	
		MCWB	40.8	41.6	44.9	51.4	58.0	62.1	64.0	63.9	59.9	52.5	45.4	40.9	(20)	
	2%	DB	47.4	49.2	58.8	64.8	71.2	78.6	79.0	78.4	70.5	63.2	53.6	49.9	(21)	
		MCWB	36.3	37.6	43.7	48.9	55.7	61.9	63.0	62.7	58.7	51.3	42.8	37.5	(22)	
	5%	DB	42.3	45.2	55.0	61.2	67.8	75.4	76.2	75.1	67.2	60.0	50.1	45.0	(23)	
		MCWB	33.2	35.3	41.5	46.6	53.9	60.4	61.9	62.0	56.3	49.9	42.4	35.5	(24)	
	10%	DB	38.8	41.7	51.0	57.5	64.2	71.9	73.4	72.0	63.9	56.6	47.3	41.4	(25)	
		MCWB	31.6	33.4	39.8	44.8	51.7	58.8	60.4	60.5	54.6	49.3	41.9	34.5	(26)	
	0.4%	WB	41.7	42.3	46.8	53.1	60.5	66.5	67.4	66.9	62.5	56.2	49.6	42.9	(27)	
		MCDB	53.3	54.0	58.5	66.4	70.9	77.4	76.8	77.5	70.1	61.2	53.0	47.3	(28)	
(30) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	37.2	38.6	44.7	50.6	57.6	64.1	65.3	64.9	60.2	54.4	46.8	40.0	(29)	
		MCDB	44.1	46.7	54.3	61.3	68.0	74.3	75.2	74.4	67.3	58.7	50.1	45.4	(30)	
	5%	WB	35.1	36.4	43.0	48.3	55.5	62.2	63.6	63.3	58.5	52.7	45.0	37.9	(31)	
		MCDB	39.1	42.9	52.1	57.4	64.6	72.0	72.6	71.9	64.5	56.7	47.7	43.0	(32)	
	10%	WB	33.6	34.7	41.1	46.4	53.6	60.3	62.1	61.9	56.7	51.0	43.3	35.7	(33)	
		MCDB	36.9	39.6	49.4	54.3	60.9	69.2	70.5	69.4	61.8	54.8	45.9	39.5	(34)	
(36) Mean Daily Temperature Range	5% DB	MDBR	15.0	15.6	17.6	18.6	18.9	20.4	20.6	19.5	17.7	16.1	14.0	14.5	(35)	
		MCDBR	19.6	20.3	25.2	26.7	26.7	26.4	25.1	24.4	22.4	21.8	18.7	19.3	(36)	
		MCWBR	11.7	11.4	13.2	13.3	13.5	12.5	12.0	11.6	12.2	12.0	10.9	10.8	(37)	
	5% WB	MCDBR	14.7	17.7	21.5	22.5	22.8	23.3	22.2	21.5	19.9	16.4	13.7	14.7	(38)	
		MCWBR	9.5	10.5	12.1	11.8	12.3	12.1	11.8	11.2	11.4	10.1	9.1	9.2	(39)	
(40) Clear-Sky Solar Irradiance	taub		0.253	0.280	0.330	0.384	0.396	0.409	0.401	0.391	0.368	0.335	0.288	0.252	(40)	
	taud		2.333	2.266	2.212	2.159	2.225	2.241	2.270	2.315	2.356	2.419	2.443	2.377	(41)	
	Ebn at Noon		272	284	282	276	276	272	273	271	267	261	256	260	(42)	
	Edh at Noon		23	31	38	44	43	43	41	38	33	27	21	20	(43)	
(44) All-Sky Solar Radiation	RadAvg		509	807	1203	1431	1574	1820	1837	1591	1230	808	495	423	(44)	
	RadStd		61	95	158	205	159	139	138	134	114	104	78	53	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	+0.86	+1.93	-3.73	+1.08	+1.17	+1.08	-227	-326	+142	+27	(46)
(47)	Regional (99 neighbors)	+0.59	N/A	N/A	+1.22	+0.79	+0.63	N/A	N/A	+104	+23	(47)

Nomenclature: See separate page